



Teaneck Board of Education
Energy Savings Plan Rev.1

Project Number: ESG-Project # DPBWI00575

Teaneck, New Jersey | March 27th, 2020



TABLE OF CONTENTS

Section 1. Executive Summary..... 5
 Energy Savings..... 5
 Benefits..... 5

Section 2. Project Description..... 6
 Facility Descriptions..... 7
 Utility Baseline Analysis..... 25
 Marginal Rates..... 28
 Utility Breakdown by Building..... 32
 Utility Escalation Rates..... 32

Section 3. Financial Impact..... 33
 Energy Savings and Cost Summary..... 33
 Business Case for Recommended Project..... 39
 Greenhouse Gas Reductions..... 41

Section 4. Energy Conservation Measures..... 42
 1-1 Comprehensive LED Lighting Upgrades..... 42
 1-2 Direct Install Program (Lighting)..... 44
 1-3 Install VFD's and Premium Motor Upgrades for HVAC..... 50
 2-1 Plug Load Controls..... 52
 2-2 Combined Heat and Power (35 kW)..... 54
 2-3 Computer Power Management Software..... 56
 2-4 Refrigeration Controls..... 57
 2-5/2-7 Direct Install Program Fuel Use Economizers..... 60
 2-6 Direct Install Program - Low-flow Domestic Hot Water Devices..... 62
 3-4 Replace Cooling in Media Center (Ben Franklin Middle School)..... 64
 3-5 Replace Cooling in Media Center (Lowell Elementary School)..... 66
 3-6 Replace Rooftop Cooling Unit at Whittier Elementary School..... 68
 4-1 Condensing Hot Water Boiler Plant (Teaneck High School – Fan Room Upgrades)..... 70
 4-1 Condensing Hot Water Boiler Plant (Teaneck High School – Hot Water Header Pipe)..... 73

Teaneck Board of Education Energy Savings Plan

| | |
|--|------------|
| 4-2 Replace Domestic Hot Water Tank at Benjamin Franklin Middle School..... | 74 |
| 4-3 Replace Steam Traps..... | 76 |
| 5-3 Refurbish Cooling Tower | 78 |
| 5-4 Unit Ventilator Replacement at Teaneck High School (Second and Third Floor)..... | 80 |
| 5-5 Unit Ventilator Refurbishment – Teaneck High School (First Floor)..... | 83 |
| 6-1 Upgrade Building Management System | 85 |
| 6-2 Operational Verification and HVAC Improvements..... | 90 |
| 7-1 Building Envelope Weatherization | 92 |
| 7-3 Repair Missing Pipe Insulation | 95 |
| Section 5. Measurement and Verification | 99 |
| Measurement & Verification (M&V) Methodologies | 99 |
| Selecting M&V Options for a Specific Project | 100 |
| Recommended Performance Verification Steps | 101 |
| Measurement and Verification Services | 106 |
| Section 6. Customer Support | 108 |
| Maintenance Impacts/ On-Going Service | 108 |
| Design and Compliance Issues | 109 |
| Customer Risks | 109 |
| Public Engagement and Community Outreach..... | 109 |
| Section 7: Implementation Schedule | 111 |
| Section 8. Sample Energy Performance Contract..... | 112 |
| Appendix 1. Energy Conservation Measures Investigated but Not Recommended at This Time..... | 113 |
| ECM: Replace Exhaust Fan Motors with EC Motors | 113 |
| ECM: Destratification Fans | 114 |
| ECM: Addition of Air-Cooled Chillers..... | 115 |
| ECM: Replace Cafeteria Roof Top Unit at Bryant Elementary School..... | 116 |
| ECM: Install High Efficiency Domestic Water Heaters..... | 117 |
| ECM: Addition of Cooling to Cafeteria at Middle Schools | 118 |

Teaneck Board of Education Energy Savings Plan

| | |
|---|------------|
| ECM: Replace Water-Cooled Chiller with Air-Cooled Chiller | 119 |
| Appendix 2. Energy Savings Calculations..... | 120 |
| Energy Savings..... | 120 |
| Operational Savings | 120 |
| Appendix 3. Building Envelope Scope Drawings..... | 122 |
| Appendix 4. Detailed Scope Descriptions | 140 |
| Building Envelope Weatherization | 140 |
| Plug Load Controls | 142 |
| Mechanical Insulation | 145 |
| Steam Trap Replacements | 152 |
| Boiler Combustion Report Data | 162 |
| Boiler HW Trends and Data..... | 171 |
| Appendix 5. Recommended Project - ESP..... | 191 |
| Appendix 6. Lighting Upgrades..... | 192 |
| Data Logger Reports | 226 |
| Appendix 7. Third Party Energy Savings Plan Review Comments & Correspondence (DLB Associates)..... | 233 |

Teaneck Board of Education
Energy Savings Plan

This page is intentionally left blank.

SECTION 1. EXECUTIVE SUMMARY

Various energy conservation measures were evaluated in the development of this Energy Savings Plan (ESP). Energy Systems Group has performed field verifications, collected data and taken field measurements to ensure the development of the most cost-effective solutions as well as accurate savings calculations. Various solutions were reviewed with the school district's administration to develop a set of Energy Conservation Measures (ECMs) that allow the school district to address the facility's priority items while reducing the total annual energy spend for the District. This study expands upon the original energy audit conducted by Camp Dresser and McKee (CDM). The original audit information was used for building descriptions as well as an overall indication of the District's needs.

Priority items include:

- Comprehensive LED Lighting Upgrades
- Replace Rooftop Cooling Unit at Whittier Elementary School
- Unit Ventilator Replacement at Teaneck High School
- Boiler Room Upgrade/ Replacement at Teaneck High School

Energy Savings

Energy saving calculations performed in the development of this ESP was completed using Microsoft Excel worksheets with Bin weather data to accurately model the building systems. Additional spreadsheets were used for measures that are not affected by the weather, such as lighting savings. Energy savings have been provided electronically for ease of review. All the energy savings calculations that have been performed are in accordance with the New Jersey Clean Energy Program Protocols to Measure Resource Savings.

Benefits

The measures investigated in this Energy Savings Plan could result in an annual utility savings of 1,697,814 kWh's of electricity and save 100,381 therms of natural gas. The total utility cost savings is \$7,544,068 over the life of the project (19 years). Additionally, these energy savings will result in a net reduction of greenhouse gases and will reduce the school district's carbon footprint by **3,507,204 lbs.** of CO₂ annually. All these savings are achieved while improving the classroom environment and renewing many items that have been in service beyond useful life expectancy

SECTION 2. PROJECT DESCRIPTION

This Energy Savings Plan (ESP) addresses the following facilities. Any description in this report-stating district wide or similar refers only to the buildings listed below:

| Teaneck Board of Education | |
|--|--|
| Benjamin Franklin Middle School | 1315 Taft Road, Teaneck, NJ 07666 |
| Bryant Elementary School | 1 Tryon Avenue, Teaneck, NJ 07666 |
| Hawthorne Elementary School | 201 Fycke Lane, Teaneck, NJ 07666 |
| Lowell Elementary School | 1025 Lincoln Place, Teaneck, NJ 07666 |
| Teaneck High School | 100 Elizabeth Avenue, Teaneck, NJ 07666 |
| Thomas Jefferson Middle School | 655 Teaneck Road, Teaneck, NJ 07666 |
| Whittier Elementary School | 491 W Englewood Avenue, Teaneck NJ 07666 |

Facility Descriptions

Benjamin Franklin Middle School



Benjamin Franklin Middle School

Background Information

Benjamin Franklin Middle School is located at 1315 Taft Road in Teaneck, New Jersey. This 100,202 ft² facility was originally built in 1957.

Building Occupancy

Approximate enrollment is 575 students with 105 staff members, including frequent visitors. Full occupancy of the building is through the months of September to June. Partial occupancy of the building remains throughout the summer months for school classes and camps.

Hours of Operation

- Monday through Friday 6:00 am to 4:00 pm (students/staff)
- Monday through Friday 6:00 AM to 12:00 AM (custodial staff)
- Saturday and Sunday hours vary

Envelope

Benjamin Franklin Middle School is a single structure building. The exterior wall of the building is composed of a brick façade. The roof of the building is flat with an EPDM overlay, while some older sections of the roof consist of spray foam insulation with gravel finish. Evidence of leakage and deterioration is seen in the older roof system.

The building has double paned windows and energy efficient FRP doors. The existing weather stripping on the building's doors appears to be in poor condition and should be replaced.

Lighting

Many light fixtures throughout the building consist of linear fluorescent fixtures which contain T8 fixtures with electronic ballast. Light fixtures also include metal halide, incandescent or CFL fixtures. Replacing the fixtures with LED technology would be a great opportunity for energy savings.

Mechanical Systems

HVAC Systems and Equipment. The entire building is heated by three (3) gas-fired condensing hot-water boilers. All boilers are located in the buildings' boiler room. Hot water generated by the boilers is circulated to the classrooms' fan coil unit ventilators by constant-speed pumps.

Air handling units with DX cooling coils provide heating or cooling to the zones they serve. Cooling throughout the building is provided by a ductless split system and AC units.

Teaneck Board of Education Energy Savings Plan

Hot Water Systems

Domestic Hot Water: The building is supplied hot water by one (1) natural gas-fired hot water heater.

Building Controls (HVAC Controls)

The building's HVAC equipment for rooms and zones are controlled by the building management system. The building's rooftop units are controlled by the building management system. The normal temperature set points for Benjamin Franklin Middle School are as follows:

| Time Period | Heating Season | Cooling Season |
|-------------------------|----------------|----------------|
| Occupied Hours | 68-72°F | 72-76°F |
| Unoccupied Hours | 55°F | 80°F |

Plug Load

The classrooms throughout Teaneck Board of Education contain computers, printers, TV's and overhead projectors. Many schools have computer centers and library's which contain 20 or more computers in each. Most schools also have office areas that contain copiers, microwaves, refrigerators, vending machines and coffee makers.

Bryant Elementary School



Background Information

Bryant Elementary School is located at 1 Tryon Ave in Teaneck, New Jersey. This 47,438 ft² facility was originally built in 1926.

Hours of Operation

- Monday through Friday 6:00 am to 4:00 pm (students/staff)
- Weekends – Closed

Building Occupancy

Approximate enrollment at Bryant Elementary School is 386 students. The school has approximately 76 staff members.


Full occupancy of the building is through the months of September to June. Partial occupancy of the building remains throughout the summer months for school classes and camps.

Envelope

The building is a single structure with a brick façade and an insulated exterior finish system. The building has flat roofs with an EPMD overlay. Pitched sections of the roof have slate shingles that appear to be original to the building. The building windows are mostly double paned and appear to be in good condition. Exterior doors on the building FRP energy efficient FRP doors. The weather stripping for these doors is in poor condition. There is gapping between the main entry door and the door frame.

Lighting

The majority of light fixtures throughout the building consist of linear fluorescent fixtures which contain T8 fixtures with electronic ballast. Light fixtures also include metal halide, incandescent or CFL fixtures. Replacing the fixtures with LED technology would be a great opportunity for energy savings.



Bryant Elementary School
Building Envelope

Mechanical Systems

HVAC Systems and Equipment: The building is provided heat by two (2) gas-fired steam boilers that are located in the boiler room. The steam generated by the boilers is ran through a heat exchanger and supplied to the classroom unit ventilators. The building utilizes two (2) DX air handling units, one is located on the roof while the other is outside on ground-level. The original built structure utilizes both unit ventilators and two-pipe steam radiator units to provide steam generated heat.

Cooling for the building is supplied by a ductless split system and individual AC units for space cooling throughout the school.



**Bryant Elementary School
Boilers**

Domestic Hot Water Systems

Domestic Hot Water: The building is supplied hot water by two electric water heaters. One water heater is 50 gallons while the other holds 40 gallons.

Building Controls (HVAC Controls)

Bryant has all systems on the BMS control. Additionally, all UVs are tied to a thermostat and a CO2 monitor for each designated area.

Plug Load

The classrooms throughout Teaneck Board of Education contain computers, printers, TV's and overhead projectors. Many schools have computer centers and library's which contain 20 or more computers in each. Most schools also have office areas that contain copiers, microwaves, refrigerators, vending machines and coffee makers.



**Bryant Elementary School
Hot Water Heater**

Hawthorne Elementary School



Background Information

The Hawthorne Elementary School is located at 201 Fycke Ln in Teaneck, New Jersey. This 49,373 ft² facility was originally built in 1925 and is in fair condition.

Building Occupancy

Approximately 342 students are enrolled at Hawthorne Elementary School. There is approximately 60 full-time or part-time employees year-round. Full occupancy of the building is through the months of September to June. Partial occupancy of the building remains throughout the summer months for school classes and camps.

Hours of Operation

- Monday through Friday 6:00 am to 4:00 pm (students/staff)
- Sunday 11:00 am to 3:00 pm

Envelope

The building's exterior wall is brick façade. This building has a flat EPDM roof with pitched roof decks. The roof decks appear to be original to the building. The roof decks contain asbestos composite shingling. The windows throughout the building are double panned. The building has many window AC units that are shielded by AC covers during the winter months.

Lighting

The majority of light fixtures throughout the building consist of linear fluorescent fixtures which contain T8 fixtures with electronic ballast. Light fixtures also include metal halide, incandescent or CFL fixtures. Replacing the fixtures with LED technology would be a great opportunity for energy savings.

Mechanical Systems

HVAC Systems and Equipment: Hawthorne Elementary School is heated by two (2) gas-fired steam boilers that are located in the boiler room. Steam generated by the boilers is ran through a heat exchanger that supplies hot water to the building unit ventilators. There are two (2) air handling units equip with DX cooling coils. One unit is located on the roof, while the other is located in the cafeteria. Both air handling units provide heating, cooling and outdoor air for ventilation. An older section of the building utilizes steam heating from either unit ventilators or two-pipe steam radiator units.

Additional cooling is provided to the office spaces by a ductless split system and individual AC units.



Hawthorne Elementary School
Boiler Room

Domestic Hot Water Systems

The building is supplied domestic hot water by one (1) 80-gallon electric hot water heater.



Hawthorne Elementary School
Hot Water Heater

Teaneck Board of Education Energy Savings Plan

Building Controls (HVAC Controls)

Hawthorne has all systems on the BMS control. Additionally, all UVs are tied to a thermostat and a CO2 monitor for each designated area.

The typical set points for Hawthorne Elementary School are as follows:

| Time Period | Heating Season | Cooling Season |
|-------------------------|----------------|----------------|
| Occupied Hours | 68-72°F | 72-76°F |
| Unoccupied Hours | 55°F | 80°F |

Plug Load

The classrooms throughout Teaneck Board of Education contain computers, printers, TV's and overhead projectors. Many schools have computer centers and library's which contain 20 or more computers in each. Most schools also have office areas that contain copiers, microwaves, refrigerators, vending machines and coffee makers.

Lowell Elementary School



Background Information

Lowell Elementary School is located at 1025 Lincoln Place in Teaneck, New Jersey. This 47,106 ft² facility was originally built in 1934 and is in fair condition.

Building Occupancy

Approximately 300 full-time or part-time staff members occupy the building. The building is occupied year-round.

Hours of Operation

- Monday through Friday 6:30 am to 6:00 pm.
- The building is at full occupancy year-round.


Envelope

The building is constructed of composite walls with a brick and concrete façade. The building is three stories tall. This includes a basement, ground level and two (2) floors. This building has a flat roof built with tar and granular finish. The pitched roof decks with asphalt shingles. The windows throughout the building are double paned and appear to be in good condition. Exterior doors are high efficiency FRP doors.

Lighting

The building is primarily lit by linear fluorescent fixtures which contain T8 lamps with electronic ballast. Other fixtures throughout the building include individual fixtures with incandescent lamps, while some areas have fixtures with compact fluorescent plug in lamps. Replacing the fixtures with LED technology would be a great opportunity for energy savings.

Lighting Controls: The interior lighting is manually controlled by wall switches. The exterior lighting is controlled by mechanical time clocks to switch lights on and off.



Lowell Elementary School
Exterior Door

Teaneck Board of Education Energy Savings Plan

Mechanical Systems

HVAC Systems and Equipment: The building is heated by two (2) natural gas-fired steam boilers which are located in the boiler room. Steam generated by the boilers are fed to a heat exchanger to provide hot water for space heating. Hot water is then circulated through unit ventilators in some of the classrooms. The building utilizes three (3) air handling units that provide outside air to the building. One air handling unit is located on the roof, while the other two are inside the building.

Cooling for offices, shared spaces and the library are provided by a ductless split system and through the wall air conditioning units.

| Location | Floor/Serves | Manufacturer | Model/Make | Date | Efficiency | Capacity |
|-------------------------|--------------------------------|--------------|-------------|------|------------|------------------|
| Basement Boiler Room | 1 st Floor Lobby | Weil-McLain | 88 series 2 | 2011 | Unknown | 1701 MBH 5psi |

Domestic Hot Water Systems

The building is supplied domestic hot water by one (1) 40-gallon natural gas-fired water heater.

Building Controls (HVAC Controls)

The boilers are currently connected through a Bradley Scochetti interface. The building's roof-top units communicate with programmable thermostats. The remaining equipment within the building is controlled manually. The set points for Lowell Elementary School are as follows;

| Time Period | Heating Season | Cooling Season |
|-------------------------|----------------|----------------|
| Occupied Hours | 68-72°F | 72-76°F |
| Unoccupied Hours | 55°F | 80°F |

Kitchen Equipment

The kitchen utilizes both electric and gas cooking equipment. Various types of refrigeration equipment are and ice machines are also present.

Plug Load

The classrooms throughout Teaneck Board of Education contain computers, printers, TV's and overhead projectors. Many schools have computer centers and library's which contain 20 or more computers in each. Most schools also have office areas that contain copiers, microwaves, refrigerators, vending machines and coffee makers.

Teaneck High School



Background Information

Teaneck High School is located at 100 Elizabeth Avenue in Teaneck, New Jersey. This 215,808 ft² facility was originally built in 1927 and is in fair condition.

Building Occupancy

Approximate enrollment is 75 students with a staff of 15 full-time or part-time employees. The building is fully occupied September through June. Partial occupy occurs during the summer months.

Hours of Operation

- Monday through Friday 6:30 am to 6:00 pm (students/staff)
- Saturday – No use and Sunday 11:00 am to 3:00 pm

Envelope

The building is constructed of composite walls with a brick façade that appears to be in good condition. The roof is flat and contains sprayed foam roofing with gravel finish. The windows throughout the building are single or double-paned. The windows appear to be in good condition. The exterior doors throughout the building are FRP doors which are in good condition.



Teaneck High School
Foam Roof Deterioration

Lighting

The building is primarily lit by linear fluorescent fixtures which contain T8 linear fixtures with electronic ballast. Fixtures throughout the building include individual fixtures with incandescent lamps, while some areas have fixtures with compact fluorescent plug in lamps. The fixtures are in good condition which provides a great opportunity for energy savings by retrofitting to LED technology.

Lighting Controls: The building's interior and exterior lighting are manually controlled.

Mechanical Systems

HVAC Systems and Equipment: The building is heated by two (2) oil-fired cast iron steam boilers which are located in the boiler room. Both boilers are dual-fueled and can be fired with either gas or oil. Steam from the boilers serves a heat exchanger which provides hot water for the building unit ventilators. Steam from the boilers also serve a separate double wall heat exchanger to generate domestic hot water.

Steam from the boilers may also serve a single-stage absorption liquid chiller. This chiller is located in the boiler room and generates chilled water for building cooling. This chiller is used on an as-needed basis throughout the summer months.

Cooling for the building is primarily provided by separate screw chillers which are adjacent to the building's boiler room. Administrative offices and technical rooms are conditioned by a ductless split system and through the wall air conditioning units.

Air handling units equip with DX cooling and hot water coils provide heat air conditioning throughout the building.

Pneumatic valves for the building are integrated into Automated Logic Control System, but many valves must be manually controlled. Many of the valves are not functioning properly and require manual operation. Building maintenance personal for the facility have difficulty in switching from heating to cooling, or cooling to heating, because of the need for manual operation, or nonfunctional valves.



Teaneck High School



Teaneck High School
Hot Water Heater

Domestic Hot Water Systems

Steam from the boilers serve a double wall heat exchanger which generates domestic hot water for the building. There is a gas fired domestic hot water heater with back-up storage tank containing a hot water coil, heated from rejected engine cooling water from the primary Tecogen chiller system.



**Teaneck High School
Controls System**

Building Controls (HVAC Controls)

Building controls consist of standalone, local thermostats, controllers or switches. The valves are pneumatically controlled by an Automated Logic System. The boiler is controlled by the Building Management System.

Teaneck High School typical set points are:

| Time Period | Heating Season | Cooling Season |
|-------------------------|----------------|----------------|
| Occupied Hours | 68-72°F | 72-76°F |
| Unoccupied Hours | 55°F | 80°F |

Kitchen Equipment

The kitchen utilizes both electric and gas cooking equipment. Various types of refrigeration equipment are present including walk-in coolers and a walk-in freezer. Standard refrigerators and ice machines are also present.

Plug Load

The classrooms throughout Teaneck Board of Education contain computers, printers, TV's and overhead projectors. Many schools have computer centers and library's which contain 20 or more computers in each. Most schools also have office areas that contain copiers, microwaves, refrigerators, vending machines and coffee makers.

Thomas Jefferson Middle School



Background Information

Thomas Jefferson Middle School is located at 655 Teaneck Road in Teaneck, New Jersey. This 105,216 ft² facility was originally built in 1927 and is in fair condition.

Building Occupancy

Approximate enrollment is 2000 students with 180 full-time staff. Full occupancy of the building is through the months of September to June. Partial occupancy occurs during the summer months.

Hours of Operation

- Monday through Friday 6:00 am to 5:00 pm (students/staff)
- A second janitorial staff is present until 12 AM Monday through Friday
- Weekend hours are varied

Envelope

The building is a single structure constructed of composite walls with a brick façade. The building has flat roofs built up from tar with granular finish. The building windows are mostly double-paned, while the building exterior doors are FRP.

Lighting

The building is primarily lit by linear fluorescent fixtures which include T8 lamps with electronic ballast. Fixtures throughout the building include individual fixtures with incandescent lamps, high bay fixtures, metal-halide fixtures and compact fluorescent plug in lamps. Replacing the fixtures with LED technology would be a great opportunity for energy savings.

Lighting Controls: The interior light fixtures are manually controlled via wall switches or sensor mounted switches. The exterior light fixtures are controlled by mechanical time clocks and wall switches.

Mechanical Systems

HVAC Systems and Equipment: The entire building is heated by three (3) gas-fired condensing hot-water boilers. All boilers are located in the buildings' boiler room. Hot water generated by the boilers is circulated to the classrooms' fan coil unit ventilators by constant-speed pumps. Air Handling units located throughout the building provide heating and cooling throughout the building zones. These air handling units have DX cooling coils and hot-water heating coils. Heating for the corridor beside the boiler room and kitchen is provided by unit heaters,

Air conditioning throughout the building is provided by a ductless spit system and through the wall air conditioning units.

Ventilation throughout the original building is provided by unit ventilators in the classrooms, lounges and office areas.

Domestic Hot Water Systems

The building is supplied domestic hot water by one (1) gas-fired water heater rated for 199 MBH. This domestic hot water heater is located in the building's boiler room.

Building Controls (HVAC Controls)

The building's equipment is controlled by self-contained local thermostats, controllers or switches. The building's rooftop units are controlled by a building management system. The normal temperature set points for Thomas Jefferson Middle School are as follows:

The typical temperature set points are as follows:

| Time Period | Heating Season | Cooling Season |
|-------------------------|----------------|----------------|
| Occupied Hours | 68-72°F | 72-76°F |
| Unoccupied Hours | 55°F | 80°F |

Teaneck Board of Education Energy Savings Plan

Kitchen Equipment

The kitchen utilizes both electric and gas cooking equipment. Various types of refrigeration equipment are present including walk-in coolers. Standard refrigerators and ice machines are also present.



Thomas Jefferson Middle School
Kitchen

Plug Load

The classrooms throughout Teaneck Board of Education contain computers, printers, TV's and overhead projectors. Many schools have computer centers and library's which contain 20 or more computers in each. Most schools also have office areas that contain copiers, microwaves, refrigerators, vending machines and coffee makers.

Whitter Elementary School



Background Information

Whitter Elementary School is located on 491 West Englewood Avenue in Teaneck, New Jersey. This 55,158 ft² facility was originally built in 1921 and is in fair condition.

Building Occupancy

Approximate enrollment is 402 students with 55 faculty and staff members. The school is occupied in the summer by administrative personnel only.

Hours of Operation

- Monday through Friday 6:00 am to 4:00 pm (students/staff)
- Saturday and Sunday – Closed

Envelope

The building is constructed of composite walls with a brick façade. The building façade is in good condition. The roof consists of hot tar built up with white granular finish. Pitched sections of the roof contain asphalt shingles. Windows throughout the building are double-paned. The exterior doors are high efficiency FRP doors.

Lighting

The building is primarily lit by linear fluorescent fixtures which contain T8 lamps with electronic ballast. Replacing the fixtures with LED technology would be a great opportunity for energy savings.

Lighting Controls: The interior lighting is controlled manually by wall switches.

Mechanical Systems

HVAC Systems and Equipment: The building is heated by two (2) gas-fired boilers. Steam that is provided by the boilers is fed through a heat exchanger to produce hot water for space heating. This heating hot water is provided to the building unit ventilators or two-pipe steam radiator units in each classroom.

Ductless split system and through the wall air conditioning units provide cooling for the cafeteria, elevator, administrative offices, and computer rooms.

Domestic Hot Water Systems

The building is supplied domestic hot water by two (2) hot water heaters. One 50-gallon water heater is gas-fired, the other is an 80-gallon electric water heater.




Whitter Elementary School
Hot Water Heater

Teaneck Board of Education Energy Savings Plan

Building Controls (HVAC Controls)

Whittier Elementary has all systems on the BMS control. Additionally, all UVs are tied to a thermostat and a CO2 monitor for each designated area.



Whittier Elementary School
Building Controls

The typical temperature set points are as follows:

| Time Period | Heating Season | Cooling Season |
|------------------|----------------|----------------|
| Occupied Hours | 68-72°F | 72-76°F |
| Unoccupied Hours | 55°F | 80°F |

Kitchen Equipment

The kitchen utilizes both electric and gas cooking equipment. Various refrigeration and ice machines are also present.

Plug Load

The classrooms throughout Teaneck Board of Education contain computers, printers, TV's and overhead projectors. Many schools have computer centers and library's which contain 20 or more computers in each. Most schools also have office areas that contain copiers, microwaves, refrigerators, vending machines and coffee makers.

Utility Baseline Analysis

Electric


The electric commodity supplier of electricity for the beginning of the baseline period is Direct Energy, LLC (DE). The transport company is PSE&G. One kWh usage is equivalent to 1000 watts running for one hour.

Natural Gas

The gas commodity supplier of electricity for the beginning of the baseline period is Direct Energy, LLC. The transport company is PSE&G. The gas utility PSE&G measures consumption in cubic feet x 100 (CCF) and converts the quantity into therms of energy. The district buildings fall under the General Service (GSG) or Large Volume Service (LVG) Rate structure for natural gas.

Energy Usage Summary

Teaneck Public Schools Energy Summary Analysis Table




Teaneck Public Schools Energy Use Index (EUI) Analysis

Teaneck Board of Education Energy Savings Plan

The chart below shows the distribution of these two energy source costs relative to the entire District energy consumption. At 70% of the total consumption, electricity comprises a larger share of the energy costs.


Teaneck Public Schools Utility Cost Breakdown Electric

Teaneck Public Schools Electric Consumption kWh & Cost



Teaneck Public Schools Utility Cost Breakdown Gas

Teaneck Public Schools Natural Gas Consumption Therms & Cost



Marginal Rates

For the purposes of determining how energy conservation measures will affect the utility bill, it is important to understand what portions of the cost can be saved. In general, there are costs associated with utility bills that are fixed and independent of usage, such as the monthly meter charge. For example, in the case of a monthly meter charge, this charge often exists even if the energy usage were zero. An energy conservation measure often cannot produce a cost savings on this portion of the bill. The utility rate structure must, therefore, be analyzed to determine what portion of the bill a cost savings can be produced using a specific energy conservation measure. For the purposes of this report, the blended average utility rate is the total cost divided by the total energy units. The effective rate is the portion of the bill effected by energy saving or the applied energy conservation measure.

The utility rates identified below were used for purposes of calculating the dollar effect of the energy savings for the district.

Electric

The effective supply kWh rate is the most recent in the baseline period. The effective transport \$/kWh and \$/kW demand rates are based on the most recent utility tariff rates as of 06/12/17. The total effective \$/kWh rate is the summation of the supply and transport effective rates. For simplification an Average Effective \$/kWh rate was determined by averaging the summer and annual effective \$/kWh rates and is used for calculations. Summer rate is considered months June through September. The total summer billed demand rate is the annual demand rate plus the summer demand rate. Rates shown include New Jersey Sales and Use Tax (SUT). A simplified weighted average \$/kW demand is used as the effective rate for savings calculations. It was calculated by taking the summation of the annual \$/kW demand times 8/12 plus the total summer \$/kW demand times 4/12.

Natural Gas

Due to the complex nature and variability of the gas rates which includes demand and balancing charges in the tariff rates the effective rate is considered for savings calculations. In cases where more than one account/meter serves a school the total average of all combined accounts is used unless the account is not significant, for instance where the account exists but delivers no natural gas on a regular basis or uses a very small amount relative to the other accounts.

| Building | \$/therm |
|---------------------------------|----------|
| Benjamin Franklin Middle School | \$0.867 |
| Bryant Elementary School | \$0.798 |
| Hawthorne Elementary School | \$0.908 |
| Lowell Elementary School | \$0.893 |
| Teaneck High School | \$0.813 |
| Thomas Jefferson Middle School | \$0.909 |
| Whittier Elementary School | \$0.917 |
| Benjamin Franklin Middle School | \$0.867 |

| Building Name | Rate | Meter # | Electric Transport Account # | Effective Rate (Note 2) | | | | EFFECTIVE RATE (Note 2) | | Solar \$ Cost Electric | Solar Production Electric (Note 3) | Total IN Electric | Total OUT Electric | NET Usage Electric | Total kWh Baseline (Note 4) | Annual Demand Billed (Note 5) | Peak Demand Billed (Note 5) | Demand Cost | Supply Cost | Delivery Cost | TOTAL Electric Cost | Blended Avg Unit Cost (\$ / Unit) (Note 6) | Base Year |
|-----------------------------|---------|---------|------------------------------|-------------------------|------------------|------------|------------------|-------------------------|------------|------------------------|------------------------------------|-------------------|--------------------|--------------------|-----------------------------|-------------------------------|-----------------------------|-------------|-------------|---------------|---------------------|--|-----------------|
| | | | | Supply | Delivery | Combine | Solar | TOTAL | | | | | | | | | | | | | | | |
| | | | | Effective \$/kWh | Effective \$/kWh | Eff \$/kWh | Effective \$/kWh | Eff \$/kW | Eff \$/kWh | | | | | | | | | | | | | | |
| Teaneck High | LPLS | 9205642 | 42 003 120 18 | \$0.0784 | \$0.01270 | \$0.0911 | \$0.09857 | \$6.72 | \$0.11899 | \$10,618 | 109,049 | - | - | 1,595,094 | 1,704,143 | 4,826.8 | 430.9 | \$ 30,797 | \$ 142,102 | \$ 49,925 | \$ 192,026 | \$ 0.120 | Jul-18 - Jun-19 |
| Teaneck High Athletic Field | GLP | 9207652 | 65 806 170 04 | Note 10 | \$0.01702 | Note 10 | \$0.09857 | \$7.21 | \$0.09857 | Note 10 | Note 10 | 18,264 | 79,112 | -60,848 | Note 10 | Note 10 | 141.0 | \$ 5,000 | \$ 10 | \$ 5,100 | Note 10 | Note 10 | Jul-18 - Jun-19 |
| Eugene Field Administration | GLP BPL | 9209244 | 66 421 219 02 | \$0.0784 | \$0.01702 | \$0.0954 | \$0.09857 | \$7.21 | \$0.11171 | \$5,214 | 53,551 | 201,403 | 4,421 | 196,982 | 250,533 | 629.7 | 73.9 | \$ 4,596 | \$ 14,803 | \$ 7,905 | \$ 22,709 | \$ 0.115 | Jul-18 - Jun-19 |
| Thomas Jefferson Middle | LPLS | 9209230 | 42 003 988 18 | \$0.0784 | \$0.01270 | \$0.0911 | \$0.09857 | \$6.72 | \$0.11914 | \$9,750 | 100,134 | 559,642 | 4,968 | 554,674 | 654,808 | 2,017.1 | 205.9 | \$ 12,912 | \$ 45,735 | \$ 22,409 | \$ 68,144 | \$ 0.123 | Jul-18 - Jun-19 |
| Hawthorne Elementary | GLP BPL | 9210816 | 67 562 643 03 | \$0.0784 | \$0.01702 | \$0.0954 | \$0.09857 | \$7.21 | \$0.10356 | \$16,014 | 164,464 | 202,950 | 51,053 | 151,897 | 316,361 | 932.0 | 96.2 | \$ 6,302 | \$ 14,075 | \$ 2,476 | \$ 16,551 | \$ 0.109 | Jul-18 - Jun-19 |
| Bryant Elementary | GLP | 9210817 | 65 828 671 05 | \$0.0784 | \$0.01702 | \$0.0954 | \$0.09857 | \$7.21 | \$0.13102 | \$21,670 | 222,549 | 149,769 | 118,569 | 31,757 | 254,306 | 819.5 | 94.5 | \$ 5,612 | \$ 5,218 | \$ 6,166 | \$ 11,384 | \$ 0.358 | Jul-18 - Jun-19 |
| Whittier Elementary | GLP | 9210154 | 66 128 016 03 | \$0.0784 | \$0.01702 | \$0.0954 | \$0.09857 | \$7.21 | \$0.12279 | \$0 | - | - | - | 272,800 | 272,800 | 666.0 | 106.0 | \$ 5,020 | \$ 24,645 | \$ 8,851 | \$ 33,496 | \$ 0.123 | Jul-18 - Jun-19 |
| Benjamin Franklin Middle | LPLS | 9209245 | 42 008 678 18 | \$0.0784 | \$0.01270 | \$0.0911 | \$0.09857 | \$6.72 | \$0.11910 | \$29,290 | 300,807 | 532,766 | 76,917 | 455,849 | 756,656 | 2,349.9 | 233.3 | \$ 13,130 | \$ 37,371 | \$ 23,096 | \$ 60,467 | \$ 0.133 | Jul-18 - Jun-19 |
| Lowell Elementary | GLP | 9210145 | 65 900 523 01 | \$0.0784 | \$0.01702 | \$0.0954 | \$0.09857 | \$7.21 | \$0.13074 | \$0 | - | - | - | 235,390 | 235,390 | 1,170.6 | 190.5 | \$ 7,635 | \$ 19,266 | \$ 11,508 | \$ 30,774 | \$ 0.131 | Jul-18 - Jun-19 |

- Note 1: The electric commodity supplier of electricity for the beginning of the baseline period is Direct Energy, LLC (DE) and was then switched to East Coast Power & Gas (ECP&G) New Jersey, LLC. For the purpose of calculations ECP&G is the most recent supply company in the baseline period and is considered the supply company for the baseline rates. The transport company is PSE&G. Teaneck High School Athletic Field uses PSE&G as the supplier under the Basic Generation Service (BGS) rate.
- Note 2: The effective transport \$/kWh and \$/kW demand rates are based on the PSE&G tariff rates effective 6/1/2019. The total effective \$/kWh rate is the summation of the supply and transport effective rates. Summer rate is considered months June through September. A simplified weighed average delivery/transport \$/kW demand rate is used in determining the Total Effective rate for savings calculations. The \$/kW demand rate was calculated by taking the summation of the non-summer \$/kW rate times 12/12 plus the Summer \$/kW rate times 4/12. A simplified weighted average delivery/transport \$/kWh rate to account for summer and winter rate differences was calculated in a similar manner by taking the summation of the non-summer \$/kWh rate times 8/12 plus the Summer \$/kW rate times 4/12. The Solar supply rate is based on the most recent solar rates in the baseline. The total effective \$/kWh rate is a ratio of the solar \$/kWh and utility \$/kWh Blended Avg Unit Cost rates ratioed by the kWh contribution.
- Note 3: Solar kWh production data was only provided for 11 months and over a different time frame from the baseline. The solar data provided covered 12/1/2018 to 9/30/2019. To establish 12 months of solar production the 11 months of solar kWh production was multiplied by a factor of (12/11). Solar costs for the baseline were estimated assuming the following: Solar Costs = 0.5*kWh*\$0.9617 + 0.5*kWh*\$0.9857 = \$0.0974/kWh (this assumes 6 months at each of the two rates)
- Note 4: Total kWh baseline is the summation of the Net Utility Meter kWh usage plus the Solar Production. The solar panels were assumed to be on the building side of the utility electric meter.
- Note 5: Annual Billed Demand is the sum of the billed demand of all billing periods during the baseline. Average billed demand is the average of the billed demand of all billing periods during the baseline. Peak Demand Billed is the highest billed demand that occurred during the baseline period.
- Note 6: The average blended unit cost is the total 12 month utility costs divided by the total 12 month billed kWhs.
- Note 7: In some instances Supply cost data was missing especially in the months of August through Oct 2018, the supply costs for these months were estimated as needed using the kWh usage multiplied by the closest available / adjoining month supply cost rates.
- Note 8: Two months of demand costs were estimated for Whittier ES.
- Note 9: Multiple billing errors and rebilling occurred for Lowell Elementary. Missing data was estimated using adjoining months.
- Note 10: Teaneck High School Athletic Field full 12 months of billing data for the baseline period was not provided however 6 months from June 2018 to Dec 2018 showed it was a net producer of electricity and the only major utility non-fixed cost in that time are associated with demand charges. The demand charges for 7 months = \$4,623, and estimated 12 month charge was set to \$5000 with total delivery charges set to \$5100. The kWh in, out, and net were estimated by multiplying the 6 months of available data by 12/6 to estimate the annual numbers. No solar billing data was provided for Teaneck High School Athletic Field which prevents determine / estimating building kWh usage from the utility data. The peak and average demand shown are based on the 6 months of available data.
- Note 11: Hawthorne Elementary unmetered BPL lighting usage and costs are not included in data. BPL unmetered rate is show for information purposes.

| Building Name | Rate | Account # | Meter # | Total Effective Rate | Baseline Consumption | Transport Cost | Supply Cost | TOTAL COST | Blended Avg Unit Cost (\$ / Unit) | Base Year |
|--------------------------------------|-----------|---------------|---------|----------------------|----------------------|----------------|-------------|------------|-----------------------------------|-----------------|
| | | | | (Note 2) \$/therm | | | | | | |
| Teaneck High School | LVG | 66 793 594 06 | 3128206 | \$0.813 | 110,033 | \$ 28,941 | \$ 62,061 | \$ 91,001 | \$ 0.83 | Jul-18 - Jun-19 |
| Teaneck High School (SMALL GAS) | GSG (HTG) | 42 003 120 18 | 3166301 | \$0.892 | 1,912 | \$ 825 | \$ 1,049 | \$ 1,873 | \$ 0.98 | Jul-18 - Jun-19 |
| Eugene Field Administration Building | GSG (HTG) | 66 421 219 02 | 3740309 | \$0.949 | 13,400 | \$ 5,091 | \$ 7,796 | \$ 12,886 | \$ 0.96 | Jul-18 - Jun-19 |
| Thomas Jefferson Middle School | LVG | 42 003 988 18 | 3637636 | \$0.909 | 44,534 | \$ 15,069 | \$ 26,892 | \$ 41,961 | \$ 0.94 | Jul-18 - Jun-19 |
| Hawthorne Elementary School | LVG | 67 562 643 03 | 2415218 | \$0.908 | 30,685 | \$ 10,801 | \$ 18,543 | \$ 29,344 | \$ 0.96 | Jul-18 - Jun-19 |
| Bryant Elementary School | LVG | 65 828 671 05 | 3227881 | \$0.798 | 54,724 | \$ 17,043 | \$ 28,102 | \$ 45,145 | \$ 0.82 | Jul-18 - Jun-19 |
| Whittier Elementary School | LVG | 65 182 085 03 | 3765336 | \$0.917 | 40,145 | \$ 14,366 | \$ 23,942 | \$ 38,309 | \$ 0.95 | Jul-18 - Jun-19 |
| Benjamin Franklin Middle School | LVG | 42 008 678 18 | 2806915 | \$0.867 | 44,141 | \$ 14,138 | \$ 25,645 | \$ 39,784 | \$ 0.90 | Jul-18 - Jun-19 |
| Lowell Elementary School (Note 4) | LVG | 65 900 523 01 | 3010316 | \$0.893 | 38,369 | \$ 13,656 | \$ 22,085 | \$ 35,741 | \$ 0.93 | Jul-18 - Jun-19 |

Note 1: The gas commodity supplier of electricity for the beginning of the baseline period is Direct Energy, LLC and was then switched to East Coast Power & Gas (ECP&G) New Jersey, LLC . If no 3rd party supplier is used the supplier defaults to the transport company is PSE&G.

Note 2: For simplification of the rates, the effective rate is the total cost minus \$168.44 or \$1495.23 or the fixed service charge for the GSL and LVG rates during the baseline period. This is considered the overall effective rate for savings calculations which integrates the demand and balancing charge into a single blended rate while subtracting out the fixed service charges. The fixed charges are based on the fixed charges for the baseline period for THS (GSG) and Bryant (LVG) from the billing data.

Note 3: The Blended Average Unit Cost is the total costs divided by the total usage.

Note 4: Lowell ES Natural Gas showed zero usage since 2016 until the utility changed the meter. It appears the meter was not functioning. A baseline was calculated to approximate what that utility baseline usage and costs would have been if the meter was working. The therms of usage was estimated based on heating degree days and having a 81 KBtu/SF energy index for the thermal usage. The average thermal index of 71 KBtu/SF is the average of all the other thermal indexes. Costs were estimated based on the average Transport Costs of \$0.356/therm and Supply Costs of \$0.576 multiplied by the estimated usage. The CDM Energy Audit report from May 28th 2010 showed 435 therms of natural gas and 27,018 gallons of fuel oil usage in 2008/2009 time frame which equates to a total of 37,981 therms combined fuel oil and natural gas indicating the estimated baseline 38,369 therms as accurate.

Note 7: In some instances data was missing, values were calculated based on utility billing meter readings or estimated by the closest available / adjoining months data.

Utility Breakdown by Building

Electric Usage and Demand

A detailed look at the monthly usage (kWh) in a typical year is shown in the Appendix.

Natural Gas Usage

A detailed look at the monthly usage (therms) in a typical year is shown in the Appendix.

Utility Escalation Rates

For purposes of calculating the extended value of the energy savings of this project, the following utility escalation rates have been used.

| School | Energy | | | | | |
|--|----------------------|--------------------------|------------------------|--------------------------|-----------------|--------------------------|
| | Electric Consumption | | Annual Electric Demand | | Natural Gas | |
| | Escalation Rate | Start Year of Escalation | Escalation Rate | Start Year of Escalation | Escalation Rate | Start Year of Escalation |
| Benjamin Franklin Middle School | 2.2% | Year 1 | 2.2% | Year 1 | 2.4% | Year 1 |
| Bryant Elementary School | 2.2% | Year 1 | 2.2% | Year 1 | 2.4% | Year 1 |
| Hawthorne Elementary School | 2.2% | Year 1 | 2.2% | Year 1 | 2.4% | Year 1 |
| Lowell Elementary School | 2.2% | Year 1 | 2.2% | Year 1 | 2.4% | Year 1 |
| Teaneck High School | 2.2% | Year 1 | 2.2% | Year 1 | 2.4% | Year 1 |
| Thomas Jefferson Middle School | 2.2% | Year 1 | 2.2% | Year 1 | 2.4% | Year 1 |
| Whitter Elementary School | 2.2% | Year 1 | 2.2% | Year 1 | 2.4% | Year 1 |

SECTION 3. FINANCIAL IMPACT

Energy Savings and Cost Summary

The table below provides a summary of the costs and savings associated with the measures recommended in the Energy Savings Plan. The savings have been calculated based on the savings methodology detailed throughout this report and included in the appendix of this report. Costs for each measure have been estimated based on project implementation experience and industry standards.

| ECM # | ECM | Year 1 Savings (\$/Yr) | ECM Cost | Simple Payback | Installation Plan | Recommend Installation |
|-------|---|------------------------|--------------|----------------|----------------------------|------------------------|
| 1 | Comprehensive LED Lighting Upgrades - Teaneck HS | \$53,668 | \$357,574 | 6.7 | Public Bidding | Yes |
| 2 | Install VFD's and Premium Motor Upgrades for HVAC | \$ 4,609 | \$ 33,685 | 7.3 | Public Bidding | Yes |
| 3 | Direct Install Program (Lighting) | \$ 74,283 | \$ 696,698 | 9.4 | DI Installer | Yes |
| 4 | Plug Load Controls | \$ 4,994 | \$ 44,952 | 9.0 | Public Bidding | Yes |
| 5 | Combined Heat and Power (35kW) | \$ 14,122* | \$ 335,500 | 23.8 | Public Bidding | Yes |
| 6 | Computer Power Management Software | \$ 15,401 | \$ 30,875 | 2.0 | Public Bidding | Yes |
| 7 | Refrigeration Controls | \$ 4,096 | \$ 42,684 | 10.4 | Public Bidding | Yes |
| 8 | Fuel Use Economizers (Hot Water Boilers) | \$ 5,513 | \$ 39,270 | 7.1 | Public Bidding | Yes |
| 9 | Direct Install Program Fuel Use Economizers (Steam Boilers) | \$ 9,979 | \$ 4,916 | 0.5 | DI Installer | Yes |
| 10 | Direct Install Program Low-flow Domestic Hot Water Devices | \$ 790 | \$ 597 | 0.8 | DI Installer | Yes |
| 11 | Replace Rooftop Cooling Unit at Whittier Elementary School | \$ 1,126 | \$ 134,922 | 119.8 | Public Bidding | Yes |
| 12 | Replace Cooling in Media Center – Benjamin Franklin Middle School | \$ 1,016 | \$ 70,018 | 68.9 | Public Bidding | Yes |
| 13 | Replace Cooling in Media Center – Lowell Elementary School | \$ 96 | \$ 34,312 | 355.7 | DI Installer | Yes |
| 14 | Condensing Hot Water Boiler Plant (Teaneck High School - Fan Room Upgrades) | \$ 10,493 | \$ 1,037,479 | 98.9 | Co-op Mechanical Installer | Yes |
| 15 | Condensing Hot Water Boiler Plant (Teaneck High School – Hot Water Header Pipe) | \$ 0 | \$ 284,900 | 100+ | Co-op Mechanical Installer | Yes |
| 16 | Replace Steam Traps | \$ 13,070 | \$ 198,580 | 15.2 | Public Bidding | Yes |
| 17 | Replace Domestic Hot Water Storage Tank at Benjamin Franklin Middle School | \$ 370 | \$ 50,070 | 135.2 | Public Bidding | Yes |
| 18 | Refurbish Cooling Tower | \$ 1,599 | \$ 22,638 | 14.2 | Public Bidding | Yes |

Teaneck Public Schools Energy Savings Plan

| ECM # | ECM | Year 1 Savings (\$/Yr) | ECM Cost | Simple Payback | Installation Plan | Recommend Installation |
|-------|--|------------------------|------------|----------------|--------------------------|------------------------|
| 19 | Upgrade Building Management System | \$ 22,529 | \$ 413,584 | 18.4 | Co-op Controls Installer | Yes |
| 20 | Operational Verification and HVAC Improvements | \$ 38,938 | \$ 163,130 | 4.2 | Co-op Controls Installer | Yes |
| 21 | Building Envelope Weatherization | \$ 21,429 | \$ 257,632 | 12.0 | Public Bidding | Yes |
| 22 | Repair Missing Piping Insulation | \$ 7,484 | \$ 113,334 | 15.1 | Public Bidding | Yes |
| 23 | Construction Contingency | \$ 0.0 | \$ 542,500 | 100+ | Public Bidding | Yes |
| 24 | Unit Ventilator Refurbishment at Teaneck High School – First Floor | \$ 1,744 | \$ 132,000 | 75.7 | Public Bidding | Yes |
| 25 | Unit Ventilator Replacement at Teaneck High School – Second Floor | \$ 1,581 | \$ 438,625 | 277.5 | Public Bidding | Yes |
| 26 | Unit Ventilator Replacement at Teaneck High School – Third Floor | \$ 2,453 | \$ 680,625 | 277.5 | Public Bidding | Yes |

*Savings from Combined Heat and Power is Energy Savings & Distributed Generation (Capacity & Generation: \$20,093; Energy: (\$5,971))

Operational Savings Estimates

The lighting retrofits recommended for this project will reduce the number of lamps that need to be replaced each year due to the longer lasting lamps and new technology fixtures. The LED lighting recommended for the exterior fixtures will last much longer than the current high intensity discharge (HID) lighting and will generate material cost savings.

A brief description of the operational savings estimated for this project is included below. Energy Systems Group has worked with the District to quantify the exact sources of savings by going through past invoices and expenses. The operational savings will not be escalated.

| Operational Savings for Financial Model | |
|---|-----------------|
| ECM Description | Annual Savings |
| LED Lighting Upgrades | \$26,130 |
| Reduction in replacement parts and maintenance expenses – District Wide | \$59,474 |
| Totals | \$85,604 |

Potential Revenue Generation Estimates

As part of the Energy Savings Plan for Teaneck Public School District, several avenues for obtaining rebates and incentives have been investigated which include:

- NJ Smart Start Equipment Incentives
- Combined Heat and Power Incentive
- Demand Response Energy Efficiency Credit

The estimated incentive amount for each program is listed below. Upon final selection of project scope and award of subcontractor bids, the incentive applications will be filed.

NJ Smart Start Equipment Incentives

The NJ Smart Start Equipment Incentives provide prescriptive rebates for defined retrofits. Incentives are applied on a unit-by-unit basis for making energy efficiency upgrades. The table below summarizes the equipment incentives, which will be applied for at Teaneck Public Schools:

| Energy Conservation Measure | Estimated Incentive |
|--|---------------------|
| LED Lighting Upgrades & Occupancy Sensors – Benjamin Franklin Middle School | \$61,605.60 |
| LED Lighting Upgrades & Occupancy Sensors – Hawthorne Elementary School | \$96,013.98 |
| LED Lighting Upgrades & Occupancy Sensors – Lowell Elementary School | \$78,633.43 |
| LED Lighting Upgrades & Occupancy Sensors – Teaneck High School | \$62,675.30 |
| LED Lighting Upgrades & Occupancy Sensors – Thomas Jefferson Elementary School | \$49,968.10 |
| LED Lighting Upgrades & Occupancy Sensors – Whitter Elementary School | \$110,828.02 |
| Totals | \$459,724.43 |

Teaneck Public Schools Energy Savings Plan

Cogeneration Incentives

Incentives are available for Combined Heat and Power (CHP) / Cogeneration systems with heat recovery and productive use of waste heat that are located on-site. Cogeneration units that are powered by natural gas and under 500kW, as in the case of the system recommended for Teaneck High School, are eligible for an incentive of \$2.00/ watt. There is a minimum of 5,000 EFL Run hours that Teaneck High School will meet to qualify for this incentive.

The CHP incentive is paid in three increments as outlined below:

- Thirty percent (30%) of the incentive upon proof of equipment purchase
- Fifty (50%) percent upon project completion and verification of installation
- Remainder twenty percent (20%) upon acceptance and confirmation the project is achieving the required performance thresholds based on twelve (12) months of operating data. proposed and/or minimum efficiency threshold

| Building | Estimated Incentive #1 | Estimated Incentive #2 | Estimated Incentive #3 | Estimated Total |
|------------------------------------|------------------------|------------------------|------------------------|-----------------|
| Cogeneration – Teaneck High School | \$19,530 | \$32,550 | \$13,020 | \$65,100 |
| Totals | \$19,530 | \$32,550 | \$13,020 | \$65,100 |

Demand Response Energy Efficiency Credit

The LED Lighting Upgrades recommended for the District will be eligible for the Energy Efficiency Credit available through PJM. The Energy Efficiency Credit pays consumers based on the permanent load reduction through the installation of energy efficiency measures. The following table summarizes the available Demand Response Incentives available due to the lighting upgrades at all buildings at the Teaneck Public Schools.

| Demand Response Energy – Emergency Capacity Credit | | |
|--|--------------------|----------------------------------|
| PJM Payment Year | Approved Load (kW) | Annual Customer Capacity Benefit |
| 2020/2021 | 312.5 kW | \$5,684 |
| 2021/2022 | 312.5 kW | \$3,573 |
| 2022/2023 | 312.5 kW | \$3,573 |
| 2023/2024 | 312.5 kW | \$3,573 |
| Totals | 312.5 kW | \$16,403 |

Teaneck Public Schools Energy Savings Plan

Business Case for Recommended Project

FORM VI - ENERGY SAVINGS PLAN

ESCO's PRELIMINARY ENERGY SAVINGS PLAN (ESP):
ESCO's PRELIMINARY ANNUAL CASH FLOW ANALYSIS FORM
Teaneck Public Schools Energy Savings Improvement Plan
ENERGY SAVINGS IMPROVEMENT PROGRAM

ESCO Name: **ENERGY SYSTEMS GROUP**

Project Scenario 1

Note: Respondents must use the following assumptions in all financial calculations:

(a) The cost of all types of energy should be assumed to inflate at 2.2% gas, 2.4% electric per year; and

1. Term of Agreement: 19 years
2. Construction period² (months): 12
3. Cash Flow Analysis Format:

Total Financed Amount⁽⁴⁾ \$ 7,976,791
Design/Consultant Fee \$ 416,666
Bond Council/FA \$ 35,000
Total ESG Project Cost⁽¹⁾ \$ 7,525,125

Interest Rate to be used for Proposal Purposes: **2.30%**

| | Annual Energy Savings | Annual Operational Savings | Energy Rebates/Incentives | Solar PPA | Total Annual Savings | Annual Project Costs | Board Costs | Annual Service Costs | Net Cash-Flow to client | Cumulative Cash Flow |
|-----------------------------|-----------------------|----------------------------|---------------------------|---------------------|----------------------|----------------------|---------------------|----------------------|-------------------------|----------------------|
| Installation ⁽³⁾ | \$ 92,070 | \$ - | \$ - | \$ - | \$ 92,070 | \$ - | \$ - | \$ - | \$ 92,070 | \$ 92,070 |
| 1 | \$ 417,071 | \$ 85,604 | \$ 87,122 | \$ 111,347 | \$ 701,145 | \$ 671,220 | \$ 698,945 | \$ 27,725 | \$ 2,200 | \$ 94,270 |
| 2 | \$ 332,334 | \$ 85,604 | \$ 36,123 | \$ 113,797 | \$ 567,857 | \$ 565,657 | \$ 565,657 | \$ - | \$ 2,200 | \$ 96,470 |
| 3 | \$ 339,832 | \$ 26,130 | \$ 16,593 | \$ 116,300 | \$ 498,855 | \$ 496,655 | \$ 496,655 | \$ - | \$ 2,200 | \$ 98,670 |
| 4 | \$ 347,499 | \$ 26,130 | \$ 3,573 | \$ 118,859 | \$ 496,061 | \$ 493,861 | \$ 493,861 | \$ - | \$ 2,200 | \$ 100,870 |
| 5 | \$ 355,340 | \$ 26,130 | \$ - | \$ 121,474 | \$ 502,943 | \$ 500,743 | \$ 500,743 | \$ - | \$ 2,200 | \$ 103,070 |
| 6 | \$ 363,357 | \$ - | \$ - | \$ 124,146 | \$ 487,504 | \$ 485,304 | \$ 485,304 | \$ - | \$ 2,200 | \$ 105,270 |
| 7 | \$ 371,556 | \$ - | \$ - | \$ 126,878 | \$ 498,434 | \$ 496,234 | \$ 496,234 | \$ - | \$ 2,200 | \$ 107,470 |
| 8 | \$ 379,941 | \$ - | \$ - | \$ 129,669 | \$ 509,610 | \$ 507,410 | \$ 507,410 | \$ - | \$ 2,200 | \$ 109,670 |
| 9 | \$ 388,515 | \$ - | \$ - | \$ 132,522 | \$ 521,036 | \$ 518,836 | \$ 518,836 | \$ - | \$ 2,200 | \$ 111,870 |
| 10 | \$ 397,282 | \$ - | \$ - | \$ 135,437 | \$ 532,719 | \$ 530,519 | \$ 530,519 | \$ - | \$ 2,200 | \$ 114,070 |
| 11 | \$ 406,248 | \$ - | \$ - | \$ 138,417 | \$ 544,665 | \$ 542,465 | \$ 542,465 | \$ - | \$ 2,200 | \$ 116,270 |
| 12 | \$ 415,416 | \$ - | \$ - | \$ 141,462 | \$ 556,878 | \$ 554,678 | \$ 554,678 | \$ - | \$ 2,200 | \$ 118,470 |
| 13 | \$ 424,792 | \$ - | \$ - | \$ 144,574 | \$ 569,366 | \$ 567,166 | \$ 567,166 | \$ - | \$ 2,200 | \$ 120,670 |
| 14 | \$ 434,380 | \$ - | \$ - | \$ 147,755 | \$ 582,134 | \$ 579,934 | \$ 579,934 | \$ - | \$ 2,200 | \$ 122,870 |
| 15 | \$ 444,184 | \$ - | \$ - | \$ 151,005 | \$ 595,189 | \$ 592,989 | \$ 592,989 | \$ - | \$ 2,200 | \$ 125,070 |
| 16 | \$ 454,210 | \$ - | \$ - | \$ - | \$ 454,210 | \$ 452,010 | \$ 452,010 | \$ - | \$ 2,200 | \$ 127,270 |
| 17 | \$ 464,463 | \$ - | \$ - | \$ - | \$ 464,463 | \$ 462,263 | \$ 462,263 | \$ - | \$ 2,200 | \$ 129,470 |
| 18 | \$ 474,947 | \$ - | \$ - | \$ - | \$ 474,947 | \$ 472,747 | \$ 472,747 | \$ - | \$ 2,200 | \$ 131,670 |
| 19 | \$ 485,669 | \$ - | \$ - | \$ - | \$ 485,669 | \$ 388,363 | \$ 388,363 | \$ - | \$ 97,306 | \$ 228,976 |
| 20 | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - |
| Totals | \$ 7,697,035 | \$ 249,598 | \$ 143,412 | \$ 1,953,641 | \$ 10,043,685 | \$ 9,879,054 | \$ 9,906,779 | \$ 27,725 | \$ 136,906 | \$ - |

NOTES:

- 1 Includes: Hard costs and project service fees defined in ESCO's PROPOSED "FORM V"
- 2 No payments are made by the Board during the construction period.
- 3 Installation period savings for Energy Savings and Operational Savings are guaranteed. These savings will be used in addition to the first loan payment.
- 4 Total Financed Cost includes all Fees and project costs.
- 5 Interest rate is indicative rate only. Final rate will vary with market conditions at time of closing.
- 6 ESG is an energyservices and engineering company, not a financial advisor.
- 7 ESG is not a financial advisor and the presented cash flow proforma is for information only
- 8 The cash flow shown is for illustration purposes, and is not intended as financial advice.
- 9 Loan repayment includes interest accumulation in the construction period
- 10 Loan repayment assumes that the 1st repayment starts immediately after construction
- 11 The annual energy 2.26% and labor .% escalation are in accordance with the RFP
- 12 The utility incentive amount shown is typical expected and is not indicative of the actual amount as project timing, changes to utility program and availability of funds affect the outcome
- 13 The 3rd party M&V fee (0.45% of the annual energy savings) is per the RFP

Incentive Breakout for Recommended Project

| Year | DR EE Credit | NJ Clean Energy Rebates | CHP | Total |
|--------------|------------------|-------------------------|------------------|-------------------|
| 1 | \$ 5,684 | \$61,908 | \$ 19,530 | \$ 87,122 |
| 2 | \$ 3,573 | \$0 | \$ 32,550 | \$ 36,123 |
| 3 | \$ 3,573 | \$0 | \$ 13,020 | \$ 16,593 |
| 4 | \$ 3,573 | \$0 | \$0 | \$ 3,573 |
| TOTAL | \$ 16,403 | \$ 61,908 | \$ 65,100 | \$ 143,412 |

Greenhouse Gas Reductions

| Avoided Emissions | Total Electric Savings | Total Natural Gas Savings | Total Annual Avoided Emissions |
|---------------------|------------------------|---------------------------|--------------------------------|
| Annual Unit Savings | kWh | Therms | |
| NO _x | 1,698 lbs | 924 lbs | 2,808 lbs |
| SO ₂ | 1,664 lbs | 0 lbs | 1,664 lbs |
| CO ₂ | 2,332,796 Lbs | 1,174,456 lbs | 3,507,254 lbs |

Factors Used in Calculations:

| | |
|-------------------------------------|-----------------------------|
| CO ₂ Electric Emissions: | 1,374 lbs. per MWh saved |
| CO ₂ Gas Emissions: | 11.7 lbs. per therm saved |
| NO _x Electric Emissions: | 1.11 lbs. per MWh saved |
| NO _x Gas Emissions: | 0.0092 lbs. per therm saved |
| SO ₂ Electric Emissions: | 0.98 lbs. per MWh saved |

SECTION 4. ENERGY CONSERVATION MEASURES

1-1 Comprehensive LED Lighting Upgrades

ECM Summary

Lighting Retrofit and Replacement: Most of the lighting fixtures throughout Teaneck Public Schools, utilize older technologies that can be upgraded. Improvements to lighting will reduce electrical consumption and improve lighting levels. The costs of material to maintain the current systems will also be reduced since these renovations replace items (i.e., lamps and ballasts) that are near the end of their life cycle and/or considered environmentally hazardous.

Where appropriate, lighting levels will be adjusted to meet Illumination Engineering Society (IES) standards.

Lighting Levels: Our proposed lighting system improvements will maximize savings while maintaining or improving existing light levels in each area. All installations will comply with IES standards. Post-retrofit light levels are typically increased because of the improved design and installation of newer equipment, but areas that are currently over lit will be adjusted to maintain IES recommended light level. Before and after sample light level reading will be performed to confirm expected results.

Exterior Lighting: In an effort to reduce electricity consumption and provide better security for Teaneck Public School buildings, ESG is proposing to retrofit the existing outside lighting (excludes parking lots) on the buildings with newer, LED technology with photocells for automatic control. In addition, every effort will be made to standardize the installed components for equipment uniformity and maintenance simplicity. Typical LED lighting system exhibit the following characteristics:

- Extremely Long Life – up to 50,000+ hours
- Highly efficient with very low wattage consumption
- Solid state lighting technology ensures that the fixtures are highly durable

Lighting Controls: Lighting controls are effective in areas where lighting is left on unnecessarily, mainly because it is a common area or due to the inconvenience to manually switch lights off when a room is left or on when a room is first occupied. This is common in rooms that are occupied for only short periods and only a few times per day. Lighting controls come in many forms. Sometimes an additional switch is adequate to provide reduced lighting levels when full light output is not needed.

Occupancy sensors detect motion and will switch the lights on when the room is occupied. No Occupancy/Vacancy sensors were included in this project, due to poor economics.

Facilities Recommended for this Measure

- Teaneck High School

Scope of Work

Because the Teaneck High School does not qualify for Direct Install Program incentives, Energy Systems Group recommends retrofitting the lighting system with new LED technology lamps. The retrofit process includes the removal of existing components of fluorescent technology including lamps, ballast(s), and tombstones. If the lens of the existing fixture is cracked or discolored, ESG will recommend replacement of this component as well. ESG recommends replacing the fluorescent technology components with new LED technology components - Direct wired Type – B LED T8 Tube and tombstone replacement.

Teaneck Public Schools Energy Savings Plan

There was no recommendation for upgrade to the metal halide and quartz downlights in the Auditorium space. Unfortunately, no cost effective options are available that will work with the existing dimming system. In order to replace these lights with an energy saving lower wattage technology, the existing dimming system will need to be replaced with a compatible dimming system. This option is not a cost effective solution for the project.

Any classrooms with bi-level switching will be converted to a checkerboard pattern, rather than two levels within each fixture.

Any existing LED fixtures will remain and not be replaced.

Energy Systems Group included (54) Fifty Four “1200 Lumen Constant Wattage Emergency Back-up LED Strip” in existing egress fixtures to provide illumination during a power loss.

Refer to Line by Line inventory included in the appendix for comprehensive fixture list.

Savings Methodology

In general, savings calculations for lighting retrofits are calculated using the following methodology:

| Savings Calculation Method | | |
|--|---|---|
| Baseline Energy Usage (kWh / yr) | = | Existing Fixture Watts x Operating Hours / yr x 1 kW / 1000 Watts |
| Estimated Energy Usage (kWh / yr) | = | Proposed Fixture Watts x Op. Hours/yr x 1 kW / 1000 Watts |
| Energy Savings (kWh / yr) | = | Baseline Energy Usage – Estimated Energy Usage |
| Baseline Demand (kW) | = | Existing Fixture Watts / 1000 Watts |
| Retrofit Demand (kW) | = | Proposed Fixture Watts / 1000 Watts |
| Energy Savings (kW) | = | (Existing Fixture Watts – Proposed Fixture Watts) x 1 kW / 1000 Watts |

Maintenance

Lighting will need to be replaced in order to provide consistent light quality throughout the exterior space. It is recommended to conduct group re-lamping on regularly scheduled intervals in order to minimize maintenance requirements.

Benefits

- Electrical energy savings
- Improved exterior light quality
- Reduction in maintenance of exterior lighting system
- Improved safety around school perimeter
- Reduced lamp replacement for 5 to 10 years for LEDs

1-2 Direct Install Program (Lighting)

ECM Summary

Existing small to mid-sized commercial and industrial facilities with a peak electric demand that did not exceed 200 kW in any of the preceding 12 months are eligible to participate in the Direct Install program. Applicants will submit the last 12 months of electric utility bills indicating that they are below the demand threshold and have occupied the building during that time. Buildings must be located in New Jersey and served by one of the state's public, regulated electric or natural gas utility companies. Created specifically for existing small to medium-sized facilities, Direct Install is a turnkey solution that makes it easy and affordable to upgrade to high efficiency equipment.

Facilities Available for Direct Install

- Benjamin Franklin Middle School
- Bryant Elementary School
- Thomas Jefferson Middle School
- Lowell Elementary School
- Hawthorne Elementary School

Scope of Work

- ESG will work closely with one of the program partners to evaluate the Direct Install Program
- The systems and equipment addressed by the program are
 - Lighting
 - Fuel use economizers
 - Low flow DHW devices, etc.

Lighting Levels: Our proposed lighting system improvements will maximize savings while maintaining or improving existing light levels in each area. All installations will comply with IES standards. Post-retrofit light levels are typically increased because of the improved design and installation of newer equipment, but areas that are currently over lit will be adjusted to maintain IES recommended light level. Before and after sample light level reading will be performed to confirm expected results.

Exterior Lighting: In an effort to reduce electricity consumption and provide better security for Teaneck Public School buildings, ESG is proposing to retrofit the existing outside lighting (excludes parking lots) on the buildings with newer, LED technology with photocells for automatic control. In addition, every effort will be made to standardize the installed components for equipment uniformity and maintenance simplicity. Typical LED lighting system exhibit the following characteristics:

- Extremely Long Life – up to 50,000+ hours
- Highly efficient with very low wattage consumption
- Solid state lighting technology ensures that the fixtures are highly durable

Lighting Controls: Lighting controls are effective in areas where lighting is left on unnecessarily, mainly because it is a common area or due to the inconvenience to manually switch lights off when a room is left or on when a room is first occupied. This is common in rooms that are occupied for only short periods and only a few times per day. Lighting controls come in many forms. Sometimes an additional switch is adequate to provide reduced lighting levels when full light output is not needed.

Occupancy sensors detect motion and will switch the lights on when the room is occupied. No Occupancy/Vacancy sensors were included in this project, due to poor economics.

Teaneck Public Schools Energy Savings Plan

Energy Systems Group recommends replacing the aging lighting system with new High Efficiency LED technology. The majority of fixtures will be replaced with new Flat panel LED technology. In each building there is a minority of specific areas that will require an LED retrofit because of technology or economic constraints.

The following locations have area specific assumptions and exclusions:

Ben Franklin Middle School

- ESG does not recommend an upgrade for the 300w R40 lamps in Auditorium downlights. There are no cost-effective high lumen options that are compatible with the dimming system.
- Bi-Level switching in (3) classrooms will be converted to a checkerboard pattern, rather than two levels within each fixture.
- Existing light levels are very low. A number of classrooms were in the 20-25 fc range.

Thomas Jefferson Middle School

- ESG does not recommend an upgrade for the 250w R40 lamps in Auditorium downlights. There are no cost-effective high lumen options that are compatible with the dimming system.
- Only (10) emergency battery backup ballasted fixtures were recorded in this school. All on second floor restrooms.
- Existing light levels are very low. A number of classrooms were in the 20-25 fc range.

Bryant Elementary School

- ESG recommends new LED Tube retrofits in areas that have Direct/Indirect fixtures such as in restrooms and in display cases.
- Light Levels were recorded on average of 35 – 40 footcandles.

Hawthorne Elementary School

- ESG recommends new LED Tube retrofits in areas such as display cases.
- Bi-Level switching in classrooms will be converted to a checkerboard pattern, rather than two levels within each fixture.
- Light Levels were recorded on average of 35 – 40 footcandles.

Lowell Elementary School

- ESG recommends new LED Tube retrofits in areas that have Direct/Indirect fixtures such as in restrooms and in display cases.
- Bi-Level switching in cafeteria, classrooms and library will be converted to a checkerboard pattern, rather than two levels within each fixture.
- Light Levels were recorded on average of 35 – 40 footcandles.

Whittier Elementary School

- ESG recommends new LED Tube retrofits in areas such as display cases.
- Light Levels were recorded on average of 35 – 40 footcandles.

Through conversation with Teaneck staff the following locations were discussed to have material only left on site. Installation will be the responsibility of Teaneck PS. Taking into consideration a six to eight week lead time, Teaneck will request the material from ESG when ready. ESG will have the materials delivered to Teaneck at the specified location. Materials will consist of the LED Flat panel fixtures only. No wiring, or ancillary electrical components are included.

Teaneck Public Schools Energy Savings Plan

| BENJAMIN FRANKLIN MIDDLE SCHOOL - Material Only Locations | | | | | |
|---|--------------------|-------------|----------|-----------------------|----------------------------|
| Floor | Space Type | Room Number | Quantity | Existing Fixture Type | Replacement Fixture Type |
| First Floor | Classroom | 105 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 107 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 108 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 106 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 104 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 202 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 201 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Second Floor | Media Center | | 21 | 1x8-4FO28-Fin | New 41w 1x8 LED Low Bay |
| Second Floor | Storage (Locked) | | 1 | 1x8-4FO28-Fin | New 41w 1x8 LED Low Bay |
| Second Floor | Prep Room | | 1 | 1x8-4FO28-Fin | New 41w 1x8 LED Low Bay |
| Second Floor | | | 1 | 1x4-2FO28-FIN | New 23w 1x4 LED Low Bay |
| Second Floor | Instrumental Music | 204 | 15 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Second Floor | Office | | 2 | 1x8-4FO28-Fin | New 41w 1x8 LED Low Bay |
| Third Floor | Classroom | 307 | 8 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Third Floor | Classroom | 305 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Third Floor | Classroom | 303 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Third Floor | Classroom | 301 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |

Teaneck Public Schools Energy Savings Plan

| THOMAS JEFFERSON MIDDLE SCHOOL - Material only locations | | | | | |
|--|------------|-------------|----------|-----------------------|----------------------------|
| Floor | Space Type | Room Number | Quantity | Existing Fixture Type | Replacement Fixture Type |
| Second Floor | Classroom | 201 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 204 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 206 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 208 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 210 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 212 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 214 | 8 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Second Floor | Prep Room | | 3 | 1x8-4FO28-Fin | New 30w 2x4 LED Flat Panel |
| Second Floor | Classroom | 216 | 8 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 218 | 6 | 1x8-4FO28-Fin | New 30w 2x4 LED Flat Panel |
| Second Floor | | | 2 | 1x4-2FO28-FIN | New 30w 2x4 LED Flat Panel |
| Second Floor | Classroom | 215 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 213 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 222 | 2 | 1x8-4FO28-Fin | New 30w 2x4 LED Flat Panel |
| Second Floor | | | 2 | 1x4-2FO28-FIN | New 30w 2x4 LED Flat Panel |
| Second Floor | Classroom | 211 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Second Floor | | | 3 | 1x8-4FO28-W | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 209 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 207 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 205 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Floor | Space Type | Room Number | Quantity | Existing Fixture Type | Replacement Fixture Type |
| Second Floor | Classroom | 203 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 202 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |

Teaneck Public Schools Energy Savings Plan

| | | | | | |
|---------------------|-----------|------|---|---------------|----------------------------|
| First Floor | Classroom | 116A | 6 | 1x8-4FO28-W | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 120B | 2 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| First Floor | Studio | 121 | 4 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| First Floor | | | 2 | 1x4-2FO28-FIN | New 30w 2x4 LED Flat Panel |
| First Floor | Classroom | 109 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 107 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 105 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 103 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 102 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 101 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 104 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 106 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 108 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 110 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 111 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | G4 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | G3 | 6 | 1x8-4FO28-Fin | New 40w 2x4 LED Flat Panel |

Teaneck Public Schools Energy Savings Plan

Refer to Line by Line inventory included in the appendix for comprehensive fixture list.

Savings Methodology

In general, savings calculations for lighting retrofits are calculated using the following methodology:

| Savings Calculation Method | | |
|--|---|---|
| Baseline Energy Usage (kWh / yr) | = | Existing Fixture Watts x Operating Hours / yr x 1 kW / 1000 Watts |
| Estimated Energy Usage (kWh / yr) | = | Proposed Fixture Watts x Op. Hours/yr x 1 kW / 1000 Watts |
| Energy Savings (kWh / yr) | = | Baseline Energy Usage – Estimated Energy Usage |
| Baseline Demand (kW) | = | Existing Fixture Watts / 1000 Watts |
| Retrofit Demand (kW) | = | Proposed Fixture Watts / 1000 Watts |
| Energy Savings (kW) | = | (Existing Fixture Watts – Proposed Fixture Watts) x 1 kW / 1000 Watts |

Maintenance

Lighting will need to be replaced in order to provide consistent light quality throughout the exterior space. It is recommended to conduct group re-lamping on regularly scheduled intervals in order to minimize maintenance requirements.

Benefits

- Reduced installation cost utilizing Direct Install Incentive Program.
- Electrical energy savings

1-3 Install VFD's and Premium Motor Upgrades for HVAC

ECM Summary

This measure will replace constant volume pumping systems with a variable flow system through the installation of Variable Frequency Drive(s) (VFD) on electric motor(s) for hot water pumps, where prudent. Constant volume systems are equipped with a differential pressure sensor and bypass valve that diverts water not being used at the terminal units back to the pump inlet. While this enables the system to properly control flow at the units, the central pumps continually operate at full speed/flow. Varying the speed of a motor to match the actual load at the terminal units reduces the pumps electrical motor power (kW), which results in significant electrical energy savings.

Any single speed or two speed inverter-duty pump motor (typically greater than 5 to 10 HP) that has fluctuating loads is a good candidate for a variable speed drive. Heating hot water pumps are ideal candidates for VFD control due to the varying loads on building heating demand and motors which are typically larger than 10 HP.

Facilities Recommended for this Measure

- Teaneck High School

Scope of Work by School

Teaneck High School

Removal & New Installation Work

- Disconnect Qty. (2) 25HP heating hot water system base mounted pumps and motors.
- F&I Qty. (2) new 25HP premium efficiency motors with pumps and new variable frequency drives (VFD's).
- Include new suction diffusers, valves, strainers, and flex connectors for each new base mounted pump.
- Include vibration isolation for (2) new base mounted pumps.
- Install new VFD's on wall and connect line voltage from new VFD's to new motors.
- Tap will need to be installed by MC in heating hot water main pipe with location determined by engineer for pressure differential switch with controls and wiring to be by controls contractor.

Teaneck Public Schools Energy Savings Plan

Savings Methodology

| | |
|--|---|
| Motor (kW) = | (Motor Horsepower x 0.746 (kW/HP) x Load Factor) = or = (Motor Amperage x Volts x 1.732 x Power Factor) / 1000 |
| Speed Ratio Correction Factor = | ((New RPM)/(Existing RPM)) ^ 3 |
| Existing Energy Use (kWh)= | (Existing kW /Existing Efficiency) x Hours of Use |
| Existing Demand Use (kW) = | (Existing kW /Existing Efficiency) x Peak Load Months x Utilization factor |
| New Energy Use (kWh) = | (New kW /New Efficiency) x Hours of Use x Speed Ratio Correction Factor |
| New Demand Use (kW) = | (New kW /New Efficiency) x Peak Load Months x Utilization factor x Speed Ratio Correction Factor |
| Total Savings (kWh, kW) = | (kWh existing - kWh new) x \$/kWh + (kW existing - kW new) x \$/kW |

Maintenance

Periodically the equipment should be checked to ensure proper operation.

Benefits

- Minimizes pump unit energy efficiency
- Lower operating cost

2-1 Plug Load Controls

ECM Summary



**BERT Plug Load Management
Software**



BERT Plug Load Management Devices

Office equipment is always regularly left in the 'on' state allowing the individual machine to revert to the 'Sleep' mode based on an internal timer. This measure will plug the office equipment into a networkable device that will allow for scheduling of the plugged-in equipment. A full survey of plug load devices for each facility was performed by ESG.

Energy Systems Group recommends utilizing specialty wall sockets from BERT that have software to track real-time electrical usage of your appliances. The software also allows you to use your web browser to view this usage and automatically turn on/off any and all appliances plugged into these outlets.

A full plug load survey was completed for each facility, detailed charts can be found in the appendix.

Facilities Recommended for this Measure

- Benjamin Franklin Middle School
- Hawthorne Elementary School
- Whittier Elementary School
- Lowell Elementary School
- Teaneck High School
- Thomas Jefferson Middle School

Scope of Work

Refer to Appendix 4 for detailed counts per building and scope descriptions.

Teaneck Public Schools Energy Savings Plan

Savings Methodology

Savings are calculated using the following methodology for all devices plugged in:

| Savings Calculation Methodology | | |
|---|---|--|
| Baseline Energy Usage (kWh / yr) | = | Average kW x Baseline Weekly Hours x 4.348 wks/mo. x Months/yr |
| Proposed Energy Usage (kWh/ yr) | = | Average kW x Proposed Weekly Hours x 4.348 wks/mo. x Months/yr |
| Electrical Savings (kWh/ yr) | = | Baseline Energy Usage – Proposed Energy Usage |

Maintenance

Periodically the equipment should be checked to ensure proper operation.

Benefits

Electrical energy savings

2-2 Combined Heat and Power (35 kW)

ECM Summary

Energy Systems Group proposes to install one (1) 35 kW cogeneration machine at Teaneck High School to supply electricity and heat to the Teaneck High School, which will offset a portion of the boiler load. The recovered heat will be rejected into the boiler hot water heating system.

Facilities Recommended for this Measure

- Teaneck High School



Scope of Work

The Yanmar CHP engine will be installed next to existing boilers on concrete pad with module.

New Installation Work:

Furnish & Install (1) Yanmar Model CP35D1-TNUG (35 kW) or equivalent, the high-efficiency generator provides 35kW of electrical power. The engine heat is captured and heats water at a rated temperature of 158°F for immediate use or storage in your facility.

- Natural gas fired CHP unit with heat rejection system located on outside wall of boiler room mounted in existing combustion air louver converted for radiator and fan.
- New CHP location will be in basement and set on new concrete housekeeping pad.
- F&I new gas piping to CHP unit from main gas meter bank.
- F&I new insulated hot water piping overhead from Yanmar CHP pump module to heating hot water system piping and heat rejection system.
- F&I new electrical power from Yanmar CHP unit to building electrical main switchgear.
- New exhaust vent piping to go through exterior wall.
- Provide factory commissioning of system (start up and testing).

Teaneck Public Schools Energy Savings Plan

Savings Methodology

In general, savings calculations for lighting retrofits are calculated using the following methodology:

| Savings Calculation Method | |
|---------------------------------------|--|
| Energy: | 35 kW/module x 1 module(s) x 1 net after "parasitic losses" |
| Electrical Cost Avoided | 35 net kW output x \$/kWh avg. displaced energy x run hours |
| Demand : | 35 kW/module x 1 module(s) available x 1 net after "parasitic losses" |
| Heat Used to Displace Boiler Gas Use: | $\frac{\left(\frac{Th}{hr\ module}\right) \times}{boiler\ efficiency} \times 1\ modules \times \$/Th\ boiler\ gas\ rate$ |

Maintenance

Follow manufacturers' recommendations for preventative maintenance. In order to be eligible for New Jersey Clean Energy incentives, Teaneck Public Schools must demonstrate that they have contracted for an extended maintenance agreement to service the cogeneration units. This maintenance agreement will be conducted outside of the Energy Savings Improvement Program, as required by law.

Benefits

The installation of a cogeneration unit will result in significant economic benefits to the overall ESIP program. These benefits include:

- Up to 20-year financing term.
- Substantial NJ Clean Energy incentives.
- Potential demand response revenue generation.
- Additional funding from FEMA grants and other local, state, and national incentives.

2-3 Computer Power Management Software

ECM Summary

Energy Systems Group will furnish and install a software utility that measures, manages, and minimizes the energy consumed by the network's PC clients through one centralized interface. It provides IT departments with a powerful approach to automate energy-efficient "best practices" throughout their networks, while it adds new control and flexibility to traditional PC power management.

With the help and cooperation of the District, ESG will install and rapidly deploy PC Power Management software on the District's PC network. A one-day deployment plan will address server and client installation, basic administrative configurations, logical power management profile groupings, and energy consumption reporting. Ongoing technical support and product revisions, with an annual energy audit to ensure maximized energy savings are also included for a period of three years.

Facilities Recommended for this Measure

| | |
|---------------------------------|--------------------------------|
| Benjamin Franklin Middle School | Lowell Elementary School |
| Whittier Elementary School | Teaneck High School |
| Hawthorne Elementary School | Thomas Jefferson Middle School |

Scope of Work

Power Management software/hardware and installation will include approximately (800) existing computer machines. Details concerning computer quantities are listed in the appendix concerning the energy savings calculations.

Savings Methodology

In general, savings calculations for lighting retrofits are calculated using the following methodology:

| Savings Calculation Method | |
|----------------------------|--|
| Existing kW | = Listed Equipment Amperage x Voltage of Equipment |
| Cost per kWh | = Average Site Data Package \$/kWh |
| Cost of Existing Equipment | = Existing kW x Cost per kWh x Effective Full Load Hours |
| Cost of Proposed Equipment | = Existing kW x Cost per kWh x Full Load Hours Using Control |
| Energy Savings | = Existing Equipment Costs – Proposed Equipment Costs |

Maintenance

Update software as needed.

Benefits

- Energy Savings

2-4 Refrigeration Controls

ECM Summary

The kitchens throughout Teaneck District Schools contain walk-in freezers, walk-in coolers, reach-in freezers and reach-in coolers. These units are controlled by a dry bulb temperature and as a result run continuously throughout the year. Installing an **NRM Cooltrol®** retrofit was assessed. The refrigeration systems usually monitor circulating air temperature in order to decide when to switch on and off. The circulating air temperature tends to rise far more quickly than the food temperature, and as result, the refrigeration unit works harder than necessary to maintain stored products at the right temperature. This, in turn, leads to excessive electricity consumption and undue wear and tear on the equipment. With **NRM Cooltrol®**, the thermostat regulates the refrigeration temperature based upon product temperature rather than air temperature, thereby maintaining product at the proper temperature. Savings is a result of reduced frequency of the compressor cycles, which are now based on food temperature rather than volatile air temperature. The equipment present in the schools are shown in the table below.



| Existing Refrigeration Systems | |
|--|-----------|
| Teaneck High School | Cooler |
| | Freezer |
| Thomas Jefferson Middle School | Freezer A |
| | Freezer B |
| | Cooler C |
| Benjamin Franklin Middle School | Freezer A |
| | Freezer B |
| | Cooler C |

Facilities Recommended for this Measure

- Benjamin Franklin Middle School
- Thomas Jefferson Middle School
- Teaneck High School

Teaneck Public Schools Energy Savings Plan

Scope of Work

Furnish and install NRM Cooltrol® at the following locations:

Teaneck High School

- Two zone(s) of energy-saving CoolTrol refrigeration controls to cycle temperature and evaporator fans
- Replace four (4) existing shaded-pole motors with four (4) EC motors in evaporators
- Dewpoint-based pulse control for anti-sweat door heaters

Thomas Jefferson Middle School

- Three zone(s) of energy-saving CoolTrol refrigeration controls to cycle temperature and evaporator fans
- Replace five (5) existing shaded-pole motors with five (5) EC motors in evaporators
- Dewpoint-based pulse control for anti-sweat door heaters

Benjamin Franklin Middle School

- Three zone(s) of energy-saving CoolTrol refrigeration controls to cycle temperature and evaporator fans
- Replace six (6) existing shaded-pole motors with six (6) EC motors in evaporators
- Dewpoint-based pulse control for anti-sweat door heaters

Savings Methodology

Energy savings will result from reducing the compressor cycling. In general, ESG uses the following approach to determine savings for this specific measure:

| Savings Calculation Method | | |
|---------------------------------------|---|---|
| Pre - kW | = | Compressor (HP) x 0.746 x Pre Cycles/hr |
| Post - kW | = | Compressor (HP) x 0.746 x Post Cycles/hr |
| Summer Season Hrs (Hs) | = | Total Hrs/yr x 55% |
| Winter Season Hrs (Hw) | = | Total Hrs/yr x 45% |
| Compressor Summer Cycling (% On) (Cs) | = | 55% |
| Compressor Winter Cycling (% On) (Cw) | = | 35% |
| Compressor Summer Operating (Hrs) | = | Hs x Cs |
| Compressor Winter Operating (Hrs) | = | Hw x Cw |
| Savings (kW) | = | Pre – Post (KW) |
| Savings (kWh) | = | (Compressor Summer Operating (Hrs)+ Compressor Winter Operating (Hrs)) x (Pre – Post (KW)) |

Teaneck Public Schools Energy Savings Plan

Maintenance

Periodically the equipment should be checked to ensure proper operation.

Benefits

- Electrical energy savings
- Reduces evaporator fan run-time

2-5/2-7 Direct Install Program Fuel Use Economizers

ECM Summary

A heating system must be able to provide acceptable comfort at the lowest anticipated outdoor temperature. Most commercial/industrial boilers have a heating capacity 1.5 to 2 times larger than needed to maintain space temperature on extreme days. Due to this oversizing of the boiler, the burner will cycle on and off to prevent overheating of the system water during any call for heat.

Intellidyne Heating System Economizers increase system efficiency, thus, the heating system uses less fuel to generate the same amount of heat. This is done by dynamically changing the aquastat's effective dead-band based on the measured heating load. This causes the average water temperature to be varied (depending on the measured load) and is accomplished by extending the burner's off-time. Extending the off-time also results in longer, more efficient burns and a reduction in burner cycling. Just as computer control has increased the gas mileage of automobiles, Intellidyne Heating System Economizers improve the fuel utilization of heating systems by supplementing the antiquated on/off control action of the aquastat with the analysis and control capabilities of a computer.

Facilities Recommended for this Measure

- Benjamin Franklin Middle School
- Bryant Elementary School
- Whittier Elementary School
- Lowell Elementary School
- Hawthorne Elementary School
- Thomas Jefferson Middle School

Scope of Work

Benjamin Franklin Middle School

New Installation Work:

Proposed are the following:

- Furnish & install (F&I) (3) each Intellidyne IntelliCon Controls at the boiler burners.
- Provide connection to existing, or newly installed, building Energy Management System (EMS)
- Provide factory commissioning of system (start up and testing).

Bryant Elementary School (Direct Install Program)

New Installation Work:

Proposed are the following:

- Furnish & install (F&I) (2) each Intellidyne IntelliCon Controls at the boiler burners.
- Provide connection to existing, or newly installed, building Energy Management System (EMS)
- Provide factory commissioning of system (start up and testing).

Hawthorne Elementary School (Direct Install Program)

New Installation Work:

Proposed are the following:

- Furnish & install (F&I) (2) each Intellidyne IntelliCon Controls at the boiler burners.
- Provide connection to existing, or newly installed, building Energy Management System (EMS)
- Provide factory commissioning of system (start up and testing).

Teaneck Public Schools Energy Savings Plan

Scope of Work Continued...

Lowell Elementary School (Direct Install Program)

New Installation Work:

Proposed are the following:

- Furnish & install (F&I) (2) each Intellidyne IntelliCon Controls at the boiler burners.
- Provide connection to existing, or newly installed, building Energy Management System (EMS)
- Provide factory commissioning of system (start up and testing).

Thomas Jefferson Middle School

New Installation Work:

Proposed are the following:

- Furnish & install (F&I) (3) each Intellidyne IntelliCon Controls at the boiler burners.
- Provide connection to existing, or newly installed, building Energy Management System (EMS)
- Provide factory commissioning of system (start up and testing).

Whittier Elementary School (Direct Install Program)

New Installation Work:

Proposed are the following:

- Furnish & install (F&I) (2) each Intellidyne IntelliCon Controls at the boiler burners.
- Provide connection to existing, or newly installed, building Energy Management System (EMS)
- Provide factory commissioning of system (start up and testing)

Savings Methodology

Energy savings will result from reducing the compressor cycling. In general, ESG uses the following approach to determine savings for this specific measure:

| Savings Calculation Method | | |
|---|---|---|
| Total Existing Boiler Natural Gas Usage (Therms) | = | Therms |
| Savings (% of Total) | = | 13%* |
| Factor of Safety | = | 50% |
| Total Natural Gas Savings (Therms) | = | (Existing Usage)*(Savings %)*(Factor of Safety) |

The savings estimate (%) matches the value stipulated by the New Jersey Board of Public Utilities New Jersey Clean Energy Program Protocols to Measure Resource Savings. ESG has also applied a 50% factor of safety to lower the estimated savings.

Maintenance

Periodically the equipment should be checked to ensure proper operation.

Benefits

- Natural Gas savings

2-6 Direct Install Program - Low-flow Domestic Hot Water Devices

ECM Summary

Bathroom and kitchen fixtures offer good water saving opportunities because many of these fixtures can be retrofit to reduce the amount of water consumed per minute of use (sinks and showers). Reducing sink water usage also saves the thermal energy used to make hot water.

Facilities Recommended for this Measure

- Hawthorne Elementary School
- Lowell Elementary School
- Bryant Elementary School
- Whittier Elementary School

Scope of Work

Installation of Low-flow Domestic Hot Water Devices on Sink Faucets –

- Existing high flow faucets on 98 sinks will be retrofit to 1.0 gpm:
- For those faucets from which existing aerators cannot be removed without damaging the faucet, a replacement aerator will not be installed. The replacement aerator will be turned over to Owner with the project's shelf stock.
- Where possible, tamper resistant aerator will be installed. For faucets that cannot accept a tamper resistant aerator, a regular aerator will be installed.

| Proposed Aerator Replacements by School | | | |
|---|-------------------|------------------|--------------------------|
| Building | Lavatory Fixtures | Kitchen Fixtures | Toilet & Shower Fixtures |
| Bryant Elementary School | 17 | 8 | 0 |
| Hawthorne Elementary School | 12 | 3 | 0 |
| Lowell Elementary School | 14 | 5 | 0 |
| Whittier Elementary School | 24 | 14 | 0 |

Teaneck Public Schools Energy Savings Plan

Savings Methodology

Thermal energy savings for sink usage is based on the following assumptions: the ratio of hot-to-cold water use, average hot and cold-water temperatures, and the domestic hot water heater efficiency.

| Savings Calculation Method | | |
|---------------------------------------|---|--|
| Frequency of Use | = | Number of users x % year-round occupancy x fixture uses/day/person |
| Water Savings (gal/yr) | = | Frequency of Use x (Baseline – Estimated Flow Rate) (gpm or gpf per fixture) x days/year x % high-flow fixtures |
| Sink/Shower Energy Savings (MMBtu/yr) | = | Water Savings (gal/yr) x (Tmixed -Tcold) (°F) x (1 Btu/lb °F X 8.34 (lb/gal) x 1 MMBtu/1,000,000 Btu |
| Sink/Shower Energy Savings (kWh/yr) | = | = Energy Savings (MMBtu/yr) x 293.1 kWh/1 MMBtu |
| Cost Savings (\$/yr) | = | [Water Savings] (kgal/yr) x [water rate + sewer rate] (\$/kgal) + [(Sink/Shower Energy Savings (MMbtu/yr)] x 1/boiler efficiency (%) x Thermal Rate (\$/MMbtu)] + [(Sink/Shower Energy Savings (kWh/yr)] x 1/boiler efficiency (%) x Electric Rate (\$/kWh)] |

Maintenance

Periodically the equipment should be checked to ensure proper operation.

Benefits

- Incentives available under NJ Direct Install Program
- Reducing water will result in natural gas (heated hot water) savings
- Decreased water usage

3-4 Replace Cooling in Media Center (Ben Franklin Middle School)

ECM Summary

Split units at Teaneck Public Schools vary based on age and condition. Replacing aged mini-split HVAC units will reduce the operating and maintenance costs of these systems. Both heating and cooling efficiencies of mini-split heat pump equipment have significantly increased in the past 10 years. ESG has identified several older units that still utilize R22 refrigerant as the prime candidates for replacement.

Facilities Recommended for this Measure

- Benjamin Franklin Middle School

Scope of Work

Currently there are (3) wall unit ventilators with HW heating coils and (3) wall mount mini split indoor units 'one unit was removed' and (4) mini -split outdoor units on roof above. Concept is to replace existing (4) mini-split systems with (4) new high efficiency mini-split heat pump systems.

Demolition and Removal Work

- Reclaim and dispose of refrigerant by licensed company from (4) existing mini-split outdoor systems on roof.
- Disconnect electrical, refrigerant piping and condensate pipe to remove (3) indoor wall mount units and (4) outdoor units on roof.
- Remove existing refrigerant piping for all (4) systems.
- Provide crane for removing of old units and setting of new units.
- Remove all demolished materials and equipment from premises and dispose of in accordance with local regulations.

New Installation Work:

Proposed are the following:

- F&I Qty. (4) Mitsubishi (or approved equal) Model PVA-A36AA7 3-ton (208/230/1) indoor wall mounted cassette units.
- F&I Qty. (4) Mitsubishi (or approved equal) Model PUZ-HA36NHA5 (33,400 BTUH Cooling / 38,000 BTUH Heating, 16.2 SEER / 12.0 EER) outdoor heat pump units placed on roof with new preformed plastic unit pads elevated with pump-up legs.
- F&I new outdoor electric disconnects for each heat pump unit.
- Reconnect power wiring to new equipment.
- F&I new manufacturers insulated refrigerant tubing packages which include interconnecting wiring.
- F&I new condensate pumps and piping as required for new indoor units.
- Mechanical Contractor to coordinate with Controls Contractor to provide integration of cooling system control and monitoring points into the DDC control system.
- Perform startup and test of new systems.

Teaneck Public Schools Energy Savings Plan

Savings Methodology

| Savings Calculation Method | | |
|----------------------------|---|---|
| Cooling Savings (kWh) | = | RTU-Size (Tons) x Cooling gradient (%) x (Existing RTU kW/Ton – New RTU kW/Ton) x Bin Hours |
| Heating Savings (kWh) | = | RTU-Size (Tons) x Heating gradient (%) x (Existing RTU kW/Ton – New RTU kW/Ton) x Bin Hours |

Maintenance

Periodically the equipment should be checked to ensure proper operation.

Benefits

- Electric savings

3-5 Replace Cooling in Media Center (Lowell Elementary School)

ECM Summary

Split units at Teaneck Public Schools vary based on age and condition. Replacing aged mini-split HVAC units will reduce the operating and maintenance costs of these systems. Both heating and cooling efficiencies of mini-split heat pump equipment have significantly increased in the past 10 years. ESG has identified several older units that still utilize R22 refrigerant as the prime candidates for replacement.

Facilities Recommended for this Measure

- Lowell Elementary School

Scope of Work

Currently there are (5) split systems that are servicing the library and special education areas at Lowell Elementary School. Concept is to replace existing (5) split systems with (5) new high efficiency split systems. This work will be completed through the Direct Install as part of the lighting upgrade to the school.

Demolition and Removal Work

- Reclaim and dispose of refrigerant by licensed company from (5) existing split outdoor systems on roof.
- Disconnect electrical, refrigerant piping and condensate pipe to remove (5) outdoor units on roof.
- Remove existing refrigerant piping for all (5) systems.
- Provide crane for removing of old units and setting of new units.
- Remove all demolished materials and equipment from premises and dispose of in accordance with local regulations.

New Installation Work:

Proposed are the following:

- F&I Qty. (5) high-efficiency electric split systems (2) 3-ton units, (2) 4-ton units, and (1) 2.5-ton units) with new preformed plastic unit pads elevated with pump-up legs.
- F&I new outdoor electric disconnects for each heat pump unit.
- Reconnect power wiring to new equipment.
- F&I new manufacturers insulated refrigerant tubing packages which include interconnecting wiring.
- F&I new condensate pumps and piping as required for new indoor units.
- Mechanical Contractor to coordinate with Controls Contractor to provide integration of cooling system control and monitoring points into the DDC control system.
- Perform startup and test of new systems.

Teaneck Public Schools Energy Savings Plan

Savings Methodology

| Savings Calculation Method | | |
|----------------------------|---|---|
| Cooling Savings (kWh) | = | RTU-Size (Tons) x Cooling gradient (%) x (Existing RTU kW/Ton – New RTU kW/Ton) x Bin Hours |
| Heating Savings (kWh) | = | RTU-Size (Tons) x Heating gradient (%) x (Existing RTU kW/Ton – New RTU kW/Ton) x Bin Hours |

Maintenance

Periodically the equipment should be checked to ensure proper operation.

Benefits

- Electric savings

3-6 Replace Rooftop Cooling Unit at Whittier Elementary School

ECM Summary

Condensing units at Teaneck Public Schools vary based on age and condition. Replacing aged condensing HVAC units will reduce the operating and maintenance costs of these systems. Whittier Elementary School's current setup includes using the condensing unit located on the roof to cool a chiller barrel located in the boiler room to provide chilled water to the new section of the school. ESG has identified this setup as a prime candidate to be replaced by packaged air-cooled chiller located on the roof of the building.

Facilities Recommended for this Measure

- Whittier Elementary School

Scope of Work

Scope is to replace existing 40 Ton, R-22 DX split condenser on roof and indoor chiller barrel with new R-410A high efficiency packaged air cooled chiller with built-in pumps, eliminating chiller barrel.

Demolition and Removal Work

- Shut down system, reclaim and dispose of refrigerant by licensed company.
- Disconnect electrical, CHW piping, refrigerant piping, condensate pipe and controls.
- Crane unit off condenser onto flatbed trailer and remove indoor chiller barrel for disposal.
- Remove all existing refrigerant piping.
- Remove all demolished equipment and materials from premises and dispose of in accordance with local regulations.

New Installation Work:

Proposed are the following:

- F&I Qty. (1) York Model YCA0043 (or approved equal) (40 Ton) Air Cooled Chiller with built-in CHW pumps to set on existing roof supports. New unit to match existing electrical voltage and phase.
- Modify existing condenser unit roof rail supports to accept new chiller unit without involving the removing of existing roof rails. Engineer will need to perform calculations for added weight and if any additional steel will be required.
- Provide crane for setting of new chiller unit.
- Mechanical Contractor to coordinate with Controls Contractor to provide integration of cooling system control and monitoring points into the DDC control system.
- Perform startup and test of new systems.

Teaneck Public Schools Energy Savings Plan

Savings Methodology

| Savings Calculation Method | | |
|----------------------------|---|---|
| Cooling Savings (kWh) | = | RTU-Size (Tons) x Cooling gradient (%) x (Existing RTU kW/Ton – New RTU kW/Ton) x Bin Hours |
| Heating Savings (kWh) | = | RTU-Size (Tons) x Heating gradient (%) x (Existing RTU kW/Ton – New RTU kW/Ton) x Bin Hours |

Maintenance

Periodically the equipment should be checked to ensure proper operation.

Benefits

- Electric savings
- Eliminate recurring maintenance costs

4-1 Condensing Hot Water Boiler Plant (Teaneck High School – Fan Room Upgrades)

ECM Summary

Steam boilers are used to provide heating, through the use of a hot water heat exchanger, to various areas throughout the building. In schools where the boilers are old and in a poor condition, the replacement of existing boilers with a similar output of new greater efficiency units will provide efficiency gains that will generate operating and fuel cost savings. The radiant and convective heat losses will also be reduced with the installation of new boilers which makes the entire hot water system more efficient. Where applicable, the steam boilers that are recommended for replacement will be replaced by condensing boilers with increased efficiencies (including thermal and combustion losses).

The replacement of the single boiler in these boiler plants with multiple new high-efficiency units will generate significant energy savings as well as provide redundancy to the heating system. Each new boiler will be slightly smaller than the existing single boiler, but as a whole central plant will meet or exceed the heating capacity of the current boiler system. The installation of the smaller boilers will increase the efficiency of the entire plant by operating more efficiently at low loads than the single boiler.

Facilities Recommended for this Measure

- Teaneck High School

Scope of Work

Demolition and Removal Work

- Replace (2) each Cleaver Brooks fire-tube boilers with (3) new high efficiency AERCO Benchmark Platinum 3000 (or approved equal) condensing boilers
- Demolition of (2) existing Cleaver Brooks steam boilers.
- Demolition of existing feed water tank and pumps – cut up for removal, if necessary
- Demolition of (2) 25-HP HHW pumps, heat exchanger, condensate receiver and all related steam piping and equipment in boiler mechanical room
- Disconnect, remove and properly dispose of hot water supply and return piping for boilers to nearest isolation valves or as required for new installation.
- Disconnect, remove and properly dispose of gas flue for boilers as required.
- Disconnect all electric, controls, gas piping, water lines, pressure reliefs and drains.
- Remove all demolished materials from premises and dispose of in accordance with local regulations.

New Installation Work:

Proposed are the following:

- Furnish & install (F&I) (3) each high-efficiency AERCO Benchmark Platinum 3000 (or approved equal) condensing boilers set on existing concrete pad.

Details of installation to include the following:

Teaneck Public Schools Energy Savings Plan

- F&I Qty. (3) new AERCO Benchmark Platinum 3000 (or approved equal) condensing hot water boilers
- Set boilers on new concrete pad
- F&I (3) new boiler circulating pumps
- F&I (2) TACO #F15009 6" X 5" End Scustion Flex-Coupled Base Mounted 25-HP Pumps.
- New pumps to include Suction Diffusers, Flanged Multi-purpose Valves, Gauges and Shut-Off Valves.
- New base-mounted pumps and motors are to be specified to match process, electrical and controls requirements.
- F&I all motor mounting adapters required for new motors.
- F&I all power transmission components required to adapt motors to pumps.
- F&I (4) new TACO Dura-Flex Stainless Steel Pipe Couplings.
- F&I new flanged air separator, floor-mounted expansion tanks, condensate neutralization kits with new chemical treatment system.
- F&I all new insulated VIC hot water supply and return piping, valves, fittings to connect from boilers to new Hot Water Header system.
- F&I new boiler drains, pressure reliefs piped to floor drains, water supply, blow down drains piped over to existing floor drains.
- F&I new 2" fiberglass insulation on all new and existing hot water supply and return piping "that has no insulation".
- F&I new gas line piping from existing gas line to new boilers with new shut off valves. Include vent relief piping as designed by engineer.
- F&I new CPVC combustion air intake and AL29-4C Stainless Steel flue exhaust piping for each boiler to vent to the outside.
- F&I proper pipe suspensions for all piping.
- F&I pipe identification and tags for all pipe, valves, etc.
- Install new line voltage electrical circuits to (3) new boilers.
- Provide factory startup; assist during startup and testing of both new boilers.

Exclusions

This ECM is designed to upgrade only the hot water generation system and does not include any of the following:

- Structural upgrades, repairs, and/or modifications in the boiler room are excluded.
- Electrical infrastructure upgrades, repairs, and/or modifications are restricted to only what is described in the New Installation Work section.
- Piping and insulation will be replaced to the first shut-off valve for the equipment. This project does not include any other piping systems.
- Any ancillary system outside of the heating hot water system is not in scope, and thus excluded from this project.

Savings Methodology

In general, savings calculations for boiler replacement are calculated using the following methodology:

| Boiler Replacement | |
|---|---|
| E_E | $= \sum_{i=1}^{8760} (Q_i \div \eta_E)$ |
| E_P | $= \sum_{i=1}^{8760} (Q_i \div \eta_P)$ |
| E_S | $= E_E - E_P$ |
| C_S | $= E_S \times \text{FUR}$ |
| Where, | |
| E_E | = Annual energy (fuel) use of existing system |
| E_P | = Annual energy use of proposed system |
| E_S | = Annual energy savings |
| C_S | = Annual cost savings |
| Q_i | = Hourly heating demand, modeled as a linear fit of OA DBT (dry-bulb temperature), with a cut-off temperature above which there is no heating |
| η | = Combustion efficiency of heating system based on field data, manufacturer's rating or snap-shot measurements |
| FUR | = Fuel unit utility rate, determined from baseline utility rate analysis |
| Subscript "i" denotes the number of hours in a year. Subscripts "E" and "P" stand for Existing and Proposed system, respectively. | |

Maintenance

Follow manufacturers' recommendations for preventative maintenance.

Benefits

- Natural Gas savings
- Operational savings through new equipment and preventative maintenance plan

4-1 Condensing Hot Water Boiler Plant (Teaneck High School – Hot Water Header Pipe)

ECM Summary

The purpose of this ECM is to reconfigure the piping from a steam/HHW system to a dedicated HHW system. Due to the conversion of the boilers from steam to condensing hot water, the header piping in the boiler room will require replacement. The new Hot Water Header Pipe design will be configured to optimize the transfer of hot water throughout the building and integrate with current systems as required.

Facilities Recommended for this Measure

- Teaneck High School

Scope of Work

Demolition and Removal Work

- Disconnect, remove and properly dispose of hot water supply and return piping for HHW system to nearest isolation valves or as required for new installation.
- Disconnect all electric, controls, piping, water lines, pressure reliefs and drains.
- Remove all demolished materials from premises and dispose of in accordance with local regulations.

New Installation Work:

Proposed are the following:

- Furnish & install newly design Hot Water Header system as approved design
- Details of installation to include the following:
 - F&I all correctly sized piping, valves, actuators, for the system
 - F&I new drains, pressure reliefs piped to floor drains, water supply, etc.
 - F&I new 2” fiberglass insulation on all new and existing hot water supply and return piping “that has no insulation”.
 - F&I proper pipe suspensions for all piping.
 - F&I pipe identification and tags for all pipe and valves.
 - Re-connect existing line voltage electrical circuits to new actuators.
 - Provide startup; assist during startup and testing of both new header system.

Exclusions

- Any ancillary system outside of the heating hot water system is not in scope, and thus excluded from this project.

Savings Methodology

N/A

Maintenance

Periodically the equipment should be checked to ensure proper operation.

Benefits

Natural Gas Savings

4-2 Replace Domestic Hot Water Tank at Benjamin Franklin Middle School

ECM Summary

The existing domestic water heaters at some facilities are nearing the end of their useful life. As existing domestic hot water tanks age, they typically experience a loss in efficiency due to fouling and scaling on the internal heat exchange components, as well as an increase in maintenance costs. This measure will include replacing the existing unit with a new high-efficiency domestic water tank.

The existing domestic hot water heaters are standard efficiency models that operate at a nameplate value of around 80% thermal efficiency. This measure will include the installation of new hot water heater tank to replace the aging, lower efficiency one. New condensing water heaters are available that operate at efficiencies up to 97%.

Facilities Recommended for this Measure

- Benjamin Franklin Middle School

Scope of Work

ESG proposes to replace existing AO Smith vented gas DHW heater and replace with new Lochinvar condensing gas water heater and new insulated storage tank. Existing indirect water heater tank will be removed.

Demolition and Removal Work

- Shut down, isolate existing indirect domestic hot water storage tank and disconnect to be removed.
- Disconnect and remove existing AO Smith 100 Gallon vented gas hot water heater, flue pipe and piping.
- Remove all demolished materials from premises and dispose of in accordance with local regulations.

New Installation Work:

- Furnish & install (F&I) (1) Lochinvar ARMOR Model AWN200PM (96% Thermal Efficiency, 5:1 Turndown, 232 GPM Recovery @ 100-degree rise) high-efficiency condensing water heater set on new concrete housekeeping pad.
- F&I Qty. (1) Lochinvar Model RGA-200 (200 Gallon) insulated DHW storage tank.
- F&I Qty. (1) TACO Model PAX30-150 expansion tank.
- F&I new copper pipe, fittings, valves and insulation to reconnect existing hot water piping system to new water heater, storage tank and expansion tank.
- F&I new mixing valve.
- F&I new 3" PVC combustion air intake and flue exhaust piping to exterior of building as per manufacturer recommendations.
- F&I condensate neutralization kit and drain piping to nearby floor drain.
- F&I pipe supports, hangers and brackets as required.
- Reconnect gas piping to new water heater.
- All connections to be leak tested.
- Provide start-up with written combustion report.
- (5) Year Manufacturer Warranty on Furnace Heat Exchanger
- All existing H&C water piping, supply pumps and check valves to remain.

Teaneck Public Schools Energy Savings Plan

Savings Methodology

| Savings Calculation Methodology | | |
|---------------------------------|---|--|
| Existing DHWH Efficiency | = | Existing Heat Production/ Existing Fuel Input |
| Proposed DHWH Efficiency | = | Proposed Heat Production/ Proposed Fuel Input |
| Energy Savings | = | Heating Production (Proposed Efficiency – Existing Efficiency) |

Maintenance

Periodically the equipment should be checked to ensure proper operation.

Benefits

- Natural gas savings

4-3 Replace Steam Traps

ECM Summary

Mechanical traps are prone to failure as they age, resulting in large steam losses and requiring substantial maintenance. Steam traps separate the steam system from the condensate system. Traditional steam traps can fail in the open or closed position. When a steam trap fails in the open or leaking-by position, some or all of the energy that was added at the boiler is lost into the condensate return system. The energy contained in steam is only utilized when it condenses in a heat exchanger (radiator, convactor, hot water heater, AHU coil, etc.) and releases its latent heat to the process. It is at this point the steam trap should allow this condensate into the condensate return system to return to the boiler. As mentioned above, a leaking trap still allows steam to flow through the heat exchange device it serves and will typically not affect its heating capacity. For this reason, leaking traps are rarely discovered without performing specific tests on the trap. Conversely, a steam trap that fails in the closed position does not allow the condensate to enter the condensate return system. As a result, condensate backs up into the heat exchange device it serves, thereby first reducing, then eliminating, its heating capacity. Plugged traps are often identified through “cold calls” and repaired. Replacing or repairing failed traps will improve the efficiency of the steam distribution system and save energy.

Facilities Recommended for this Measure

- Bryant Elementary School
- Hawthorne Elementary School
- Lowell Elementary School
- Whittier Elementary School

Scope of Work

- All mechanical traps identified in the steam trap audit will be replaced with new traps
- In many instances it was difficult to confirm size, make and model of the various thermostatic traps inside radiator and convactor enclosures due to the cover itself and accumulated dust and debris. This information should be confirmed before ordering any model specific parts.

| Proposed Trap Replacements by School | |
|---|--------------|
| Building | Traps |
| Bryant Elementary School | 128 |
| Hawthorne Elementary School | 87 |
| Lowell Elementary School | 80 |
| Whitter Elementary School | 119 |
| Total Steam trap Replacements | 414 |

Detailed drawings of the trap locations for each building is provided in Appendix 4.

Savings Methodology

Savings are calculated using the following methodology:

Steam trap losses depend on the steam pressure and temperature, the type of trap, orifice size, and the level of leakage through the failed trap. Steam losses are calculated based on the amount of steam lost through the trap. Failed closed or “plugged” traps are unique in that there is no steam lost through the trap itself. Steam traps are important in the steam system to remove the condensate from the system. If the condensate is not removed from the steam system, the system loses efficiency. In some cases, a steam trap that is failed closed will cause an excessive buildup of condensate and could cause a blockage of steam flow.

Steam trap losses for leaking traps are calculated using the following modified Napier formula:

| Savings Calculation Methodology | | |
|---------------------------------|---|---|
| Q, Heat Loss (lb/hr) | = | $24.24 * D^2 * (P+14.7) * \text{orifice factor} * \text{app factor} * \text{loss factor}$ |
| Where, D | = | orifice diameter (inches) |
| P | = | Gauge Pressure (psig) |
| Orifice Factor | = | 0.66 (orifice reduction due to presence of condensate) |
| App Factor | = | application factor (1 if drip leg, 0.92 if coil or other valved application) |
| Loss Factor | = | 1.0 for blowing by, 0.3 for leaking |

Maintenance

Periodically the equipment should be checked to ensure proper operation.

Benefits

- Natural gas savings

5-3 Refurbish Cooling Tower

ECM Summary

As cooling towers age, their efficiency decreases due to dirt, corrosion and scale impairing heat transfer. Leaks and evaporative losses cause the cooling tower to use more water and the cooling energy associated with it. ESG proposes to coat the cooling tower to provide a flexible barrier to seal all of the seams for the cooling tower.

Additionally, variable frequency drives (VFDs) are used to control the fan speed of cooling towers in correlation with the outside air temperature. This allows for the optimal efficiency of cooling tower water and saves electric energy. ESG proposes to repair/recommission the current non-functioning VFDs installed on the cooling tower fan.

Facilities Recommended for this Measure

- Teaneck High School

Scope of Work

Cooling Tower Coating

- Remove and save fill.
- Clean the exterior and interior of the cooling tower.
- Sandblast/grind pan to remove any scale.
- Coat entire pan with polyurea to stop leak and protect from future leaks.
- Re-install original fill. Any material that is damaged during process will be replaced with new.

VFD Repair/Recommission

- Replace damaged VFD cabinet.
- Recommission current drives and integrate onto Building Management System.

Savings Methodology

| | |
|--|--|
| Motor (kW) = | $(\text{Motor Horsepower} \times 0.746 \text{ (kW/HP)} \times \text{Load Factor}) = \text{or} =$ $(\text{Motor Amperage} \times \text{Volts} \times 1.732 \times \text{Power Factor}) / 1000$ |
| Speed Ratio Correction Factor = | $((\text{New RPM})/(\text{Existing RPM}))^3$ |
| Existing Energy Use (kWh)= | $(\text{Existing kW} / \text{Existing Efficiency}) \times \text{Hours of Use}$ |
| Existing Demand Use (kW) = | $(\text{Existing kW} / \text{Existing Efficiency}) \times \text{Peak Load Months} \times$ $\text{Utilization factor}$ |
| New Energy Use (kWh) = | $(\text{New kW} / \text{New Efficiency}) \times \text{Hours of Use} \times \text{Speed Ratio}$ Correction Factor |
| New Demand Use (kW) = | $(\text{New kW} / \text{New Efficiency}) \times \text{Peak Load Months} \times \text{Utilization}$ $\text{factor} \times \text{Speed Ratio Correction Factor}$ |
| Total Savings (kWh, kW) = | $(\text{kWh existing} - \text{kWh new}) \times \$/\text{kWh} + (\text{kW existing} - \text{kW new}) \times$ $\$/\text{kW}$ |

Teaneck Public Schools Energy Savings Plan

Maintenance

Periodically the equipment should be checked to ensure proper operation.

Benefits

- Maximizes fan energy efficiency
- Lower operating cost
- Electric cost savings

5-4 Unit Ventilator Replacement at Teaneck High School (Second and Third Floor)

ECM Summary

Unit Ventilators (UVs) throughout Teaneck Public School District vary based on age and condition. Replacing aged unit ventilator units at Teaneck High School will reduce the operating and maintenance costs of these systems. Motor efficiency, heating and outdoor air damper efficiency of unit ventilators will improve with the installed units. ESG has identified a majority of the units as the prime candidates for replacement.

Facilities Recommended for this Measure

- Teaneck High School

Scope of Work

Replace (74) seventy-four existing unit ventilators at the Teaneck High School. ESG recommends replacing (29) twenty nine units on the second floor and (45) forty five units on the third floor of the high school

Note the total count of unit ventilators at the high school is 115, however, at least ten of these units were chosen to be removed from the scope of work by ESG and Teaneck, for the following reasons:

- Room 218 -1 (new and no need to replace)
- Room 222 -1 (new and no need to replace)
- Room 226 -1 (new and no need to replace)
- Room 230 -1 (new and no need to replace)
- Room 234 -1 (new and no need to replace)
- Room 236 -1 (new and no need to replace)
- Room 227 -1 (contains 3 UVs but only 2 are needed)
- Room 214 -1 (contains 3 UVs but only 2 are needed)
- Room 216 -1 (contains 2 UVs but only 1 is needed)

Demolition and Removal Work

- Remove (74) seventy-four Unit Vent Systems inclusive of cabinet, filler pieces and false back. Existing wall sleeve and outside grille is to remain.
- Disconnect and make safe electrical, plumbing (Hot water, steam, etc.) and controls and prepare for new work
- Remove piping from unit ventilator to point of isolation ball valve located at the branch take-off for each unit's supply and return. If applicable, disconnect existing condensate piping and prepare for connection to new equipment.
- Provide rigging/equipment to safely remove/install overhead located Unit Ventilators.
- Remove all demolished materials from premises and dispose of in accordance with local regulations.

Teaneck Public Schools Energy Savings Plan

New Installation Work:

Proposed are the following:

- F&I (74) seventy-four **Carrier** Model (or approved equal) Unit Ventilators each with high-efficiency EC motor, DDC-ready, Dual temp Coils, Cold Weather Damper Assembly, 208V/1PH, 1" Filter, End Panels, 1,250 CFM Supply Air.
- Repair exterior wall as required and paint to match existing
- Install new floor tile where required – owner to select tile
- Rig new unit ventilator into the building and anchor to exterior wall
- Provide new DDC control valve
- Reconnect existing piping to new unit ventilator and reinsulate piping
- Reconnect condensate drain piping
- Relocate DDC controller and mount inside new unit ventilator
- Reconnect power and DDC wiring
- Controls Contractor is responsible for all controls; open protocol DDC Controller to integrate with building DDC Controls Upgrade project.
- Provide testing and balancing (air & water) for each new unit ventilator.

Exclusions

- Any ancillary system outside of the unit ventilator system is not in scope, and thus excluded from this project.
- Cosmetic repairs will be completed to best match the current tile/paint, complete wall/room replacement or re-painting is excluded from this project.

Savings Methodology

| | |
|--|---|
| Motor (kW) = | (Motor Horsepower x 0.746 (kW/HP) x Load Factor) = or = (Motor Amperage x Volts x 1.732 x Power Factor) / 1000 |
| Speed Ratio Correction Factor = | ((New RPM)/(Existing RPM)) ^ 3 |
| Existing Energy Use (kWh)= | (Existing kW /Existing Efficiency) x Hours of Use |
| Existing Demand Use (kW) = | (Existing kW /Existing Efficiency) x Peak Load Months x Utilization factor |
| New Energy Use (kWh) = | (New kW /New Efficiency) x Hours of Use x Speed Ratio Correction Factor |
| New Demand Use (kW) = | (New kW /New Efficiency) x Peak Load Months x Utilization factor x Speed Ratio Correction Factor |
| Total Savings (kWh, kW) = | (kWh existing - kWh new) x \$/kWh + (kW existing - kW new) x \$/kW |

Teaneck Public Schools Energy Savings Plan

Maintenance

Periodically the equipment should be checked to ensure proper operation.

Benefits

- Electric savings

5-5 Unit Ventilator Refurbishment – Teaneck High School (First Floor)

ECM Summary

Energy Systems Group proposes to refurbish the existing standard efficiency motors with high efficiency EC motors in the unit ventilators throughout the District. The advantages of replacing existing permanent split capacity (PSC) motors with electronically commutated motors (ECM) is the increase in control ability of the motor. EC Motors may be programmed to vary speed and can reach efficiencies up to 80% above standard PSC motors.

Facilities Recommended for this Measure

- Teaneck High School

Scope of Work

Concept is to refurbish unit ventilators on the first floor. Components to be replaced will include fan deck assembly (motor, fan wheels and shaft), replacement of existing pneumatic control valve with new 2-way DDC control valve as provided by controls contractor for mechanical contractor to install.

Demolition and Removal Work:

- Remove existing unit ventilator fan deck assemblies.
- The metal cabinet (shroud) of the existing Unit Ventilators will remain in place. Replacement components should fit within the allowed space of the existing metal cabinet.
- Components to remain consistent across all Unit Vent installations and interface with building control systems.
- Disconnect electrical, plumbing (hot water, etc.) and controls.
- Remove all demolished materials from premises and dispose of in accordance with local regulations.

New Installation Work:

- F&I high-efficiency EC motor-based fan deck assemblies (including motor / shaft and fan wheels inside unit ventilators).
- Install Only Qty. (32) new two-way DDC hot water heating valves 'provided by controls contractor' to connect existing hot water heating coil inside each unit ventilators.
- Install Only DDC actuators 'provided by controls contractor' for outside air damper on each unit ventilator.
- Clean and inspect outside air damper at each unit ventilator for proper mechanical movement and operation before installing new DDC actuator.
- Clean hot water coils, clean and service inside unit ventilators.
- Provide air test of each of the Unit Vent refurbishments.

Teaneck Public Schools Energy Savings Plan

Savings Methodology

| | |
|--|---|
| Motor (kW) = | $(\text{Motor Horsepower} \times 0.746 \text{ (kW/HP)} \times \text{Load Factor}) =$ or $= (\text{Motor Amperage} \times \text{Volts} \times 1.732 \times \text{Power Factor}) / 1000$ |
| Speed Ratio Correction Factor = | $((\text{New RPM})/(\text{Existing RPM})) ^ 3$ |
| Existing Energy Use (kWh)= | $(\text{Existing kW} / \text{Existing Efficiency}) \times \text{Hours of Use}$ |
| Existing Demand Use (kW) = | $(\text{Existing kW} / \text{Existing Efficiency}) \times \text{Peak Load Months} \times$ $\text{Utilization factor}$ |
| New Energy Use (kWh) = | $(\text{New kW} / \text{New Efficiency}) \times \text{Hours of Use} \times \text{Speed Ratio}$ Correction Factor |
| New Demand Use (kW) = | $(\text{New kW} / \text{New Efficiency}) \times \text{Peak Load Months} \times \text{Utilization}$ $\text{factor} \times \text{Speed Ratio Correction Factor}$ |
| Total Savings (kWh, kW) = | $(\text{kWh existing} - \text{kWh new}) \times \$/\text{kWh} + (\text{kW existing} - \text{kW new})$ $\times \$/\text{kW}$ |

Maintenance

Periodically the equipment should be checked to ensure proper operation.

Benefits

- Reduced energy consumption
- Improve system performance

6-1 Upgrade Building Management System

ECM Summary

This ECM includes modernization of the District's DDC control system for the HVAC equipment. With the communication between the control devices and the new updated digital interface/software, the facility manager will be able to take advantage of scheduling for occupied and unoccupied periods based on the actual occupancy of each space in the facility. The DDC system will also aid in the response time to service / maintenance issues when the facility is not under normal maintenance supervision, i.e. after-hours. To achieve this level of control, ESG, with the help of Teaneck Staff and outside controls experts worked together to evaluate the existing system and identify deficiencies.

Facilities Recommended for this Measure

- Benjamin Franklin Middle School
- Bryant Elementary School
- Whittier Elementary School
- Hawthorne Elementary School
- Lowell Elementary School
- Teaneck High School
- Thomas Jefferson Middle School

Scope of Work

Level 1 –

OBJECTIVE: Update the software and develop a good base and starting point for the following recommended measures.

- A. NEW SOFTWARE PACKAGE – install latest and greatest ALC software for multiple users.
- B. Provide and install Premium multiuser Version 7.0 of WebCTRL w/advanced reporting onto the Teaneck BOE server
- C. Create new Graphics with updated display information

Exclusion: additional storage for trend data will be quantified and carried on the existing co-op contract not the ESIP project.

Benjamin Franklin M.S.

1. Add OA sensor readings to all graphics
2. Basement floor plan – add thermographic areas and picks for basement equipment
3. Basement dressing rooms – update reheat coil graphic
4. Basement – remove heat exchanger graphic and program from database
5. Basement – update graphic for corridors A, B, C, D & F MAU and corridors C & E MAU
6. First floor – add thermographic area and pick for the garage on the first floor plan
7. First floor – update 19 UV graphics
8. First floor – update graphics for common locker room MAU and girl's locker room AHU
9. First floor – update graphics for boy's gym AHU and girl's gym AHU
10. Second floor – update 21 UV graphics
11. Second floor - update graphics for main office AHU
12. Second floor - update graphics for kitchen AHU
13. Second floor - update graphics for cafeteria AHU
14. Second floor - update graphics for rehearsal AHU

Teaneck Public Schools Energy Savings Plan

15. Second floor - update graphics for foyer AHU
16. Second floor - update 11 UV graphics
17. Third floor – update graphics for auditorium RTU and add in CO2 sensor

Bryant E.S.

1. Basement – add second boiler and data for both boilers to graphics
2. Basement – add graphics for gas sub meter
3. Basement – create graphics for boiler interface
4. 1st floor – update graphic for EF-34
5. Roof – add picks for rooftop equipment to roof graphics
6. Add graphic for outside air conditions
7. Add picks for building levels to floorplan

Hawthorne E.S.

1. Basement – add equipment picks to basement graphics
2. Basement – add graphic for gas sub meter
3. Basement – create graphic for boiler interface panel
4. Basement - update graphic for EF-38
5. Roof – Add picks for rooftop equipment to roof graphics
6. Add graphic for outside air conditions
7. Roof - update graphic for EF-6A and EF-6B

Lowell Elementary School

1. Basement – add equipment picks to basement graphic
2. Basement – add graphic for gas sub meter
3. Basement – create graphic for boiler interface panel
4. Basement – add second boiler and data for both boilers to the pumps and heat exchanger graphic
5. First floor – update graphic for AHU-131
6. First floor – update graphic for AHU-114A auditorium
7. First floor – update graphic for AHU-114B
8. First floor – create graphic for EF-110 and EF-115
9. Roof – Correct picks for rooftop equipment on roof graphic
10. Add graphic for outside air conditions
11. Roof – update graphic for rooftop EFs

Thomas Jefferson M.S.

1. Add OA humidity sensor readings to all graphics
2. Map correct OA temperature reading to equipment graphics
3. Ground floorplan – add thermographic areas and picks for ground floor equipment
4. Ground floor – create graphic to show Jefferson HW system boilers and pumps
5. Ground floor – correct link to Jefferson HW system overview
6. Ground floor – create graphic for gas sub meter
7. Ground floor – remove heat exchanger graphic and program from database
8. Ground floor – update 6 UV graphics
9. Ground floor – create graphic for EF-17A, EF-4 and EF-6
10. First floor North – update 12 UV graphics
11. First floor North – update graphic for kitchen AHU
12. First floor North – update graphic for cafeteria AHU
13. First floor North – update graphic for girls lock room AHU
14. First floor North – add freezestat reset button to graphic for Gym AHU-2 and AHU-3
15. First floor North – update graphic for girls locker room AHU
16. First floor South – update 21 UV graphics
17. Second floor South – update 22 UV graphics
18. Auditorium – update graphic for RTU

Whittier E.S.

1. Basement – add graphics for teacher's lounge RAD-4A and 4B
2. Basement – add graphics for room 9 RAD-9B
3. Basement – add graphic for gas sub meter
4. Basement – create graphics for boiler interface
5. Basement – add second boiler and data for both boilers to the pumps and heat exchanger graphic
6. First floor - create graphic for air-cooled chiller
7. First floor - create graphic for dual temp isolation valves
8. First floor - create graphic for room 129 RAD
9. First floor - create graphic for room 102 RAD
10. First floor - create graphic for EF-10 south
11. First floor - create graphic for EF-13 and EF-14
12. Second floor – create graphic for FT-13 and EF-5
13. Second floor – create graphic for EF-1, 2 and EF-3
14. Second floor – create graphic for RADE-E
15. Second floor – create graphic for RADE-226, PR EF-1 and PR EF-2
16. Second floor – create graphic for EF-10 north
17. Roof – correct picks for rooftop equipment on roof graphic
18. Add graphic for outside air conditions

Teaneck High School

1. Add OA sensor readings to all graphics
2. Basement – add graphic for mechanical room exhaust systems
3. Basement – remove graphic and programming hot water plant gym heat exchanger
4. Basement – add graphic for chilled water plant Bacharach refrigerant Monitor

Teaneck Public Schools Energy Savings Plan

Level 2 –

OBJECTIVE: Once the new software is installed and the graphics have been created, make sure the end points are communicating and controlling the end use devices correctly by the following recommended measures:

C. Map the system to the end use devices through an Operational Verification and HVAC Improvement

- Benjamin Franklin Middle School
- Bryant Elementary School
- Whittier Elementary School
- Hawthorne Elementary School
- Lowell Elementary School
- Teaneck High School
- Thomas Jefferson Middle School

process in the following schools:

D. Install 4 new boiler room interface control boards to replace existing Bradley Scochetti. (2 Middle

- Bryant Elementary School
- Whittier Elementary School
- Lowell Elementary School
- Hawthorne Elementary School

schools are Aerco and not required. 1 HS will be replaced with new Aerco boilers and not required)

E. Hook up all exhaust fans in all schools. Identify how many are not physically connected and provide a price to get them on the system and working.

- Benjamin Franklin M.S. – All Exhaust Fans on ALC System
- Bryant E.S – 4 Exhaust Fans
- Hawthorn E.S. – 4 Exhaust Fans
- Lowell Elementary School – 5 Exhaust Fans
- Thomas Jefferson M.S. – All Exhaust Fans on ALC System
- Whittier E.S. – 5 Exhaust Fans
- Teaneck High School – 14 Exhaust Fans

F. Carry an allowance for parts on a per school basis to fix potential hardware problems (valves, actuators, bad EP boards, thermostats, etc.)

- Benjamin Franklin M.S. – 6 rooms
- Bryant E.S – 4 rooms
- Hawthorn E.S. – 4 rooms
- Lowell Elementary School – 4 rooms
- Thomas Jefferson M.S. – 6 rooms
- Whittier E.S. – 4 rooms
- Teaneck High School – 0 rooms

Elementary schools = 4 rooms/bldg.

Middle Schools = 6 rooms/bldg.

High School = 0 – will be rectified by the replacement of unit ventilators and refurbishment ECMs.

Teaneck Public Schools Energy Savings Plan

Level 3 -

OBJECTIVE: Now that the system has been created and everything is talking correctly. Let's implement a schedule to achieve energy savings by the following recommended measures:

- Benjamin Franklin Middle School
- Bryant Elementary School
- Whittier Elementary School
- Hawthorne Elementary School
- Lowell Elementary School
- Teaneck High School
- Thomas Jefferson Middle School

G. Create a schedule for each piece of equipment in the following schools:

H. after 1 month revisit schedule and tune system and again after 3 months revisit schedule and tune system.

Level 4 -

OBJECTIVE: Get the cooling tower Fans / VFDs communicating and working correctly by the following recommended measures:

I. Programming, Hardware – box and displays, Installation.

- I. Replace NEMA 4 rated VFDs enclosure, replace both VFD displays, confirm communications and reprogram control of both VFDs and condenser water bypass valve.

Level 5 -

OBJECTIVE: Boiler room upgrade by the following recommended measures:

K. Install Seven Control valves, (3) new boilers, (1) air cooled chiller, Controls to monitor/talk to VFDs on HW and condenser water pumps.

- K. Boiler room upgrade. Isolate and disconnect existing controls and wiring for all equipment being removed. Provide two (2) 8" electronic control valves, three (3) 6" electronic control valves and two (2) 4" electronic control valves. Provide, install, program, startup and commission a complete DDC system to monitor and control three (3) new Aerco boilers, two (2) new dual temperature water pump VFDs, two (2) new hot water pump VFDs, two (2) new condenser water VFDs, seven (7) electronic control valves along with all required temperature and pressure sensors. Provide one (1) Modbus interface router, front end equipment graphics, trends and alarms. Provide one (1) day of training to owner.

Savings Methodology

See savings calculations provided in Appendix.

Maintenance

Update software as needed.

Benefits

- Electrical energy savings
- Natural gas savings
- Continuous monitoring and HVAC scheduling
- Maintaining occupancy comfort levels
- Reduce operational cost

6-2 Operational Verification and HVAC Improvements

ECM Summary

Through extensive field investigations and discussions with Teaneck staff it was discovered that the existing BMS system has a corrupted database and is not thoroughly connected or controlled. ESG believes that as a result of the implementation of the "Operational Verification and HVAC Improvements" ECM, there will be a significant amount of savings that will not be easily quantifiable or verifiable. Teaneck and ESG, agree that a 5% savings from electrical and thermal systems is a conservative estimate of energy savings as a result of the implementation of Operational Verification and the HVAC improvements listed below.

Facilities Recommended for this Measure

- Benjamin Franklin Middle School
- Bryant Elementary School
- Whittier Elementary School
- Hawthorne Elementary School
- Lowell Elementary School
- Teaneck High School
- Thomas Jefferson Middle School

Scope of Work

The following approach was developed in tiers to accomplish a complete and fully functioning control system.

Level 1 –

- A. NEW SOFTWARE PACKAGE – install latest and greatest ALC software for multiple users.
- B. Create new Graphics with updated display information.

Level 2 –

- C. Map the system to the end use devices through an Operational Verification and HVAC Improvement process.

Level 3 -

- G. Create a schedule for each piece of equipment
- H. after 1 month revisit schedule and tune system and again after 3 months revisit schedule and tune system.

Savings Methodology

From the implementation of the Level 1, 2 and 3 work, Teaneck PS and ESG agree to a stipulated savings for this work equaling 5% of total cooling and total heating energy.

| Savings Calculation Method | | |
|----------------------------|---|---|
| Cooling Savings (kWh) | = | Stipulated Savings % * Total Annual Electrical Usage |
| Heating Savings (Therm) | = | Stipulated Savings % * Total Annual Natural Gas Usage |

Teaneck Public Schools Energy Savings Plan

Maintenance

Update BMS software as needed.

Benefits

- Electrical energy savings
- Natural gas savings
- Continuous monitoring and HVAC scheduling
- Maintaining occupancy comfort levels
- Reduce operational cost

7-1 Building Envelope Weatherization

ECM Summary

Infiltration drives energy costs higher by allowing unconditioned outside air to enter the building, thus adding to the building load and causing additional unnecessary heating and cooling loads. Teaneck School District buildings were surveyed in order to identify potential improvements for outside air infiltration reduction. The main observations are listed below:

- Most entrance doors need weather stripping, sweeps or the closure or strike plate adjusted;
- Sealant is recommended around the perimeter of several windows;
- Numerous penetrations were observed that need to be sealed.

These deficiencies mostly reflect the skin of the buildings, which either have existed since original construction of the building, were added during some retrofit periods, or were caused by deterioration.

Detailed findings from the audit are located in the appendix.

Facilities Recommended for this Measure

- Benjamin Franklin Middle School
- Bryant Elementary School
- Whittier Elementary School
- Hawthorne Elementary School
- Lowell Elementary School
- Teaneck High School
- Thomas Jefferson Middle School

Scope of Work

A building envelope audit was performed for the entire district. The results of the audit were the identification of several areas of envelope deficiency. The deficient areas were tabulated and their savings potential calculated.

Building Envelope Scope drawings and recommendations are listed in the Appendices.

Savings Methodology

The physics of air leakage guide the requirements for the design of an effective air leakage control retrofit project.

- Big Holes = Area
Sealing big holes and/or a lot of small holes generates savings.
- Big Pressure Differentials = ΔP
Sealing surfaces that have the highest pressures acting on them generates savings: at the top and bottom of the building (stack pressure), spaces that are pressurized or depressurized (mechanical pressure) and surfaces that are most exposed to the elements (wind pressure).
- Big Temperature Differentials = ΔT or HDD
Sealing interior-to-exterior air leakage pathways generates savings. Isolating interior spaces (or compartmentalizing) is effective only across interior spaces with very different interior environment needs.

Teaneck Public Schools Energy Savings Plan

Thermal Upgrade

ESG uses standard heat loss calculations (U, A, ΔT) to estimate savings from thermal barrier improvements.

As with air leakage, the physics of thermal heat loss guide the requirements for the design of an effective energy saving insulation upgrade project.

- Weak Existing Insulation Values: U-Value
Insulating surfaces with the weakest existing insulation values generates savings.
- Big Surface Areas: Area
Insulating large surface areas generates savings.
- Big Temperature Differentials: ΔT or Degree Days

INFILTRATION/ EXFILTRATION SAVINGS CALCULATION METHODOLOGY

Cooling Savings

| | | | | | | | | |
|-------------------------------------|---|---------------------|---|------------------|---|------------------------------------|---|---------------------------|
| | | Flow Factor | | $(\Delta P)^n$ | | A | | CFM Reduction |
| 1) Q | = | Flow Factor | x | Wind Pressure | x | Aggregate Air Leakage Pathway Hole | = | Cubic Feet / Minute (CFM) |
| | | Total Heat Constant | | CFM Reduction | | Enthalpy | | Tons |
| 2) Tons | = | 4.5 | x | CFM Reduction | x | Enthalpy Value | = | Tons |
| | | | | BTU Hour per Ton | | | | |
| 3) kWh Savings | = | Tons | | kW per Ton | | Cooling Hours | | kWh |
| | | Tons | x | 1.2 | x | Cooling Hours for Location | = | kWh |
| 4) Savings | = | kWh | | Fuel Cost/kWh | | | | |
| | | kWh Savings | x | Fuel Cost in \$ | = | Savings in Dollars | | |
| 5) Savings from Air Leakage Control | | | | | | | = | Savings in Dollars |
| 6) Project Investment | | | | | | | = | Investment in Dollars |
| 7) Simple Payback | | | | | | | = | Investment / Savings |

Teaneck Public Schools Energy Savings Plan

Insulating interior-to-exterior surfaces (attic surfaces are included in this category) generates savings. Isolating interior surfaces (or compartmentalizing) is effective only across interior spaces with very different interior environment needs.

Maintenance

After the building envelopes have been improved, operations and maintenance should be reduced, due to improved space conditions and lower humidity during the cooling season. The maintenance staff should maintain the newly installed equipment per manufacturers' recommendations. The manufacturer specification sheets will be provided for exact maintenance requirements.

Benefits

- Electrical energy savings
- Fuel energy savings

7-3 Repair Missing Pipe Insulation

ECM Summary

Non-insulated pipelines and associated valves and fittings carrying thermal fluids because heat loss where not intended and result in excess fuel consumption, as well as discomfort in occupied areas. Valves and fittings without insulation were observed throughout the buildings and installation of new insulation is recommended. Installation of the proper amount of insulation will not only conserve energy but will also improve safety by reducing the chance for burns on hot piping or slipping due to condensate on a pipe. This ECM would insulate bare and poorly insulated heating hot water piping and failed heating hot water piping insulation in the boiler room.

Findings

- Pipe Insulation – un-insulated pipes in the steam, condensate, and heating and hot water systems are leading to unnecessary distribution losses and wasted energy.
- Valve & Fitting Insulation – valves and fittings are difficult components of a mechanical system to insulate and as a result are frequently left un-insulated. These un-insulated or poorly insulated components have the same temperature fluids passing through them as the pipes that are more likely to be insulated; un-insulated components of the distribution system lead to unnecessary distribution losses and wasted energy.
- Tank Insulation – tanks are difficult components of a mechanical system to insulate and as a result are frequently left un-insulated. Un-insulated or poorly insulated tanks or equipment have the same temperature fluids passing through them as the pipes that are more likely to be insulated; un-insulated components of the distribution system lead to unnecessary distribution losses and wasted energy.

Facilities Recommended for this Measure

- Teaneck High School
- Hawthorne Elementary School
- Whittier Elementary School
- Lowell Elementary School
- Thomas Jefferson Middle School
- Bryant Elementary School
- Benjamin Franklin Middle School

Scope of Work

Detailed information, quantities and types, can be found in the appendix.

Note: All insulation thickness shall be confirmed to be in accordance with the New Jersey Energy Conservation Code, **ASHRAE 90.1 2016**. Contract shall be responsible for verification of these thicknesses.

Savings Methodology

Mechanical Insulation Savings Calculations

This section describes our methodology for calculating energy savings. We use standard heat transfer methods to compute heat loss from bare and insulated mechanical systems (piping, valves, fittings, tanks and ductwork). The difference in heat loss is the energy savings, as follows:

$$\text{Energy Savings} = [\text{Existing Heat Loss}] - [\text{Insulated Heat Loss}]$$

Methodology

We use standard heat transfer methods to compute radiation, convection, and conduction heat loss from

(Alternatively, gain to, for cold systems) bare and insulated systems. Key parameters that affect the heat transfer rate include: temperature of fluid (e.g. steam, hot water, chilled water, etc.); surface temperature of the component (e.g. pipe, fitting, tank, ductwork); temperature of environment; emissivity of surface; average wind speed where applicable; percentage of existing component covered with insulation; and condition of existing insulation, where applicable.

Energy Usage

Existing and proposed energy use are computed as follows:

Pipes & Fittings

$$\text{Heat Loss (Btu/h)} = (\text{Heat Loss / lin.ft. bare pipe}) * (\text{lin.ft. of pipe}) * [1 - (\%insulated)] + (\text{Heat Loss / lin.ft. insulated pipe}) * (\text{lin.ft. of pipe}) * (\%insulated)$$

$$\text{Fuel Loss (MMBTU/yr)} = (\text{Heat Loss Btu/h}) * (\text{heating hrs/year}) \div (\text{efficiency})$$

$$\text{Electric Loss (kWh/yr)} = (\text{Heat Loss Btu/h}) * (\text{cooling hrs/year}) \div (12,000 \text{ Btu/ton-hr}) * (\text{cooling kW/ton})$$

Tanks, Plates, & Ductwork

Existing and proposed heat loss for tanks, plates, and ductwork are calculated as follows:

$$\text{Heat Loss (Btu/h)} = (\text{Heat Loss / sq.ft.}) * (\text{sq.ft. of component}) * (\text{qty}) * [1 - (\%insulated)] + (\text{Heat Loss / sq.ft. insulated}) * (\text{qty}) * (\text{sq.ft. of component}) * (\%insulated)$$

$$\text{Fuel Loss (MMBTU/yr)} = (\text{Heat Loss Btu/h}) * (\text{heating hrs/year}) \div (\text{efficiency})$$

$$\text{Electric Loss (kWh/yr)} = (\text{Heat Loss Btu/h}) * (\text{cooling hrs/year}) \div (12,000 \text{ Btu/ton-hr}) * (\text{cooling kW/ton})$$

Energy Savings

Energy savings are the difference between existing and proposed heat loss:

$$\text{Fuel Savings (MMBTU/yr)} = (\text{Existing Fuel Loss}) - (\text{Proposed Fuel Loss})$$

$$\text{Electric Savings (MMBTU/yr)} = (\text{Existing Electric Loss}) - (\text{Proposed Electric Loss})$$

$$\text{Cost Savings (\$/yr)} = (\text{Fuel Savings MMBTU/yr}) * (\text{Fuel Rate \$/MMBTU}) + (\text{Electric Savings kWh/yr}) * (\text{Electric Rate \$/kWh})$$

Heat Transfer: Bare Systems

Bare systems are subject to convection and radiation heat transfer. We ignore conductive heat transfer through the pipe/fitting material (e.g. steel, copper, PVC etc.) as this is negligible as compared to heat transfer through insulation and air convection.

Pipes & Fittings

This section describes the heat transfer calculations for pipes and fittings for indoor systems subject to natural convection (no wind). The calculations for outdoor systems subject to forced convection (wind) are similar except that the formulas are more complicated. These methods are presented following this section.

For fittings (valves, elbows, strainers, etc.), we estimate heat loss based on equivalent length of straight pipe, which is the ratio of the area of the fitting to the area of 1 linear foot of pipe of the same size (fitting equivalent length = Area of fitting, ft² / Area of pipe of equivalent diameter, ft²).

$$q_{pipe} = \frac{2 * \pi * \Delta T}{h * (D_{outer}/2)}$$

Where:

q_{pipe} = heat loss per linear foot = Btu/h/lin.ft.

h = total convective heat transfer factor = $h_{convection} + h_{radiation}$

$$h_{convection} = 0.213 * \left(\frac{\Delta T}{D}\right)^{\frac{1}{4}} \quad \text{[ASHRAE 2005, Ch. 3, Eq. T10.16]}$$

$\Delta T = T_{surface} - T_{air}$

$\Delta T = T_{surface} - T_{air}$

D = Outer diameter

$$h_{radiation} = \epsilon * \sigma * \frac{(T_{surface}^4 - T_{air}^4)}{(T_{surface} - T_{air})}$$

ϵ = emissivity of surface

σ = Stefan-Boltzmann constant = 0.1714×10^{-8} Btu / (hr-ft²-°R⁴)

$T_{surface}$ = Temperature of surface

T_{air} = Average ambient air temperature

Heat Transfer: Insulated Systems

Insulated systems are subject to convection, radiation, and conductive heat transfer. We ignore conductive heat transfer through the pipe/fitting material (e.g. steel, copper, PVC etc.) as this is negligible when compared to heat transfer through insulation and air convection.

$$q_{pipe} = \frac{2 * \pi * \Delta T}{\frac{\ln(D_{outer}/D_{inner})}{k} + \frac{1}{h * (D_{outer}/2)}}$$

Where:

q_{pipe} = heat loss per linear foot = Btu/h/lin.ft.

$$h_{convection} = 0.213 * \left(\frac{\Delta T}{D}\right)^{\frac{1}{4}} \quad \text{[ASHR]}$$

$\Delta T = T_{surface} - T_{air}$

$\Delta T = T_{surface} - T_{air}$

D = Outer diameter

$$h_{radiation} = \epsilon * \sigma * \frac{(T_{surface}^4 - T_{air}^4)}{(T_{surface} - T_{air})}$$

ϵ = emissivity of surface

σ = Stefan-Boltzmann constant = 0.1714×10^{-8} Btu / (hr-ft²-°R⁴)

$T_{surface}$ = Temperature of surface

T_{air} = Average ambient air temperature

L = Pipe length or fitting equivalent length

Heat Transfer for Outdoor Systems

The methods for computing heat loss for outdoor systems subject to forced convection (wind) are identical to the methods for indoors systems described above except that the formulas to compute the convective heat transfer coefficient h is more complicated. These methods are described below:

Pipes & Fittings: Outdoor Systems

The convection heat transfer coefficient is:

$$h_{convection} = Nu * k / D_{outer}$$

$$Nu = \text{Nussault number} = 0.3 + \frac{0.62 * Re^{(\frac{1}{2})} * Pr^{(\frac{1}{4})}}{\left[1 + \left(\frac{0.4}{Pr}\right)^{(\frac{2}{3})}\right]^{(\frac{1}{4})}} * \left[1 + \left(\frac{Re}{282,000}\right)^{(\frac{5}{8})}\right]^{(\frac{4}{5})}$$

$$Re = \text{Reynolds number} = \frac{V * D_{outer}}{v}$$

$$Pr = \text{Prandtl number} = 0.7 \text{ (for air)}$$

v = kinematic viscosity of air

V = wind speed

D_{outer} = outer pipe diameter

Plates, Tanks, Ductwork: Outdoor Systems

The convection heat transfer coefficient for flat surfaces is estimated as follows

$$h_{convection} = Nu * k / D_{outer}$$

$$Nu = \text{Nussault number} = 0.415 * Re^{(\frac{1}{2})} * Pr^{(\frac{1}{4})}$$

$$Re = \text{Reynolds number} = \frac{V * L}{v}$$

$$Pr = \text{Prandtl number} = 0.7 \text{ (for air)}$$

v = kinematic viscosity of air

V = wind speed

L = width or diameter of component

Maintenance

The maintenance staff should maintain the newly installed equipment per manufacturers' recommendations. The manufacturer specification sheets will be provided for exact maintenance requirements.

Benefits

- Fuel energy savings

SECTION 5. MEASUREMENT AND VERIFICATION

Measurement & Verification (M&V) Methodologies

This section contains a description of the types of Measurement and Verification (M&V) methodologies that Energy Systems Group will use to guarantee the performance of this project.

They have been developed and defined by two independent authorities:

- International Performance Measurement and Verification Protocol (IPMVP)
- Federal Energy Management Program (FEMP)

There are four guarantee options that may be used to measure and verify the performance of an energy conservation measure. Each one is described below.

Option A – Retrofit Isolation: Key Parameter Measurement

Energy savings is determined by field measurement of the key parameters affecting the energy use of the system(s) to which an improvement measure was applied separate from the energy use of the rest of the facility. Measurement frequency ranges from short-term to continuous, depending on the expected variations in the measured parameter, and the length of the reporting period.

Measurement of key parameters means that those parameters not selected for field measurement will be estimated. Estimates can be based on historical data, manufacturer's specifications, or engineering judgment. Documentation of the source or justification of the estimated parameter will be described in the M&V plan in the contract. Energy savings is determined through engineering calculations of the baseline and post-retrofit energy used based on the combination of measured and estimated parameters, along with any routine adjustments.

Option B – Retrofit Isolation: All Parameter Measurement

Like Option A, energy savings is determined by field measurement of the energy use of the systems to which an improvement measure was applied separate from the energy use of the rest of the facility. However, all of the key parameters affecting energy use are measured; there are no estimated parameters used for Option B. Measurement frequency ranges from short-term to continuous, depending on the expected variations in the savings and the length of the reporting period. Energy savings is determined through engineering calculations of the baseline and post-retrofit energy used based on the measured parameters, along with any routine adjustments.

Option C – Whole Building Metering/Utility Bill Comparisons

Option C involves the use of utility meters or whole building sub-meters to assess the energy performance of a total building. Option C assesses the impact of any type of improvement measure, but not individually if more than one is applied to an energy meter. This option determines the collective savings of all improvement measures applied to the part of the facility monitored by the energy meter. In addition, since whole building meters are used, savings reported under Option C include the impact of any other change made in facility energy use (positive or negative).

Option C may be used in cases where there is a high degree of interaction between installed improvement measures or between improvement measures and the rest of the building or the isolation and measurement of individual improvement measures is difficult or too costly.

This Option is intended for projects where savings are expected to be large enough to be discernable from the random or unexplained energy variations that are normally found at the level of the whole facility meter. The larger the savings, or the smaller the unexplained variations in the baseline, the easier it will be to identify savings. In addition, the longer the period of savings analysis after installing the improvement measure, the less significant is the impact of short-term unexplained variations. Typically, savings should be more than 20% of the baseline energy use if they are to be separated from the noise in the baseline data.

Periodic inspections should be made of all equipment and operations in the facility after the improvement measure installation. These inspections will identify changes from baseline conditions or intended operations. Accounting for changes (other than those caused by the improvement measures) is the major challenge associated with Option C-particularly when savings are to be monitored for long periods.

Savings are calculated through analysis of whole facility utility meter or sub-meter data using techniques from simple comparison to regression analysis.

Option D – Calibrated Simulation

Option D involves the use of computer simulation software to predict energy use, most often in cases where baseline data does not exist. Such simulation models must be calibrated so that it predicts an energy use and demand pattern that reasonably matches actual utility consumption and demand data from either the base-year or a post-retrofit year.

Option D may be used to assess the performance of all improvement measures in a facility, akin to Option C. However, different from Option C, multiple runs of the simulation in Option D allow estimates of the savings attributable to each improvement measure within a multiple improvement measure project.

Option D may also be used to assess just the performance of individual systems within a facility, akin to Option A and B. In this case, the system's energy use must be isolated from that of the rest of the facility by appropriate meters.

Savings are calculated using energy use simulation models, calibrated with hourly or monthly utility billing data and/or end-use metering.

Selecting M&V Options for a Specific Project

The tailoring of your specific M&V option is based on the level of M&V precision required to obtain the desired accuracy level in the savings determination and is dependent on:

- The complexity of the Energy Conservation Measure
- The potential for changes in performance
- The measured savings value.

The challenge of the M&V plan is to balance three related elements:

- The cost of the M&V Plan
- Savings certainty
- The benefit of the particular conservation measure.

Savings can also be non-measured. If savings are non-measured, these savings are mutually agreed upon as achieved at substantial completion of the respective facility improvement measure and shall not be measured or monitored during the term of the performance contract. Non-measured energy savings are limited to no more than 10-15% of the overall project savings.

Teaneck Public Schools Energy Savings Plan

Recommended Performance Verification Steps

Energy Systems Group’s performance verification methods are designed to provide the facility’s administration with the level of M&V necessary to protect them from an under-performing ECM, yet have a minimal impact on the project’s financial success.

The selection of the M&V methods to be used is based on the criteria as detailed by IPMVP and Energy Systems Group’s experience with hundreds of successful performance contracts in the K-12, state, and local government sectors. Following is a table illustrating how the savings of the major energy conservation measures proposed for this project will be verified.

| ECM Description | Measurement and Verification Method - Summary | Detail of M&V Methodology |
|--|---|---|
| <p>Comprehensive LED Lighting Upgrades (including lighting occupancy sensors)</p> | <p>Option A: One-time pre and post-retrofit kW measurement. Burn hours agreed upon with school district.</p> | <p>Pre M&V: Lighting power readings will be taken on a sample of lighting fixtures. Lighting burn hours were measured through the use of light loggers.</p> <p>Post M&V: Lighting power readings will be taken on a sample of lighting fixtures. Measurements will occur once at the outset of the agreement. “Occupied” hours logged during the baseline data collection will be used as the post-installation burn hours.</p> <p>Energy Savings: Energy savings will be calculated using the actual measured wattage reduction and measured burn-hours.</p> |
| <p>Building Envelope / Weatherization Improvements</p> | <p>Option A: Existing envelope deficiencies are documented based on collected field data to provide a baseline for evaluation the effectiveness of the air barrier systems and insulation. Post-retrofit verification of improvements will be documented.</p> | <p>Pre M&V: The magnitude of the air infiltration caused by cracks and joint deficiencies determined by field surveys. Thickness of existing attic insulation will be sample measured in at least 5 locations where applicable to scope of work</p> <p>Post M&V: The areas identified for weatherization improvements will be verified to be complete through visual inspection and as-built documentation. Thickness of existing attic insulation will be sample measured in at least 5 locations where applicable to scope of work which will be used to estimate the U-value based on manufactures data or estimates.</p> <p>Energy Savings: Energy savings will be based on the ASHRAE crack method calculations. If the commissioning process reveals any variation in the as-built conditions, then savings will be adjusted.</p> |
| <p>Repair Missing Piping Insulation</p> | <p>Option A: Savings are from installing pipe insulation and insulation blankets.</p> | <p>Pre M&V: The size of the space requiring insulation installation were measured during the field audit of a sample of spaces per IPMVP protocol.</p> |

Teaneck Public Schools Energy Savings Plan

| | | |
|--|---|---|
| | | <p>Post M&V: Following installation, the size and the surface temperature of the space where the insulation is installed will be verified.</p> <p>Energy Savings: Savings are from a reduction in heat loss through uninsulated pipes, valves, and surfaces.</p> |
| Plug Load Management | <p>Option A: Savings are from the reduced operating hours of the plugged in equipment.</p> | <p>Pre M&V: Quantity of plug load devices was determined in the field survey. Nameplate data was used to determine the total kW of plugged in equipment.</p> <p>Post M&V: Once the installation is complete, the plug load control devices will be inspected to ensure proper operation. During the guarantee term, actual operating conditions will be downloaded from a sample of plug load devices to verify equipment schedules are still in place and equipment is being turned off.</p> <p>Energy Savings: Savings are from the reduced operating hours of the plugged in equipment.</p> |
| Condensing Hot Water Boiler Plant (Teaneck High School - Fan Room Upgrades) | <p>Option A: Baseline energy consumption based on collected field data and combustion efficiency of existing boilers. Post installation energy consumption based on combustion efficiency of new boilers.</p> | <p>Pre M&V: Energy Systems Group will take a combustion efficiency test to verify the efficiency of existing boilers and estimate the fuel consumption of existing boilers based on collected field data and utility bills.</p> <p>Post M&V: Energy Systems Group will take a combustion efficiency test to verify the efficiency of new boilers.</p> <p>Energy Savings: Savings for the new boilers will be determined using the base heating load and the difference in efficiencies between the existing boilers and new boilers. Total energy savings is the difference between the existing overall building heating system efficiency and the post heating system efficiency.</p> |
| Refrigeration Controls | <p>Non-Measured: Savings are from the reduced electric consumption of freezer and refrigerator.</p> | <p>Pre M&V: Manufacturer's data and operating parameters will be collected on the freezer and refrigerator.</p> <p>Post M&V: Once the installation is completed, the walk-in box control system will be inspected to ensure proper operation.</p> <p>Energy Savings: Savings are from the reduced electric consumption of freezer and refrigerator.</p> |
| Combined Heat and Power | <p>Option B: Savings are from the electric and heat provided by the cogeneration system.</p> | <p>Pre M&V: The baseline utility bills were analyzed to determine baseline heating and electric loads and the time that the cogeneration system is able to operate per year and the capacity of the cogeneration system.</p> <p>Post M&V: The electric generation output from</p> |

Teaneck Public Schools Energy Savings Plan

| | | |
|---|---|---|
| | | <p>the cogeneration system will be measured with an electric meter. The heat output from the cogeneration system will be determined by measuring the water inlet/outlet temperature and flow rate. The gas input to the cogeneration system will be measured with a gas meter. Combined, these data points will be used to verify the conversion efficiency of the cogeneration system.</p> <p>Energy Savings: Savings are from the electric and heat provided by the cogeneration system.</p> |
| Computer Power Management | <p>Option A: Pre and post data will be collected over a two to four week period before and after the power management strategies have been implemented.</p> | <p>Pre M&V: Power state on a sample of devices over sample period of time prior to implementation of power strategies. Post M&V: Power state on a sample of devices over sample period of time following implementation of power strategies.</p> <p>Energy Savings: The energy savings for each state (on/active, standby, hibernate, and off) are calculated and totalized to determine the total energy cost savings for the measure.</p> |
| Replace Steam Traps | <p>Option A: Savings are from replacing failed working steam traps and/or fixing steam trap leakage.</p> | <p>Pre M&V: Pre (baseline) field survey showing number and types of trap failures Post M&V: Post – completion of repairs to identified failed traps and verification of quantities and trap sizes.</p> <p>Energy Savings: Energy savings will be calculated using the field survey, drawings, and manufactures data, with savings coming from a reduction in steam and thermal losses from repaired or replaced leaking traps</p> |
| Upgrade Building Management System | <p>Option A: Savings are from implementing control strategies.</p> | <p>Pre M&V: Due to lack of functionality in existing HVAC Controls and the nature of work proposed in the ECMs, the following Pre M&V tasks will be performed. Accepted engineering practices / building simulations will be used to calculate energy consumption baselines. Operating parameters of the system was verified through BAS system (where applicable). Post M&V: The new HVAC Controls will be utilized to record the following items as an assurance of performance. Various control points within the building management system will be trended and/or totalized. This data will be used to verify that all control strategies are in place and functioning as intended.</p> <p>Energy Savings: Savings are from implementing control strategies.</p> |

Teaneck Public Schools Energy Savings Plan

| | | |
|---|---|---|
| <p>Install VFDs and Premium Efficiency Motor Upgrades</p> | <p>Option A: Savings are from the reduced operating hours of the plugged in equipment.</p> | <p>Pre M&V Quantity of the motors and horsepower were determined in the field survey. Nameplate data was used to determine the total KW of related equipment. Post M&V: Once the installation is complete, the VFD's will be inspected to ensure proper operation. During the guarantee term, actual operating conditions will be downloaded from the BMS to verify motors (and associated fans/pumps) are being operated at part load. Energy Savings: Savings are from the reduced kW load of the equipment at reduced speed.</p> |
| <p>Unit Ventilator Replacement (Teaneck High School)</p> | <p>Option A: Savings are from replacing the existing unit ventilators with new unit ventilators</p> | <p>Pre M&V: Manufacturer's data and operating parameters will be collected on the unit ventilators requiring replacement. Post M&V The new unit ventilators will be inspected following installation to verify proper operation. Energy Savings: Savings are from improving the efficiency by refurbishing the existing unit ventilators.</p> |
| <p>Unit Ventilator Refurbishment (Teaneck High School)</p> | <p>Option A: Savings are from refurbishing the existing unit ventilators with new components</p> | <p>Pre M&V: Manufacturer's data and operating parameters will be collected on the unit ventilators requiring refurbishment. Post M&V: The refurbished unit ventilators will be inspected following installation to verify proper operation. Energy Savings: Savings are from improving the efficiency by refurbishing the existing unit ventilators.</p> |
| <p>Low Flow Hot Water Devices</p> | <p>Non-Measured – Savings are from reduced hot water consumption.</p> | <p>Pre M&V: Manufactures rating, label information, or observed estimated field conditions Post M&V: Once the installation is completed, the new equipment will be inspected to verify if they are working properly. Energy Savings: Savings are from the reduce domestic hot water load being placed on the domestic water heater.</p> |
| <p>Fuel Use Economizers</p> | <p>Non-Measured: Savings are from the optimized on and off cycles of the burner ignition.</p> | <p>Pre M&V: Manufacturer's data and existing operating parameters will be collected on the boilers. Post M&V: The boiler controllers will be inspected following installation to verify proper operation Energy Savings: Savings are from the optimized on and off cycles of the burner ignition.</p> |
| <p>Replace Cooling in</p> | <p>Non-Measured: Savings</p> | <p>Pre M&V: Manufacturer's data and operating</p> |

Teaneck Public Schools Energy Savings Plan

| | | |
|---|--|---|
| Media Centers | are from the reduced electric consumption of split system condensing units. | parameters will be collected on the condensing units. Post M&V: Once the installation is completed, the condensing units will be inspected to ensure proper operation. Energy Savings: Savings are from the reduced electric consumption of the condensing units. |
| Replace DHW Tank (Benjamin Franklin Middle School) | Non-Measured: Baseline energy consumption based on collected field data and combustion efficiency of existing water heaters. Post installation energy consumption based on combustion efficiency of new water heaters. | Pre M&V: Manufacturer's data and operating parameters will be collected on the unit. Post M&V: Once the installation is completed, the unit will be inspected to ensure proper operation. Energy Savings: Savings for the new domestic hot water heater will be determined using the base heating load and the difference in efficiencies between the existing and new water heaters. |
| Refurbish Cooling Tower | Non-Measured: Savings are from the reduced full load operating hours of the connected equipment. | Pre M&V: The cooling tower controls are failed based on field survey and interviews and is being operated in hand at 100% speed. Post M&V: Once the installation is complete, the VFD's will be inspected to ensure proper operation. Energy Savings: Savings are from the reduced kW load of the equipment at reduced speed. |
| Operation Verification and HVAC Improvements | Non-Measured: Savings are from the reduced electric and heating fuel consumption of the HVAC systems. | Pre M&V: Existing operating parameters will be collected on the systems. Post M&V: Updated operating parameters will be collected on the systems. Energy Savings: By updating BMS programs, installing advanced software, verifying and correcting scheduling based on when the spaces are occupied, energy savings are achieved. |
| Condensing Hot Water Plant (THS - Hot Water Header Pipe) | Non-Measured | This work is required as part of the conversion of the existing boiler plant from Steam to Hot Water. |
| Construction Contingency | Non-Measured | N/A, Non-Measured |

Teaneck Public Schools Energy Savings Plan

Measurement and Verification Services

Measurement and Verification Services will be provided in association with the guarantee provided by Energy Systems Group. The guarantee will be in effect for each year that the District elects to participate in the Measurement and Verification Services. The cost of the measurement and verification services is included in the business case in the “Annual Services” column as outlined in the table below:

| Year | Annual Amount (\$/Yr) |
|-------|-----------------------|
| 1 | \$27,725 |
| Total | \$27,725 |

ESG will provide the M&V Services set forth below in connection with the Assured Performance Guarantee.

- During the Installation Period, an ESG Performance Engineer will track Measured Project Benefits. ESG will report the Measured Project Benefits achieved during the Installation Period, as well as any Non-Measured Project Benefits applicable to the Installation Period, to Customer within 60 days of the commencement of the Guarantee Term.
- Within 60 days of each anniversary of the commencement of the Guarantee Term, ESG will provide Customer with an annual report containing:
 - An executive overview of the project’s performance and Project Benefits achieved to date;
 - A summary analysis of the Measured Project Benefits accounting; and
 - Depending on the M&V Option, a detailed analysis of the Measured Project Benefits calculations.
- During the Guarantee Term, an ESG Performance Engineer will monitor the on-going performance of the Improvement Measures, as specified in this Agreement, to determine whether anticipated Measured Project Benefits are being achieved. The Performance Engineer will visit Customer regularly and assist Customer on-site or remotely, with respect to the following activities:
 - Review of information furnished by Customer from the facility management system to confirm that control strategies are in place and functioning;
 - Advise Customer’s designated personnel of any performance deficiencies based on such information;
 - Coordinate with Customer’s designated personnel to address any performance deficiencies that affect the realization of Measured Project Benefits; and
 - Inform Customer of opportunities to further enhance project performance and of opportunities for the implementation of additional Improvement Measures.
 - Track utility bills on a monthly basis to determine current utility rate costs and to identify any billing anomalies.
- For specified Improvement Measures, ESG will:
 - Conduct pre and post installation measurements required under this Agreement;
 - Confirm the building management system employs the control strategies and set points specified in this Agreement; and
 - Analyze actual as-built information and adjust the Baseline and/or Measured Project Benefits to conform to actual installation conditions (e.g., final lighting benefits calculations)

- will be determined from the as-built information to reflect the actual mix of retrofits encountered during installation).
- Confirm that the appropriate metering and data points required to track the variables associated with the applicable Improvement Measures' benefits calculation formulas are established; and
 - Set up appropriate data capture systems (e.g., trend and totalization data on the facility management system) necessary to track and report Measured Project Benefits for the applicable Improvement Measure.

SECTION 6. CUSTOMER SUPPORT

Maintenance Impacts/ On-Going Service

New pieces of equipment that are installed as part of the ESIP project will be provided with the standard manufacturer warranty. Once installation of the equipment is complete, the remaining warranty period will be transferred to Teaneck Public School District; any warranty issues will be handled directly with the equipment manufacturer rather than with Energy Systems Group.

a) ESG subcontractors will warranty the installation for a period of 12 months, beginning at substantial completion.

b) In addition, ESG will facilitate warranty related issues for a period of 12 months, beginning at substantial completion. Extended manufacture warranties beyond the 12-month installation warranty period will be facilitated by the District.

The installation of the recommended measures will reduce the amount of emergency maintenance required by the district through the installation of new equipment; however, preventative maintenance is still required in order to ensure the correct operation of the equipment for the expected lifetime. A service agreement cannot be included as part of this project per the New Jersey Local Finance Notice 2009-11. Once the scope is finalized and bids are received, Energy Systems Group will assist the District in preparing bids for any preventative service agreement that is felt necessary for the new equipment. The service agreement will cover recommended maintenance per each equipment manufacturer. Training on the proper maintenance and operation of each piece of equipment has also been included as part of the ESIP project which will allow the District to complete the majority of maintenance and repair in-house in order to utilize District resources.

In order to ensure the District is fully capable of achieving the energy savings and fully utilizing the new HVAC and Building Automation Systems, Energy Systems Group has included training for district employees.

Energy Systems Group recommends the District go out to bid for the following 3rd party service contracts in order to achieve the continuous savings throughout the term of the Energy Savings Improvement Program:

- Cogeneration Service Agreement to allow for emergency service and preventative maintenance on the new cogeneration systems. In order to receive the incentives for the cogeneration system, a 10-year maintenance contract must be in place. Energy Systems Group has shown the savings paying for this maintenance agreement but has not included the agreement within the ESIP.

Services for Lighting, Boiler Replacements, Combined Heat and Power, Plug Load Management, and walk-in freezer controller upgrades, such as filter changes and on-going maintenance can be completed by District staff.

Design and Compliance Issues

Teaneck Public School District will work closely with Energy Systems Group and CHA Consulting Inc. (CHA) to oversee and complete all design engineering for the purposes of public bidding of the work as well as completing construction drawings.

As part of the Energy Savings Plan development, Energy Systems Group completed a thorough analysis of the building electrical and mechanical systems including light level readings throughout the spaces. The existing light levels are typically within 10-20% of current Illumination Engineering Society (IES) recommendations, which is reasonable given the varying age of lamps throughout the District. The proposed lighting solution will continue to adhere to current IES and NJ Education Code guidelines for light levels, which in many cases may increase the current light levels to the spaces. At this time, Energy Systems Group did not observe any compliance issues in the development of this Energy Savings Plan.

Customer Risks

Asbestos reports were obtained and reviewed for all schools as part of Energy Systems Group's safety policy. Based on the reports, asbestos materials will have to be abated prior to any work being performed. If any additional asbestos is found during the installation of the measures, Energy Systems Group will stop work and notify the School District. Any work associated with testing or remediation of asbestos containing material will be the responsibility of Teaneck Public School District. Based on the asbestos reports provided, we feel this is a low risk item.

The NJ SmartStart, NJ Clean Energy and Demand Response Energy Efficiency Credit, and Combined Heat and Power Incentives outline the anticipated incentive amounts to Teaneck Public School District. Energy Systems Group does not guarantee the rebate or state incentive structure. If the programs change or the incentive amounts differ, Teaneck Public School District will be responsible to make up the difference in received incentives for the financing. The difference could result from over performance of energy conservation measures, other rebates/ incentives that may be available, restructuring the loan payment for years 1 and 2, or capital contributions by the District.

Public Engagement and Community Outreach

Student Engagement in ESIP Development: ESG has involved students at all levels in the energy related fields. At Teaneck Public Schools, we plan to expand on interests related to energy conservation throughout the district and would welcome and actively encourage student involvement in various phases of the proposed project. Furthermore, in line with our commitment, and with Teaneck's concurrence, we propose to offer presentations to Energy Clubs, including them in the process.

STEM EXPO Sponsorship: ESG has a history of sponsoring STEM programs for many school districts and Universities across the country. If selected, ESG would like to sponsor the Teaneck's Annual STEM EXPO and further complement your Engineering/Technology Science curriculum.

Community Outreach Program: ESG is focused on creating a partnership with Teaneck Public School District that will extend beyond the scope of this project. Keeping the community informed and involved in the process is key to success. One way this can be achieved is thru a **Community Scholarship Program**. At Northern Illinois University (NIU), ESG established The **Energy Systems Group Scholarship Award in Engineering** to underscore our commitment. Established in 2001, ESG and NIU jointly select students for award of this scholarship. To date, we have awarded **\$35,000** to NIU engineering students with superior academic excellence. ESG would like to establish a similar program for Teaneck Public Schools.

ESG will seek to develop and build partnerships between The National Education Foundation (NEF) and the Teaneck Public School District. These partnerships were developed by ESG and the NEF, to bring

Teaneck Public Schools Energy Savings Plan

engineering and engineering technology career opportunities to students through the educational programs offered by the University of Salt Lake City Utah. These programs help students who might not otherwise consider careers in these sciences or further expand the knowledge of the children who are participating in such class. In addition, this affords local colleges and Universities the opportunity to recruit future applicants from the local school boards. Some of these programs are listed below:

Student Engagement in ESIP Development: ESG has involved students at all levels in the energy related fields. At TPS, we plan to expand on interests related to energy conservation throughout the TPS campus and would welcome and actively encourage student involvement in various phases of the proposed project. Furthermore, in line with our commitment, and with TPS's concurrence, we propose to offer presentations to Energy Clubs, including them in the process.

Solar Photovoltaic Systems at Work Grades 9-12: This program includes learning activities for the secondary levels and a supply kit to investigate solar energy and its uses. Additional instructional materials include the Renewable Energy Sources poster, Energist, the Electrical Generation poster and Energist, the Energy Basics CD, and the Eye Chart poster. The program can stand alone or complement Energy Fun, Energy Fundamentals, Energy Action Technology, or Energy Action Patrol.

Career Exploration, grades 11-12: Provides students with career related work experience while obtaining up to 40 hours of academic credit. The program allows students a superb opportunity to integrate classroom theory into the world of work, as well as providing career option exploration, skill development, work environment exposure, and professional contacts.

SECTION 7: IMPLEMENTATION SCHEDULE

A preliminary installation schedule for the measures implemented as part of the ESP is included below to provide a reasonable expectation for the timeline of construction. Once final bids are received and financing of the project is complete, the installation will be finalized in much greater detail and reviewed with the team from Teaneck Public School District to ensure agreement. A high-level review of the next steps in the process is shown below as well as the estimated time frame to complete each step:

- Pre-ESIP Contract Work: January 1, 2020 – March 10, 2020
- Approval resolution to contract with Energy Systems Group: April 21, 2020
- Financing of project: 21 days (April 22 -)
- Complete 95% design drawings and bid specifications – April 27, 2020
- Installation – January 2020 - April 2021
- Maintenance: On-going

SECTION 8. SAMPLE ENERGY PERFORMANCE CONTRACT

A sample Energy Performance Contract has been provided electronically to the District for review.

APPENDIX 1. ENERGY CONSERVATION MEASURES INVESTIGATED BUT NOT RECOMMENDED AT THIS TIME

ECM: Replace Exhaust Fan Motors with EC Motors

ECM Summary



GREENHECK Vari-Green Motor

The District has several exhaust fans that have older low-efficiency motors and have exceeded their useful life. Although this measure results in a poor payback period, it is recommended based on the potential for energy savings, improved occupant comfort and safety concerns.


On small motor applications, Electronically Commutated (EC) Motors have the proven potential to generate significant savings. These motors are typically in sizes up to 1 horsepower, and their efficiencies are high compared to the older fractional horsepower motors. Since these motors are without mechanical brushes and the commutator reduces friction losses, they work much like Direct Current (DC) motors. They are programmable and can be used for a wide range of applications.

Facilities Considered for this Measure

- All buildings

ECM: Destratification Fans

ECM Summary



In rooms with high ceilings typically stratification of heated air occurs, resulting in air at ceiling level being warmer than the floor level. Since temperature at the floor level dictates the comfort of occupants and is typically the location of the thermostat controlling the system, this results in additional operating hours to satisfy space conditions. A de-stratification fan continuously mixes the air, balancing temperatures from ceiling to floor and wall to wall which helps the HVAC system maintain the desired temperature.

Facilities Considered for this Measure

- All buildings

ECM: Addition of Air-Cooled Chillers

ECM Summary

Some of the schools in the district have areas that are either not fully air conditioned or have systems that are in need of an upgrade/replacement. We have proposed the addition of cooling at Benjamin Franklin & Thomas Jefferson Middle Schools, in an efficient manner so that the space can be comfortably occupied throughout the year. This ECM entails the addition a high efficiency air cooled chilling system. The proposed system will reduce cooling costs compared to a standard DX equipment and will include DDC controls that can be easily integrated into the proposed Building Management System. The new systems will also ensure that all equipment operates with a common, environmentally low-impact refrigerant minimizing the ozone depletion potential.

Benjamin Franklin Middle School

Concept would be to install a new 280-ton air cooled chiller setting on steel structure next to Auditorium Trane 40-ton DX Rooftop unit with HW Coil. Trane 40-ton unit would be converted; removing DX system, compressors, piping and DX cooling coil and new CHW coil installed in unit. Chiller would provide CHW from new roof mounted chiller down to boiler mechanical room connecting to new pumps with premium efficiency motors. These pumps will be piped for Dual Temperature to provide chilled water and heating hot water for each season

Thomas Jefferson Middle School

Concept would be to install a new 315-ton air cooled chiller setting on steel structure on the roof. Chiller would provide CHW from new roof mounted chiller down to boiler mechanical room connecting to new pumps with premium efficiency motors. These pumps will be piped for Dual Temperature to provide chilled water and heating hot water for each season

Facilities Considered for this Measure

- Thomas Jefferson Middle School
- Benjamin Franklin Middle School

ECM: Replace Cafeteria Roof Top Unit at Bryant Elementary School

ECM Summary

Split units in the Teaneck School District vary based on age and condition. Replacing aged split system HVAC units will reduce the operating and maintenance costs of these systems. Both heating and cooling efficiencies of split system HVAC equipment have significantly increased in the past 10 years. ESG has identified several older units that still utilize R22 refrigerant as the prime candidates for replacement.

The scope of this project would be to replace the current split HVAC system (with HW coil) that uses R22 refrigerant with a new, high-efficiency R410A split system. The new system would be adapted to the current installation for fit and functionality.

Facilities Considered for this Measure

- Bryant Elementary School

ECM: Install High Efficiency Domestic Water Heaters

ECM Summary

The existing domestic water heaters at some District facilities are nearing the end of their useful life. As existing DHW boiler(s) age, they typically experience a loss in efficiency due to fouling and scaling on the internal heat exchange components, as well as an increase in maintenance costs. This measure will include replacing these units with new high-efficiency domestic water heating systems.

The existing domestic hot water heaters are standard efficiency models that operate at a nameplate value of around 80% thermal efficiency. This measure will include the installation of new hot water heaters to replace these aging, lower efficiency ones. New condensing water heaters are available that operate at efficiencies up to 97%.

Facilities Considered for this Measure

- All buildings

ECM: Addition of Cooling to Cafeteria at Middle Schools

ECM Summary

The existing cafeteria air handling units at the Middle Schools are heating only. As existing units, they are unable to be modified to allow cooling to be added to the cafeterias. This measure will include replacing these units with new high-efficiency rooftop units with DX cooling and HHW coil for heating. These units will include economizers, relief dampers and new roof curbs.

Facilities Considered for this Measure

- Ben Franklin Middle School
- Thomas Jefferson Middle School

ECM: Replace Water-Cooled Chiller with Air-Cooled Chiller

ECM Summary

The existing (2) 100-ton water-cooled chillers at Teaneck High School are nearing the end of their useful life. As existing chillers age, they typically experience a loss in efficiency due to fouling and scaling on the internal heat exchange components, as well as an increase in maintenance costs. This measure will include replacing these units with new high-efficiency 200-ton air-cooled chiller.

The addition of the air-cooled chiller to the cooling system will allow for flexibility to add cooling more easily as the air-cooled chiller could provide cooling in the shoulder months without requiring the cooling tower to be brought online.

Facilities Considered for this Measure

- Teaneck High School

APPENDIX 2. ENERGY SAVINGS CALCULATIONS

Energy Savings

Energy savings were calculated using an Excel based bin calculation workbook developed by Energy Systems Group; all savings calculations and field measurements will be provided electronically.

Operational Savings

New LED Fixtures

Annual operational savings are calculated based on the reduced amount of material needed for replacement of the lighting system. This is calculated by comparing the existing lifetime of the T8, HID and halogen lamps to the new lifetime of LED lighting. The calculations are based on replacements of T8 fixtures every three years, T8 ballasts every 5 years, HID lamps every 5 years and halogen lamps being replaced every 2 years. The table below highlights the various lamp types and associated replacement timing as well as total cost with replacement. These savings do not include any costs for labor to replace the bulbs or additional material needed for replacement such as lifts, replacement fixtures, new sockets, etc.

| Material Type | Lifetime | Cost/ Unit |
|-------------------------|----------|------------|
| Linear fluorescent (T8) | 3 years | \$5 |
| Electronic Ballast | 5 years | \$25 |
| HID Lamp | 5 years | \$25 |
| HID Ballast | 5 years | \$75 |
| Halogen, PARs, BRs | 2 years | \$10 |
| Incandescent, CFLs, MRs | 2 years | \$2 |

This methodology is used to determine the annual savings through the replacement of all lamp types with new LED lamps and fixtures. The fixture warranty associated with each of these replacements is 10 years. Operational savings have been claimed for a total of 5 years per the BPU regulations.

Mechanical Upgrades (Boiler Replacement & Controls Upgrades)


The annual operating expenses for Teaneck Public Schools was provided to Energy Systems Group in order to determine the amount of emergency repair maintenance conducted annually at the District. The installation of new equipment along with manufacturers' warranties will effectively eliminate the need for these emergency repair costs. The operational savings for these measures have been claimed for 2 years per the BPU regulations. A complete breakdown of the operational analysis for the District is included on the following pages.

Operational Savings Summary


Energy Systems Group has worked with the District to quantify the exact sources of savings by going through past invoices and expenses. The table below summarizes the cost savings estimated from invoices provided by the District; these invoices are summarized only by the applicable ECMs and any non-recurring charge. Any preventative maintenance or service contracts that will remain were not factored into this analysis. The complete list of invoices is provided electronically. The operational savings will not be escalated.

| Operational Savings for Financial Model | |
|---|-----------------|
| ECM Description | Annual Savings |
| LED Lighting Upgrades | \$26,130 |
| Reduction in replacement parts and maintenance expenses – District Wide | \$59,474 |
| Totals | \$85,604 |

APPENDIX 3. BUILDING ENVELOPE SCOPE DRAWINGS



Benjamin Franklin Middle School
Basement Floor Plan




Door Weather Stripping

Weather stripping is to be installed as noted on the plan. Notes stand for:
 s = sides, l = top, w = sweep, c = center
 Only doors with retrofit recommendations are numbered. Floor plan numbering is
 NOT intended to match any existing building security numbers.


-  Single Door Weather Stripping
-  Double Door Weather Stripping

-  Caulking
-  Retrofit Wall AC Unit

Teaneck Public Schools Energy Savings Plan



Benjamin Franklin Middle School
First Floor Plan




Door Weather Stripping

Weather stripping is to be installed as noted on the plan. Notes stand for:
 s = sides, l = top, w = sweep, c = center
 Only doors with retrofit recommendations are numbered. Floor plan numbering is
 NOT intended to match any existing building security numbers.

- Single Door Weather Stripping
- Double Door Weather Stripping

- Caulking
- Retrofit Wall AC Unit




Door Weather Stripping

Weather stripping is to be installed as noted on the plan. Notes stand for:
s = sides, l = top, w = sweep, c = center
Only doors with retrofit recommendations are numbered. Floor plan numbering is NOT intended to match any existing building security numbers.

- Single Door Weather Stripping
- Double Door Weather Stripping

- Caulking
- ▲ Retrofit Wall AC Unit



Benjamin Franklin Middle School
Third Floor Plan



Door Weather Stripping

Weather stripping is to be installed as noted on the plan. Notes stand for:
s = sides, t = top, w = sweep, c = center
Only doors with retrofit recommendations are numbered. Floor plan numbering is NOT intended to match any existing building security numbers.


- Single Door Weather Stripping
- Double Door Weather Stripping

Caulking

Retrofit Wall AC Unit

Teaneck Public Schools Energy Savings Plan

Page 19




Door Weather Stripping
Weather stripping is to be installed as noted on the plan. Notes stand for:
s = sides, l = top, w = sweep, c = center
Only doors with retrofit recommendations are numbered. Floor plan numbering is NOT intended to match any existing building security numbers.

- Single Door Weather Stripping
- Double Door Weather Stripping
- Overhang Air Sealing (Seal)

- Roof-Wall Air Sealing (Block, Seal)
- Roof-Wall Air Sealing (Seal)

Teaneck Public Schools Energy Savings Plan




Teaneck Public Schools Energy Savings Plan

Door Weather Stripping
Weather stripping is to be installed at doors as noted on the floor plan
Notes stand for:
s = sides
t = top
w = sweep
c = center
Only doors with retrofit recommendations are numbered. Floor plan numbering is NOT intended to match any existing building security numbers.


- ① Single Door Weather Stripping
- ② Double Door Weather Stripping


No Work Recommended on this Floor




Eugene Field Second Floor

0 5' 10' 15' 20'





Lowell Basement Floor







Door Weather Stripping
Weather stripping is to be installed as noted on the plan. Notes stand for:
s = sides, t = top, w = sweep, c = center
Only doors with retrofit recommendations are numbered. Floor plan numbering is NOT intended to match any existing building security numbers.


- # Single Door Weather Stripping
- # Double Door Weather Stripping

Lowell First Floor






Lowell Second Floor



High School First Floor

Page 26



Door Weather Stripping

Weather stripping is to be installed as noted on the plan. Notes stand for:
s = sides, t = top, w = sweep, c = center
Only doors with retrofit recommendations are numbered. Floor plan numbering is NOT intended to match any existing building security numbers.

- Single Door Weather Stripping
- Double Door Weather Stripping
- Overhead Door Weather Stripping

 Double Hung Window Weatherization

Window Weatherization:

Repair Interior Glazing Gasket Corners (all windows) - apply caulk to corners of window lite assemblies where existing gaskets were installed improperly, damaged, or removed.

High School Second Floor

Page 27



Door Weather Stripping

Weather stripping is to be installed as noted on the plan. Notes stand for:
s = sides, t = top, w = sweep, c = center
Only doors with retrofit recommendations are numbered. Floor plan numbering is NOT intended to match any existing building security numbers.

- Single Door Weather Stripping
- Double Door Weather Stripping
- Overhead Door Weather Stripping

 Double Hung Window Weatherization


Window Weatherization:

Repair Interior Glazing Gasket Corners (all windows) - apply caulk to corners of window lite assemblies where existing gaskets were installed improperly, damaged, or removed.

Teaneck Public Schools Energy Savings Plan

High School Third Floor

Page 28



Door Weather Stripping

Weather stripping is to be installed as noted on the plan. Notes stand for:
 s = sides, t = top, w = sweep, c = center
 Only doors with retrofit recommendations are numbered. Floor plan numbering is
 NOT intended to match any existing building security numbers.

○ Single Door Weather Stripping

● Double Door Weather Stripping


■ Overhead Door Weather Stripping


--- Double Hung Window Weatherization

Window Weatherization


Repair Interior Glazing Gasket Corners (all windows) - apply caulk to corners of window lite assemblies where existing gaskets were installed improperly, damaged, or removed.

Teaneck Public Schools Energy Savings Plan






- Door Weather Stripping**
Weather stripping is to be installed at doors as noted on the floor plan
- Notes stand for:
s = sides
t = top
w = sweep
c = center
- Only doors with retrofit recommendations are numbered. Floor plan numbering is NOT intended to match any existing building security numbers.
- # Single Door Weather Stripping
 - # Double Door Weather Stripping
 - Caulking
 - Attic Insulation 10" Open Blow Cellulose
 - Retrofit Access Hatch




Whittier Basement

0 5' 10' 15' 20'

Teaneck Public Schools Energy Savings Plan



Teaneck Public Schools Energy Savings Plan



APPENDIX 4. DETAILED SCOPE DESCRIPTIONS

Design Drawings will be available electronically.

Building Envelope Weatherization

Findings

AC Unit Weatherization – air conditioning units at Benjamin Franklin Elementary School are installed through-the-wall and remain in the building all year. A/C Unit Covers will eliminate unwanted air infiltration/exfiltration while the covers are in place.

Attic Flat Insulation –attic insulation is crucial for controlling conductive heat loss in a building. After air gaps are sealed and convective air loss is reduced the biggest remaining form of heat loss becomes conduction. Under-insulated surfaces at Whittier Elementary School result in excessive energy loss due to the lack of a properly insulated thermal barrier.

Caulking – there are unsealed perimeter joints and holes found at the gym window systems of Whittier Elementary School. Weaknesses at snap trim components of doors and windows at Benjamin Franklin Middle School are also allowing air to infiltrate and exfiltrate the building at small cracks in the construction of building envelope components.

Door Weather Stripping – deteriorated weather stripping materials, ineffective weather stripping installation and daylight showing at the perimeter of door systems create direct pathways for unwanted infiltration/exfiltration throughout the school district.

Double Hung Window Weatherization – deteriorated weather stripping at double hung windows of Teaneck High School are allowing excessive air leakage at the meeting rail and bottom of lower sashes throughout the building. Double Hung window sash locks have fallen off completely at select windows and have been replaced by sliding latch locks in order to keep windows secured. The sliding latch locks do not compress the little existing weather stripping that still exists; regardless of locking hardware double hung windows are the largest building envelope weakness throughout the High School building.

Overhang Air Sealing – overhangs are roofs, floor systems or areas above entryways that extend beyond the plane of the exterior wall system. This area of construction at the Bryant Elementary School was misunderstood by builders and the cavity that extends beyond the plane of the exterior wall system was incorrectly “connected” to the interior heated spaces of the building in many locations. Overhangs that are not properly sealed at the plane of the surface that should separate the conditioned space from the outdoors lead to excessive air leakage and heat loss at these vulnerable areas in the building envelope.

Overhead Door Weather Stripping/ Roll-up Door Weather Stripping – remove existing weather stripping and replace with new commercial grade weather stripping to create a full air seal around the door. With low grade, none, or deteriorating materials in place overhead and roll-up doors are a major air leakage sources.

Roof-Wall Intersection Air Sealing – the roof-wall intersection is regularly an area that allows unwanted air leakage through the building shell. Exterior flashing and finish details at this area are not constructed to stop air leakage (exterior flashings are for water control, not air control); unsealed exterior flashing details combine with interior gaps in the framing between the roof and wall assembly to allow infiltration/ exfiltration.

Window Weatherization – glazing gaskets throughout the High School building were installed poorly or have deteriorated badly resulting in small air gaps at the intersection between muntions, mullions and glass components.

Building Envelope Improvement Recommendations

- AC Unit Weatherization
 - A/C Unit Covers (Benjamin Franklin MS) – install rigid coverings over all relevant A/C units as noted on floor plan.
- Attic Flat Insulation
 - 10” Open Blow Cellulose (Whittier ES) – install 10 inches of cellulose across the attic flat.
- Caulking
- Door Weather Stripping
- Double Hung Window Weatherization
 - Double Hung Window Weatherization (Teaneck High School) – where the meeting rail lock has been removed; install continuous mechanically fastened Q-Ion weather stripping to bottom sash so as to compress against the gap between the upper and lower sash at the meeting rail. Where the meeting rail sash lock is in place; separate the upper and lower sash for the purpose of cleaning the upper sash “U-channel” receiving weather barrier. Vacuum out debris and metal brush channel to receive sealant. Apply siliconized acrylic sealant to channel. Close and lock window inserting PVDC monofilaments to keep the sealant in the “U-channel” from adhering to the upper sash. Remove the monofilaments once the sealant is cured. Install PVC foam Weatherseal Tape to sill so as to receive lower sash at the interior frame. Make upper sash stationary and caulk in place to eliminate air leakage at upper sash.

- Overhang Air Sealing
- Overhead Door Weather Stripping/ Roll-up Door Weather Stripping
- Weather Strip (Teaneck High School) – install heavy-duty aluminum carrier with oversized vinyl insert gasket at the sides: install heavy-duty aluminum carrier with an oversized bottom U-style gasket at bottom.
- Roof-Wall Intersection Air Sealing
- Window Weatherization
- Custom Window Weatherization (Teaneck High School) – install Sascho Big Stretch caulk at failed and missing glazing bead corners of all windows. Caulk is to be applied at corners and full lengths of windows where existing glazing gaskets are missing or damaged.

Teaneck Public Schools Energy Savings Plan

Plug Load Controls

Benjamin Franklin Middle School

| Device Type: | Quantity: |
|--|-----------|
| Projector | 7 |
| Smartboard | 0 |
| Projector/Smartboard Combo | 0 |
| Amplifier | 0 |
| Charging Cart | 19 |
| Small Printer | 0 |
| Medium Printer | 12 |
| Large Printer/Copier (110 only) | 2 |
| TV/LCD/Smart TV | 0 |
| Snack Vending | 1 |
| Soda Vending | 1 |
| Lg Coffeemaker (Bunn) | 0 |
| H/C Water Dispenser | 0 |
| Water Fountain (plug on outside) | 0 |
| AC - 220 (not to be more than 20 amps) | 0 |
| AC - 110 20 amps | 0 |
| AC - 110 15 amps | 1 |
| Electric Hot Water Heater | 0 |
| Other Device not listed above | |

Hawthorne Elementary School

| Device Type: | Quantity: |
|--|-----------|
| Projector | 1 |
| Smartboard | 3 |
| Projector/Smartboard Combo | 0 |
| Amplifier | 0 |
| Charging Cart | 9 |
| Small Printer | 0 |
| Medium Printer | 10 |
| Large Printer/Copier (110 only) | 0 |
| TV/LCD/Smart TV | 0 |
| Snack Vending | 0 |
| Soda Vending | 0 |
| Lg Coffeemaker (Bunn) | 0 |
| H/C Water Dispenser | 0 |
| Water Fountain (plug on outside) | 0 |
| AC - 220 (not to be more than 20 amps) | 0 |
| AC - 110 20 amps | 3 |
| AC - 110 15 amps | 0 |
| Electric Hot Water Heater | 0 |
| Other Device not listed above | 0 |

Teaneck Public Schools Energy Savings Plan

Lowell Elementary School

| Device Type: | Quantity: |
|--|-----------|
| Projector | 0 |
| Smartboard | 0 |
| Projector/Smartboard Combo | 0 |
| Amplifier | 0 |
| Charging Cart | 16 |
| Small Printer | 0 |
| Medium Printer | 8 |
| Large Printer/Copier (110 only) | 0 |
| TV/LCD/Smart TV | 0 |
| Snack Vending | 0 |
| Soda Vending | 0 |
| Lg Coffeemaker (Bunn) | 0 |
| H/C Water Dispenser | 0 |
| Water Fountain (plug on outside) | 0 |
| AC - 220 (not to be more then 20 amps) | 0 |
| AC - 110 20 amps | 0 |
| AC - 110 15 amps | 2 |
| Electric Hot Water Heater | 0 |
| Other Device not listed above | 0 |

Teaneck High School

| Device Type: | Quantity: |
|--|-----------|
| Projector | 18 |
| Smartboard | 0 |
| Projector/Smartboard Combo | 0 |
| Amplifier | 0 |
| Charging Cart | 34 |
| Small Printer | 0 |
| Medium Printer | 9 |
| Large Printer/Copier (110 only) | 6 |
| TV/LCD/Smart TV | 0 |
| Snack Vending | 0 |
| Soda Vending | 0 |
| Lg Coffeemaker (Bunn) | 0 |
| H/C Water Dispenser | 0 |
| Water Fountain (plug on outside) | 6 |
| AC - 220 (not to be more then 20 amps) | 0 |
| AC - 110 20 amps | 0 |
| AC - 110 15 amps | 0 |
| Electric Hot Water Heater | 0 |
| Other Device not listed above | 0 |

Teaneck Public Schools Energy Savings Plan

Thomas Jefferson Middle School

| Device Type: | Quantity: |
|--|-----------|
| Projector | 0 |
| Smartboard | 4 |
| Projector/Smartboard Combo | 0 |
| Amplifier | 0 |
| Charging Cart | 25 |
| Small Printer | 2 |
| Medium Printer | 23 |
| Large Printer/Copier (110 only) | 0 |
| TV/LCD/Smart TV | 0 |
| Snack Vending | 1 |
| Soda Vending | 2 |
| Lg Coffeemaker (Bunn) | 0 |
| H/C Water Dispenser | 0 |
| Water Fountain (plug on outside) | 3 |
| AC - 220 (not to be more than 20 amps) | 0 |
| AC - 110 20 amps | 0 |
| AC - 110 15 amps | 0 |
| Electric Hot Water Heater | 0 |
| Other Device not listed above | 0 |

Whitter Elementary School

| Device Type: | Quantity: |
|--|-----------|
| Projector | 1 |
| Smartboard | 4 |
| Projector/Smartboard Combo | 0 |
| Amplifier | 0 |
| Charging Cart | 11 |
| Small Printer | 0 |
| Medium Printer | 7 |
| Large Printer/Copier (110 only) | 0 |
| TV/LCD/Smart TV | 0 |
| Snack Vending | 0 |
| Soda Vending | 1 |
| Lg Coffeemaker (Bunn) | 0 |
| H/C Water Dispenser | 0 |
| Water Fountain (plug on outside) | 0 |
| AC - 220 (not to be more than 20 amps) | 0 |
| AC - 110 20 amps | 1 |
| AC - 110 15 amps | 1 |
| Electric Hot Water Heater | 1 |
| Other Device not listed above | 0 |

Teaneck Public Schools Energy Savings Plan

Mechanical Insulation

TEANECK PUBLIC SCHOOLS, NJ MECHANICAL INSULATION SAVINGS SUMMARY

| Building | Fluid Type | Pipe Dia (") or Tank Surface Area(SF)* | Component | Insulation Thickness (") | Proposed Insulation Type | Quantity or Length | Total Eq Length(LF) or Total Area(SF)* | Heating or Cooling Hrs/Yr | Price per Unit | Total Investment | Fuel Savings MMBtu | Electric Savings kWh | Total Savings | Payback |
|--|-------------------|--|--------------------|--------------------------|--------------------------|--------------------|--|---------------------------|----------------|------------------|--------------------|----------------------|---------------|-----------------|
| Benjamin Franklin Middle School | | | | | | | | | | | | | | |
| | MTHW | 10 | Butterfly Valve | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 305.20 | \$610 | 11.3 MMBtu | 0 kWh | \$91 | 6.7 yrs |
| | MTHW | 10 | Centrifugal Pump | 1.5 | Removable Blanket | 2 | 10 | 5110 | 352.30 | \$705 | 13.8 MMBtu | 0 kWh | \$111 | 6.4 yrs |
| | MTHW | 10 | Check Valve | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 337.70 | \$675 | 11.3 MMBtu | 0 kWh | \$91 | 7.4 yrs |
| | MTHW | 10 | Flange | 1.5 | Removable Blanket | 12 | 21.6 | 5110 | 279.30 | \$3,352 | 29.9 MMBtu | 0 kWh | \$239 | 14.0 yrs |
| | MTHW | 10 | Flex Fitting | 2 | Cellular Glass | 4 | 6 | 5110 | 62.80 | \$251 | 8.7 MMBtu | 0 kWh | \$70 | 3.6 yrs |
| | MTHW | 10 | Suction Diffuser | 1.5 | Removable Blanket | 2 | 8.8 | 5110 | 352.30 | \$705 | 12.2 MMBtu | 0 kWh | \$97 | 7.2 yrs |
| | MTHW Total | | | | | | | | | \$6,298 | 87.3 MMBtu | 0 kWh | \$698 | 9.0 yrs |
| Benjamin Franklin Middle School Total | | | | | | | | | | \$6,298 | 87.3 MMBtu | 0 kWh | \$698 | 9.0 yrs |
| Bryant Elementary School | | | | | | | | | | | | | | |
| | MTHW | 2 | Butterfly Valve | 1.5 | Removable Blanket | 5 | 20.5 | 5110 | 90.80 | \$454 | 7.1 MMBtu | 0 kWh | \$57 | 8.0 yrs |
| | MTHW | 2 | Flo-Check | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 108.70 | \$217 | 2.9 MMBtu | 0 kWh | \$23 | 9.5 yrs |
| | MTHW | 2 | In-Line Pump | 1.5 | Removable Blanket | 2 | 10 | 5110 | 142.70 | \$285 | 3.5 MMBtu | 0 kWh | \$28 | 10.2 yrs |
| | MTHW | 2 | Straight Pipe | 2 | Cellular Glass | 12 | 12 | 5110 | 36.10 | \$433 | 4.4 MMBtu | 0 kWh | \$35 | 12.4 yrs |
| | MTHW | 3.4 | Air Separator Tank | 2 | Cellular Glass | 1 | 3.4 | 5110 | 161.40 | \$548 | 2.0 MMBtu | 0 kWh | \$16 | 35.1 yrs |
| | MTHW | 12 | Flange | 2 | Cellular Glass | 1 | 1.8 | 5110 | 47.00 | \$47 | 3.0 MMBtu | 0 kWh | \$24 | 1.9 yrs |
| | MTHW Total | | | | | | | | | \$1,985 | 22.9 MMBtu | 0 kWh | \$183 | 10.9 yrs |
| | LPS | 1.25 | Control Valve | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 100.50 | \$201 | 2.7 MMBtu | 0 kWh | \$22 | 9.3 yrs |
| | LPS | 2 | Butterfly Valve | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 90.80 | \$182 | 3.8 MMBtu | 0 kWh | \$30 | 6.0 yrs |
| | LPS | 2.5 | 90 Degree Elbow | 2.5 | Cellular Glass | 2 | 3.6 | 5110 | 72.70 | \$145 | 0.9 MMBtu | 0 kWh | \$7 | 20.8 yrs |
| | LPS | 2.5 | Flange | 1.5 | Removable Blanket | 2 | 3.6 | 5110 | 87.60 | \$175 | 2.0 MMBtu | 0 kWh | \$16 | 11.1 yrs |
| | LPS | 2.5 | Gate Valve | 1.5 | Removable Blanket | 1 | 5 | 5110 | 123.30 | \$123 | 2.7 MMBtu | 0 kWh | \$22 | 5.6 yrs |
| | LPS | 2.5 | Straight Pipe | 2.5 | Cellular Glass | 8 | 8 | 5110 | 67.60 | \$541 | 1.9 MMBtu | 0 kWh | \$16 | 34.8 yrs |
| | LPS | 2.5 | Strainer | 1.5 | Removable Blanket | 2 | 10 | 5110 | 123.30 | \$247 | 5.5 MMBtu | 0 kWh | \$44 | 5.6 yrs |
| | LPS | 5 | 90 Degree Elbow | 3 | Cellular Glass | 1 | 1.8 | 5110 | 88.00 | \$88 | 1.9 MMBtu | 0 kWh | \$15 | 5.7 yrs |
| | LPS | 5 | Flange | 3 | Cellular Glass | 1 | 1.8 | 5110 | 74.20 | \$74 | 1.9 MMBtu | 0 kWh | \$15 | 4.8 yrs |
| | LPS | 5 | Straight Pipe | 3 | Cellular Glass | 6 | 6 | 5110 | 74.20 | \$445 | 6.5 MMBtu | 0 kWh | \$52 | 8.6 yrs |
| | LPS | 6 | Bonnet | 1.5 | Removable Blanket | 2 | 3.6 | 5110 | 204.50 | \$409 | 4.2 MMBtu | 0 kWh | \$34 | 12.1 yrs |
| | LPS | 6 | Flange | 1.5 | Removable Blanket | 3 | 5.4 | 5110 | 201.40 | \$604 | 6.3 MMBtu | 0 kWh | \$51 | 11.9 yrs |
| | LPS | 6 | Gate Valve | 1.5 | Removable Blanket | 1 | 5 | 5110 | 253.30 | \$253 | 5.9 MMBtu | 0 kWh | \$47 | 5.4 yrs |
| | LPS | 8 | 90 Degree Elbow | 3 | Cellular Glass | 1 | 1.8 | 5110 | 104.80 | \$105 | 2.9 MMBtu | 0 kWh | \$23 | 4.5 yrs |
| | LPS | 8 | Bonnet | 1.5 | Removable Blanket | 2 | 3.6 | 5110 | 204.50 | \$409 | 5.4 MMBtu | 0 kWh | \$43 | 9.5 yrs |
| | LPS | 8 | Flange | 3 | Cellular Glass | 3 | 5.4 | 5110 | 79.50 | \$238 | 8.7 MMBtu | 0 kWh | \$69 | 3.4 yrs |
| | LPS | 8 | T Intersection | 3 | Cellular Glass | 1 | 1.2 | 5110 | 104.80 | \$105 | 1.9 MMBtu | 0 kWh | \$15 | 6.8 yrs |
| | LPS | 14 | Flange | 3 | Cellular Glass | 6 | 10.8 | 5110 | 94.10 | \$565 | 25.2 MMBtu | 0 kWh | \$202 | 2.8 yrs |
| | LPS | 14 | Straight Pipe | 3 | Cellular Glass | 6 | 6 | 5110 | 94.10 | \$565 | 14.0 MMBtu | 0 kWh | \$112 | 5.0 yrs |
| | LPS | 14 | T Intersection | 3 | Cellular Glass | 1 | 1.2 | 5110 | 118.30 | \$118 | 2.8 MMBtu | 0 kWh | \$22 | 5.3 yrs |
| | LPS Total | | | | | | | | | \$5,592 | 107.2 MMBtu | 0 kWh | \$857 | 6.5 yrs |
| | Cond | 1 | 90 Degree Elbow | 1.5 | Cellular Glass | 24 | 43.2 | 5110 | 32.30 | \$775 | 6.9 MMBtu | 0 kWh | \$55 | 14.1 yrs |
| | Cond | 1 | Steam Trap | 1.5 | Removable Blanket | 5 | 22 | 5110 | 116.80 | \$584 | 3.4 MMBtu | 0 kWh | \$27 | 21.3 yrs |
| | Cond | 1 | Straight Pipe | 1.5 | Cellular Glass | 75 | 75 | 5110 | 32.90 | \$2,471 | 12.0 MMBtu | 0 kWh | \$96 | 25.8 yrs |
| | Cond | 1 | Strainer | 1.5 | Cellular Glass | 4 | 20 | 5110 | 36.70 | \$147 | 3.2 MMBtu | 0 kWh | \$26 | 5.8 yrs |
| | Cond | 1 | T Intersection | 1.5 | Cellular Glass | 2 | 2.4 | 5110 | 32.30 | \$65 | 0.4 MMBtu | 0 kWh | \$3 | 21.1 yrs |
| | Cond | 1.5 | 45 Degree Elbow | 2 | Cellular Glass | 4 | 4 | 5110 | 37.70 | \$151 | 0.9 MMBtu | 0 kWh | \$7 | 20.3 yrs |
| | Cond | 1.5 | 90 Degree Elbow | 2 | Cellular Glass | 6 | 10.8 | 5110 | 37.70 | \$226 | 2.5 MMBtu | 0 kWh | \$20 | 11.3 yrs |
| | Cond | 1.5 | 90 Degree Elbow | 2 | Cellular Glass | 3 | 5.4 | 5110 | 37.70 | \$113 | 1.3 MMBtu | 0 kWh | \$10 | 11.3 yrs |
| | Cond | 1.5 | In-Line Pump | 1.5 | Removable Blanket | 2 | 10 | 5110 | 142.70 | \$285 | 2.2 MMBtu | 0 kWh | \$18 | 16.2 yrs |
| | Cond | 1.5 | Steam Trap | 1.5 | Removable Blanket | 1 | 4.4 | 5110 | 123.30 | \$123 | 1.0 MMBtu | 0 kWh | \$8 | 15.9 yrs |
| | Cond | 1.5 | Straight Pipe | 2 | Cellular Glass | 9 | 9 | 5110 | 35.80 | \$322 | 2.1 MMBtu | 0 kWh | \$17 | 19.3 yrs |
| | Cond | 1.5 | Straight Pipe | 2 | Cellular Glass | 22 | 22 | 5110 | 35.80 | \$787 | 5.1 MMBtu | 0 kWh | \$41 | 19.3 yrs |
| | Cond | 1.5 | T Intersection | 2 | Cellular Glass | 2 | 2.4 | 5110 | 37.70 | \$75 | 0.6 MMBtu | 0 kWh | \$4 | 16.9 yrs |
| | Cond | 2 | 90 Degree Elbow | 2 | Cellular Glass | 3 | 5.4 | 5110 | 37.70 | \$113 | 1.5 MMBtu | 0 kWh | \$12 | 9.2 yrs |
| | Cond | 2 | Straight Pipe | 2 | Cellular Glass | 47 | 47 | 5110 | 36.10 | \$1,697 | 13.4 MMBtu | 0 kWh | \$107 | 15.8 yrs |
| | Cond | 3 | Bonnet | 1.5 | Removable Blanket | 1 | 1.8 | 5110 | 123.30 | \$123 | 0.7 MMBtu | 0 kWh | \$6 | 22.1 yrs |
| | Cond | 3 | Straight Pipe | 2 | Cellular Glass | 2 | 2 | 5110 | 37.10 | \$74 | 0.8 MMBtu | 0 kWh | \$7 | 11.4 yrs |
| | Cond | 3 | T Intersection | 2 | Cellular Glass | 1 | 1.2 | 5110 | 40.40 | \$40 | 0.5 MMBtu | 0 kWh | \$4 | 10.3 yrs |
| | Cond | 4 | Flange | 2 | Cellular Glass | 2 | 3.6 | 5110 | 38.40 | \$77 | 1.8 MMBtu | 0 kWh | \$15 | 5.2 yrs |
| | Cond | 56.9 | Condensate Tank | 2 | Cellular Glass | 1 | 56.9 | 5110 | 44.90 | \$2,553 | 25.4 MMBtu | 0 kWh | \$203 | 12.6 yrs |
| | Cond Total | | | | | | | | | \$10,802 | 85.7 MMBtu | 0 kWh | \$685 | 15.8 yrs |

Teaneck Public Schools Energy Savings Plan

TEANECK PUBLIC SCHOOLS, NJ MECHANICAL INSULATION SAVINGS SUMMARY

| Building | Fluid Type | Pipe Dia (") or Tank Surface Area(SF)* | Component | Insulation Thickness (") | Proposed Insulation Type | Quantity or Length | Total Eq Length(LF) or Total Area(SF)* | Heating or Cooling Hrs/Yr | Price per Unit | Total Investment | Fuel Savings MMBTU | Electric Savings kWh | Total Savings | Payback | |
|---|-------------------|--|-------------------|--------------------------|--------------------------|--------------------|--|---------------------------|----------------|------------------|--------------------|----------------------|----------------|-----------------|-----------------|
| Bryant Elementary School Total | | | | | | | | | | \$18,379 | 215.7 MMBtu | 0 kWh | \$1,726 | 10.7 yrs | |
| Eugene Administration Building | MTHW | 1.5 | 90 Degree Elbow | 2 | Cellular Glass | 5 | 9 | 5110 | 37.70 | \$188 | 2.7 MMBtu | 0 kWh | \$21 | 8.8 yrs | |
| | MTHW | 1.5 | Control Valve | 1.5 | Removable Blanket | 1 | 4.1 | 5110 | 123.30 | \$123 | 1.2 MMBtu | 0 kWh | \$9 | 13.3 yrs | |
| | MTHW | 1.5 | End Cap | 2 | Cellular Glass | 2 | 3.6 | 5110 | 123.20 | \$246 | 1.1 MMBtu | 0 kWh | \$9 | 28.7 yrs | |
| | MTHW | 1.5 | Flo-Check | 1.5 | Removable Blanket | 1 | 4.1 | 5110 | 107.00 | \$107 | 1.2 MMBtu | 0 kWh | \$9 | 11.5 yrs | |
| | MTHW | 1.5 | Straight Pipe | 2 | Cellular Glass | 4 | 4 | 5110 | 35.80 | \$143 | 1.2 MMBtu | 0 kWh | \$10 | 15.0 yrs | |
| | MTHW | 1.5 | Straight Pipe | 2 | Cellular Glass | 7 | 7 | 5110 | 35.80 | \$250 | 2.1 MMBtu | 0 kWh | \$17 | 15.0 yrs | |
| | MTHW | 1.5 | Strainer | 1.5 | Removable Blanket | 1 | 5 | 5110 | 105.40 | \$105 | 1.4 MMBtu | 0 kWh | \$11 | 9.3 yrs | |
| | MTHW | 1.5 | Triple Duty Valve | 1.5 | Removable Blanket | 1 | 5 | 5110 | 105.40 | \$105 | 1.4 MMBtu | 0 kWh | \$11 | 9.3 yrs | |
| | MTHW | 2 | 90 Degree Elbow | 2 | Cellular Glass | 2 | 3.6 | 5110 | 37.70 | \$151 | 2.6 MMBtu | 0 kWh | \$21 | 7.2 yrs | |
| | MTHW | 2 | Bonnet | 1.5 | Removable Blanket | 1 | 1.8 | 5110 | 98.90 | \$99 | 0.6 MMBtu | 0 kWh | \$5 | 19.7 yrs | |
| | MTHW | 2 | Control Valve | 1.5 | Removable Blanket | 1 | 4.1 | 5110 | 155.80 | \$156 | 1.4 MMBtu | 0 kWh | \$11 | 13.6 yrs | |
| | MTHW | 2 | Flange | 1.5 | Removable Blanket | 4 | 7.2 | 5110 | 87.60 | \$350 | 2.5 MMBtu | 0 kWh | \$20 | 17.5 yrs | |
| | MTHW | 2 | In-Line Pump | 1.5 | Removable Blanket | 2 | 10 | 5110 | 142.70 | \$285 | 3.5 MMBtu | 0 kWh | \$28 | 10.2 yrs | |
| | MTHW | 2 | In-Line Pump | 1.5 | Removable Blanket | 1 | 5 | 5110 | 142.70 | \$143 | 1.7 MMBtu | 0 kWh | \$14 | 10.2 yrs | |
| | MTHW | 2 | Straight Pipe | 2 | Cellular Glass | 2 | 2 | 5110 | 36.10 | \$72 | 0.7 MMBtu | 0 kWh | \$6 | 12.4 yrs | |
| | MTHW | 2 | Straight Pipe | 2 | Cellular Glass | 31 | 31 | 5110 | 36.10 | \$1,120 | 11.3 MMBtu | 0 kWh | \$91 | 12.4 yrs | |
| | MTHW | 2 | T Intersection | 2 | Cellular Glass | 1 | 1.2 | 5110 | 37.70 | \$38 | 0.4 MMBtu | 0 kWh | \$4 | 10.7 yrs | |
| | MTHW | 2 | Triple Duty Valve | 1.5 | Removable Blanket | 1 | 5 | 5110 | 123.30 | \$123 | 1.7 MMBtu | 0 kWh | \$14 | 8.9 yrs | |
| | MTHW | 3 | 90 Degree Elbow | 2 | Cellular Glass | 2 | 3.6 | 5110 | 40.40 | \$161 | 3.8 MMBtu | 0 kWh | \$30 | 5.4 yrs | |
| | MTHW | 3 | Control Valve | 1.5 | Removable Blanket | 1 | 4.1 | 5110 | 188.30 | \$188 | 2.0 MMBtu | 0 kWh | \$16 | 11.5 yrs | |
| | MTHW | 3 | Flange | 1.5 | Removable Blanket | 7 | 12.6 | 5110 | 87.60 | \$613 | 6.3 MMBtu | 0 kWh | \$50 | 12.2 yrs | |
| | MTHW | 3 | Flange | 2 | Cellular Glass | 4 | 7.2 | 5110 | 37.10 | \$148 | 3.8 MMBtu | 0 kWh | \$30 | 4.9 yrs | |
| | MTHW | 3 | Gate Valve | 1.5 | Removable Blanket | 1 | 5 | 5110 | 155.80 | \$156 | 2.5 MMBtu | 0 kWh | \$20 | 7.8 yrs | |
| | MTHW | 3 | Straight Pipe | 2 | Cellular Glass | 6 | 6 | 5110 | 37.10 | \$223 | 3.1 MMBtu | 0 kWh | \$25 | 8.9 yrs | |
| | MTHW | 3 | Strainer | 1.5 | Removable Blanket | 1 | 5 | 5110 | 123.30 | \$123 | 2.5 MMBtu | 0 kWh | \$20 | 6.2 yrs | |
| | MTHW | 3 | T Intersection | 2 | Cellular Glass | 6 | 7.2 | 5110 | 40.40 | \$242 | 3.8 MMBtu | 0 kWh | \$30 | 8.1 yrs | |
| | MTHW | 3 | Triple Duty Valve | 1.5 | Removable Blanket | 2 | 10 | 5110 | 123.30 | \$247 | 5.0 MMBtu | 0 kWh | \$40 | 6.2 yrs | |
| | MTHW | 4 | Butterfly Valve | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 123.30 | \$247 | 5.1 MMBtu | 0 kWh | \$41 | 6.0 yrs | |
| | MTHW | 4 | Gate Valve | 1.5 | Removable Blanket | 1 | 5 | 5110 | 188.30 | \$188 | 3.1 MMBtu | 0 kWh | \$25 | 7.5 yrs | |
| | MTHW | 4 | Straight Pipe | 2 | Cellular Glass | 6 | 6 | 5110 | 38.40 | \$231 | 3.9 MMBtu | 0 kWh | \$31 | 7.3 yrs | |
| | MTHW | 4 | Straight Pipe | 2 | Cellular Glass | 3 | 3 | 5110 | 38.40 | \$115 | 2.0 MMBtu | 0 kWh | \$16 | 7.3 yrs | |
| | MTHW | 4 | T Intersection | 2 | Cellular Glass | 1 | 1.2 | 5110 | 43.60 | \$44 | 0.8 MMBtu | 0 kWh | \$6 | 6.9 yrs | |
| | MTHW Total | | | | | | | | | | \$6,732 | 86.4 MMBtu | 0 kWh | \$691 | 9.7 yrs |
| Eugene Administration Building Total | | | | | | | | | | \$6,732 | 86.4 MMBtu | 0 kWh | \$691 | 9.7 yrs | |
| Hawthorne Elementary School | MTHW | 2 | Check Valve | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 123.30 | \$247 | 2.9 MMBtu | 0 kWh | \$23 | 10.8 yrs | |
| | MTHW | 2 | Flange | 1.5 | Removable Blanket | 9 | 16.2 | 5110 | 87.60 | \$789 | 5.6 MMBtu | 0 kWh | \$45 | 17.5 yrs | |
| | MTHW | 2 | In-Line Pump | 1.5 | Removable Blanket | 2 | 10 | 5110 | 142.70 | \$285 | 3.5 MMBtu | 0 kWh | \$28 | 10.2 yrs | |
| | MTHW | 3 | Check Valve | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 155.80 | \$312 | 4.1 MMBtu | 0 kWh | \$33 | 9.6 yrs | |
| | MTHW | 3 | End Cap | 2 | Cellular Glass | 1 | 1.8 | 5110 | 124.50 | \$125 | 0.9 MMBtu | 0 kWh | \$8 | 16.6 yrs | |
| | MTHW | 3 | Flange | 1.5 | Removable Blanket | 4 | 7.2 | 5110 | 87.60 | \$350 | 3.6 MMBtu | 0 kWh | \$29 | 12.2 yrs | |
| | MTHW | 3 | In-Line Pump | 1.5 | Removable Blanket | 2 | 10 | 5110 | 175.20 | \$350 | 5.0 MMBtu | 0 kWh | \$40 | 8.8 yrs | |
| | MTHW | 16 | Flange | 2 | Cellular Glass | 1 | 1.8 | 5110 | 56.20 | \$56 | 3.8 MMBtu | 0 kWh | \$30 | 1.9 yrs | |
| | MTHW Total | | | | | | | | | | \$2,514 | 29.3 MMBtu | 0 kWh | \$234 | 10.7 yrs |
| | LPS | 2 | Bonnet | 1.5 | Removable Blanket | 4 | 7.2 | 5110 | 98.90 | \$396 | 3.3 MMBtu | 0 kWh | \$26 | 14.9 yrs | |
| | LPS | 2 | Control Valve | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 155.80 | \$312 | 3.8 MMBtu | 0 kWh | \$30 | 10.3 yrs | |
| | LPS | 2 | Flange | 1.5 | Removable Blanket | 4 | 7.2 | 5110 | 87.60 | \$350 | 3.3 MMBtu | 0 kWh | \$26 | 13.2 yrs | |
| | LPS | 2 | Strainer | 1.5 | Removable Blanket | 2 | 10 | 5110 | 123.30 | \$247 | 4.6 MMBtu | 0 kWh | \$37 | 6.7 yrs | |
| | LPS | 4 | Bonnet | 1.5 | Removable Blanket | 1 | 1.8 | 5110 | 155.80 | \$156 | 1.5 MMBtu | 0 kWh | \$12 | 13.1 yrs | |
| | LPS | 4 | Flange | 1.5 | Removable Blanket | 1 | 1.8 | 5110 | 168.90 | \$169 | 1.5 MMBtu | 0 kWh | \$12 | 14.2 yrs | |
| | LPS | 6 | Bonnet | 1.5 | Removable Blanket | 5 | 9 | 5110 | 204.50 | \$1,023 | 10.6 MMBtu | 0 kWh | \$85 | 12.1 yrs | |
| | LPS | 8 | Bonnet | 1.5 | Removable Blanket | 2 | 3.6 | 5110 | 204.50 | \$409 | 5.4 MMBtu | 0 kWh | \$43 | 9.5 yrs | |
| | LPS Total | | | | | | | | | | \$3,061 | 33.9 MMBtu | 0 kWh | \$271 | 11.3 yrs |
| | Cond | 0.75 | 90 Degree Elbow | 1.5 | Cellular Glass | 10 | 18 | 5110 | 31.80 | \$318 | 2.3 MMBtu | 0 kWh | \$19 | 17.1 yrs | |
| | Cond | 0.75 | Ball Valve | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 74.50 | \$149 | 1.0 MMBtu | 0 kWh | \$8 | 18.1 yrs | |
| | Cond | 0.75 | Check Valve | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 90.80 | \$182 | 1.0 MMBtu | 0 kWh | \$8 | 22.0 yrs | |
| | Cond | 0.75 | Steam Trap | 1.5 | Removable Blanket | 2 | 8.8 | 5110 | 107.00 | \$214 | 1.1 MMBtu | 0 kWh | \$9 | 24.2 yrs | |

Teaneck Public Schools Energy Savings Plan

TEANECK PUBLIC SCHOOLS, NJ MECHANICAL INSULATION SAVINGS SUMMARY

| Building | Fluid Type | Pipe Dia (") or Tank Surface Area(SF)* | Component | Insulation Thickness (") | Proposed Insulation Type | Quantity or Length | Total Eq Length(LF) or Total Area(SF)* | Heating or Cooling Hrs/Yr | Price per Unit | Total Investment | Fuel Savings MMBTU | Electric Savings kWh | Total Savings | Payback | |
|-----------------------------|--|--|--------------------|--------------------------|--------------------------|--------------------|--|---------------------------|----------------|------------------|--------------------|----------------------|---------------|-----------------|-----------------|
| Hawthorne Elementary School | Cond | 0.75 | Straight Pipe | 1.5 | Cellular Glass | 12 | 12 | 5110 | 32.70 | \$392 | 1.5 MMBtu | 0 kWh | \$12 | 31.6 yrs | |
| | Cond | 1 | 90 Degree Elbow | 1.5 | Cellular Glass | 10 | 18 | 5110 | 32.30 | \$323 | 2.9 MMBtu | 0 kWh | \$23 | 14.1 yrs | |
| | Cond | 1 | In-Line Pump | 1.5 | Removable Blanket | 2 | 10 | 5110 | 118.30 | \$237 | 1.6 MMBtu | 0 kWh | \$12 | 19.0 yrs | |
| | Cond | 1 | Steam Trap | 1.5 | Removable Blanket | 1 | 4.4 | 5110 | 116.80 | \$117 | 0.7 MMBtu | 0 kWh | \$5 | 21.3 yrs | |
| | Cond | 1 | Straight Pipe | 1.5 | Cellular Glass | 3 | 3 | 5110 | 32.90 | \$99 | 0.5 MMBtu | 0 kWh | \$4 | 25.8 yrs | |
| | Cond | 1 | Straight Pipe | 1.5 | Cellular Glass | 45 | 45 | 5110 | 32.90 | \$1,482 | 7.2 MMBtu | 0 kWh | \$57 | 25.8 yrs | |
| | Cond | 1 | Strainer | 1.5 | Removable Blanket | 1 | 5 | 5110 | 100.50 | \$101 | 0.8 MMBtu | 0 kWh | \$6 | 16.1 yrs | |
| | Cond | 1.5 | 90 Degree Elbow | 2 | Cellular Glass | 3 | 5.4 | 5110 | 37.70 | \$113 | 1.3 MMBtu | 0 kWh | \$10 | 11.3 yrs | |
| | Cond | 1.5 | 90 Degree Elbow | 2 | Cellular Glass | 5 | 9 | 5110 | 37.70 | \$188 | 2.1 MMBtu | 0 kWh | \$17 | 11.3 yrs | |
| | Cond | 1.5 | Steam Trap | 1.5 | Removable Blanket | 2 | 8.8 | 5110 | 123.30 | \$247 | 1.9 MMBtu | 0 kWh | \$15 | 15.9 yrs | |
| | Cond | 1.5 | Straight Pipe | 2 | Cellular Glass | 15 | 15 | 5110 | 35.80 | \$536 | 3.5 MMBtu | 0 kWh | \$28 | 19.3 yrs | |
| | Cond | 1.5 | Straight Pipe | 2 | Cellular Glass | 28 | 28 | 5110 | 35.80 | \$1,001 | 6.5 MMBtu | 0 kWh | \$52 | 19.3 yrs | |
| | Cond | 1.5 | Strainer | 1.5 | Removable Blanket | 1 | 5 | 5110 | 105.40 | \$105 | 1.1 MMBtu | 0 kWh | \$9 | 12.0 yrs | |
| | Cond | 1.5 | T Intersection | 2 | Cellular Glass | 4 | 4.8 | 5110 | 37.70 | \$151 | 1.1 MMBtu | 0 kWh | \$9 | 16.9 yrs | |
| | Cond | 2 | 90 Degree Elbow | 2 | Cellular Glass | 1 | 1.8 | 5110 | 37.70 | \$38 | 0.5 MMBtu | 0 kWh | \$4 | 9.2 yrs | |
| | Cond | 2 | 90 Degree Elbow | 2 | Cellular Glass | 19 | 34.2 | 5110 | 37.70 | \$716 | 9.7 MMBtu | 0 kWh | \$78 | 9.2 yrs | |
| | Cond | 2 | Ball Valve | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 123.30 | \$247 | 2.2 MMBtu | 0 kWh | \$18 | 13.9 yrs | |
| | Cond | 2 | Check Valve | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 123.30 | \$247 | 2.2 MMBtu | 0 kWh | \$18 | 13.9 yrs | |
| | Cond | 2 | Straight Pipe | 2 | Cellular Glass | 16 | 16 | 5110 | 36.10 | \$578 | 4.6 MMBtu | 0 kWh | \$36 | 15.8 yrs | |
| | Cond | 2 | Straight Pipe | 2 | Cellular Glass | 60 | 60 | 5110 | 36.10 | \$2,167 | 17.1 MMBtu | 0 kWh | \$137 | 15.8 yrs | |
| | Cond | 2 | T Intersection | 2 | Cellular Glass | 6 | 7.2 | 5110 | 37.70 | \$226 | 2.1 MMBtu | 0 kWh | \$16 | 13.8 yrs | |
| | Cond | 3 | 90 Degree Elbow | 2 | Cellular Glass | 2 | 3.6 | 5110 | 40.40 | \$81 | 1.5 MMBtu | 0 kWh | \$12 | 6.9 yrs | |
| | Cond | 3 | T Intersection | 2 | Cellular Glass | 2 | 2.4 | 5110 | 40.40 | \$81 | 1.0 MMBtu | 0 kWh | \$8 | 10.3 yrs | |
| | Cond | 56.9 | Condensate Tank | 2 | Cellular Glass | 1 | 56.9 | 5110 | 44.90 | \$2,553 | 25.4 MMBtu | 0 kWh | \$203 | 12.6 yrs | |
| | Cond Total | | | | | | | | | | \$12,886 | 104.3 MMBtu | 0 kWh | \$835 | 15.4 yrs |
| | Hawthorne Elementary School Total | | | | | | | | | | \$18,461 | 167.5 MMBtu | 0 kWh | \$1,340 | 13.8 yrs |
| | Lowell Elementary School | MTHW | 3 | 90 Degree Elbow | 2 | Cellular Glass | 1 | 1.8 | 5110 | 40.40 | \$40 | 0.9 MMBtu | 0 kWh | \$8 | 5.4 yrs |
| | | MTHW | 3 | Balance Valve | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 155.80 | \$312 | 4.1 MMBtu | 0 kWh | \$33 | 9.6 yrs |
| | | MTHW | 3 | Butterfly Valve | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 107.00 | \$214 | 4.1 MMBtu | 0 kWh | \$33 | 6.6 yrs |
| | | MTHW | 3 | Centrifugal Pump | 1.5 | Removable Blanket | 2 | 10 | 5110 | 167.20 | \$334 | 5.0 MMBtu | 0 kWh | \$40 | 8.4 yrs |
| MTHW | | 3 | End Cap | 2 | Cellular Glass | 1 | 1.8 | 5110 | 124.50 | \$125 | 0.9 MMBtu | 0 kWh | \$8 | 16.6 yrs | |
| MTHW | | 3 | Flange | 2 | Cellular Glass | 5 | 9 | 5110 | 37.10 | \$186 | 4.7 MMBtu | 0 kWh | \$38 | 4.9 yrs | |
| MTHW | | 3 | Flex Fitting | 2 | Cellular Glass | 4 | 6 | 5110 | 41.10 | \$164 | 3.1 MMBtu | 0 kWh | \$25 | 6.6 yrs | |
| MTHW | | 3 | Straight Pipe | 2 | Cellular Glass | 6 | 6 | 5110 | 37.10 | \$223 | 3.1 MMBtu | 0 kWh | \$25 | 8.9 yrs | |
| MTHW | | 3 | Straight Pipe | 2 | Cellular Glass | 9 | 9 | 5110 | 37.10 | \$334 | 4.7 MMBtu | 0 kWh | \$38 | 8.9 yrs | |
| MTHW | | 3 | Suction Diffuser | 1.5 | Removable Blanket | 2 | 8.8 | 5110 | 188.30 | \$377 | 4.4 MMBtu | 0 kWh | \$35 | 10.8 yrs | |
| MTHW | | 15.3 | Air Separator Tank | 2 | Cellular Glass | 1 | 15.3 | 5110 | 44.90 | \$687 | 8.8 MMBtu | 0 kWh | \$70 | 9.8 yrs | |
| MTHW | | 16 | Flange | 2 | Cellular Glass | 1 | 1.8 | 5110 | 56.20 | \$56 | 3.8 MMBtu | 0 kWh | \$30 | 1.9 yrs | |
| MTHW Total | | | | | | | | | | \$3,051 | 47.6 MMBtu | 0 kWh | \$381 | 8.0 yrs | |
| LPS | | 1 | Control Valve | 2.5 | Cellular Glass | 1 | 4.1 | 5110 | 72.40 | \$72 | 1.2 MMBtu | 0 kWh | \$9 | 7.8 yrs | |
| LPS | | 1 | Gate Valve | 1.5 | Removable Blanket | 2 | 10 | 5110 | 82.70 | \$165 | 2.7 MMBtu | 0 kWh | \$21 | 7.8 yrs | |
| LPS | | 1 | Straight Pipe | 2.5 | Cellular Glass | 6 | 6 | 5110 | 65.30 | \$392 | 1.7 MMBtu | 0 kWh | \$14 | 28.8 yrs | |
| LPS | | 1 | Strainer | 1.5 | Removable Blanket | 1 | 5 | 5110 | 100.50 | \$101 | 1.3 MMBtu | 0 kWh | \$11 | 9.5 yrs | |
| LPS | | 2 | Control Valve | 1.5 | Removable Blanket | 1 | 4.1 | 5110 | 155.80 | \$156 | 1.9 MMBtu | 0 kWh | \$15 | 10.3 yrs | |
| LPS | | 2 | Flange | 2.5 | Cellular Glass | 2 | 3.6 | 5110 | 66.40 | \$133 | 1.8 MMBtu | 0 kWh | \$14 | 9.4 yrs | |
| LPS | | 2 | Straight Pipe | 2.5 | Cellular Glass | 3 | 3 | 5110 | 66.40 | \$199 | 1.5 MMBtu | 0 kWh | \$12 | 17.0 yrs | |
| LPS | 2 | Strainer | 1.5 | Removable Blanket | 1 | 5 | 5110 | 123.30 | \$123 | 2.3 MMBtu | 0 kWh | \$18 | 6.7 yrs | | |
| LPS | 4 | Flange | 3 | Cellular Glass | 1 | 1.8 | 5110 | 72.30 | \$72 | 1.6 MMBtu | 0 kWh | \$13 | 5.7 yrs | | |
| LPS | 6 | Bonnet | 1.5 | Removable Blanket | 8 | 14.4 | 5110 | 204.50 | \$1,636 | 16.9 MMBtu | 0 kWh | \$135 | 12.1 yrs | | |
| LPS | 6 | Flange | 3 | Cellular Glass | 2 | 3.6 | 5110 | 75.30 | \$151 | 4.5 MMBtu | 0 kWh | \$36 | 4.1 yrs | | |
| LPS | 6 | Flange | 3 | Cellular Glass | 1 | 1.8 | 5110 | 75.30 | \$75 | 2.3 MMBtu | 0 kWh | \$18 | 4.1 yrs | | |
| LPS | 6 | Straight Pipe | 3 | Cellular Glass | 3 | 3 | 5110 | 75.30 | \$226 | 3.8 MMBtu | 0 kWh | \$30 | 7.5 yrs | | |
| LPS | 10 | End Cap | 1.5 | Removable Blanket | 3 | 5.4 | 5110 | 350.80 | \$1,052 | 9.9 MMBtu | 0 kWh | \$79 | 13.4 yrs | | |
| LPS | 10 | Straight Pipe | 3 | Cellular Glass | 1 | 1 | 5110 | 82.80 | \$83 | 2.0 MMBtu | 0 kWh | \$16 | 5.3 yrs | | |
| LPS Total | | | | | | | | | | \$4,637 | 55.2 MMBtu | 0 kWh | \$441 | 10.5 yrs | |
| Cond | 0.75 | 45 Degree Elbow | 1.5 | Cellular Glass | 2 | 2 | 5110 | 31.80 | \$64 | 0.3 MMBtu | 0 kWh | \$2 | 30.7 yrs | | |
| Cond | 0.75 | 90 Degree Elbow | 1.5 | Cellular Glass | 4 | 7.2 | 5110 | 31.80 | \$127 | 0.9 MMBtu | 0 kWh | \$7 | 17.1 yrs | | |
| Cond | 0.75 | Straight Pipe | 1.5 | Cellular Glass | 18 | 18 | 5110 | 32.70 | \$588 | 2.3 MMBtu | 0 kWh | \$19 | 31.6 yrs | | |

Teaneck Public Schools Energy Savings Plan

TEANECK PUBLIC SCHOOLS, NJ MECHANICAL INSULATION SAVINGS SUMMARY

| Building | Fluid Type | Pipe Dia (") or Tank Surface Area(SF) ^a | Component | Insulation Thickness (") | Proposed Insulation Type | Quantity or Length | Total Eq Length(LF) or Total Area(SF) ^a | Heating or Cooling Hrs/Yr | Price per Unit | Total Investment | Fuel Savings MMBtu | Electric Savings kWh | Total Savings | Payback | |
|---------------------------------------|-------------------|--|-----------------|--------------------------|--------------------------|--------------------|--|---------------------------|----------------|------------------|--------------------|----------------------|----------------|-----------------|----------------|
| Lowell Elementary School | Cond | 1 | 90 Degree Elbow | 1.5 | Cellular Glass | 2 | 3.6 | 5110 | 32.30 | \$65 | 0.6 MMBtu | 0 kWh | \$5 | 14.1 yrs | |
| | Cond | 1 | 90 Degree Elbow | 1.5 | Cellular Glass | 4 | 7.2 | 5110 | 32.30 | \$129 | 1.1 MMBtu | 0 kWh | \$9 | 14.1 yrs | |
| | Cond | 1 | 90 Degree Elbow | 1.5 | Cellular Glass | 3 | 5.4 | 5110 | 32.30 | \$97 | 0.9 MMBtu | 0 kWh | \$7 | 14.1 yrs | |
| | Cond | 1 | 90 Degree Elbow | 1.5 | Cellular Glass | 7 | 12.6 | 5110 | 32.30 | \$226 | 2.0 MMBtu | 0 kWh | \$16 | 14.1 yrs | |
| | Cond | 1 | Bonnet | 1.5 | Removable Blanket | 3 | 5.4 | 5110 | 74.50 | \$224 | 0.8 MMBtu | 0 kWh | \$7 | 33.2 yrs | |
| | Cond | 1 | Gate Valve | 1.5 | Removable Blanket | 1 | 5 | 5110 | 82.70 | \$83 | 0.8 MMBtu | 0 kWh | \$6 | 13.3 yrs | |
| | Cond | 1 | Steam Trap | 1.5 | Removable Blanket | 2 | 8.8 | 5110 | 116.80 | \$234 | 1.4 MMBtu | 0 kWh | \$11 | 21.3 yrs | |
| | Cond | 1 | Steam Trap | 1.5 | Removable Blanket | 1 | 4.4 | 5110 | 116.80 | \$234 | 1.4 MMBtu | 0 kWh | \$11 | 21.3 yrs | |
| | Cond | 1 | Straight Pipe | 1.5 | Cellular Glass | 2 | 2 | 5110 | 32.90 | \$132 | 0.6 MMBtu | 0 kWh | \$5 | 25.8 yrs | |
| | Cond | 1 | Straight Pipe | 1.5 | Cellular Glass | 12 | 12 | 5110 | 32.90 | \$395 | 1.9 MMBtu | 0 kWh | \$15 | 25.8 yrs | |
| | Cond | 1 | Straight Pipe | 1.5 | Cellular Glass | 24 | 24 | 5110 | 32.90 | \$791 | 3.8 MMBtu | 0 kWh | \$31 | 25.8 yrs | |
| | Cond | 1 | Straight Pipe | 1.5 | Cellular Glass | 69 | 69 | 5110 | 32.90 | \$2,273 | 11.0 MMBtu | 0 kWh | \$88 | 25.8 yrs | |
| | Cond | 1 | Strainer | 1.5 | Cellular Glass | 2 | 10 | 5110 | 36.70 | \$73 | 1.6 MMBtu | 0 kWh | \$13 | 5.8 yrs | |
| | Cond | 1 | Strainer | 1.5 | Removable Blanket | 1 | 5 | 5110 | 100.50 | \$101 | 0.8 MMBtu | 0 kWh | \$6 | 16.1 yrs | |
| | Cond | 1.25 | 90 Degree Elbow | 1.5 | Cellular Glass | 2 | 3.6 | 5110 | 32.30 | \$65 | 0.7 MMBtu | 0 kWh | \$6 | 11.3 yrs | |
| | Cond | 1.25 | 90 Degree Elbow | 1.5 | Cellular Glass | 5 | 9 | 5110 | 32.30 | \$162 | 1.8 MMBtu | 0 kWh | \$14 | 11.3 yrs | |
| | Cond | 1.25 | Gate Valve | 1.5 | Removable Blanket | 2 | 10 | 5110 | 82.70 | \$165 | 1.9 MMBtu | 0 kWh | \$16 | 10.7 yrs | |
| | Cond | 1.25 | Steam Trap | 1.5 | Removable Blanket | 1 | 4.4 | 5110 | 116.80 | \$234 | 1.7 MMBtu | 0 kWh | \$14 | 17.1 yrs | |
| | Cond | 1.25 | Straight Pipe | 1.5 | Cellular Glass | 2 | 2 | 5110 | 32.90 | \$66 | 0.4 MMBtu | 0 kWh | \$3 | 20.7 yrs | |
| | Cond | 1.25 | Straight Pipe | 1.5 | Cellular Glass | 30 | 30 | 5110 | 32.90 | \$988 | 6.0 MMBtu | 0 kWh | \$48 | 20.7 yrs | |
| | Cond | 1.25 | Strainer | 1.5 | Removable Blanket | 1 | 5 | 5110 | 100.50 | \$201 | 1.9 MMBtu | 0 kWh | \$16 | 13.0 yrs | |
| | Cond | 1.5 | 45 Degree Elbow | 2 | Cellular Glass | 4 | 4 | 5110 | 37.70 | \$151 | 0.9 MMBtu | 0 kWh | \$7 | 20.3 yrs | |
| | Cond | 1.5 | 90 Degree Elbow | 2 | Cellular Glass | 22 | 39.6 | 5110 | 37.70 | \$829 | 9.2 MMBtu | 0 kWh | \$73 | 11.3 yrs | |
| | Cond | 1.5 | 90 Degree Elbow | 2 | Cellular Glass | 7 | 12.6 | 5110 | 37.70 | \$264 | 2.9 MMBtu | 0 kWh | \$23 | 11.3 yrs | |
| | Cond | 1.5 | Gate Valve | 1.5 | Removable Blanket | 4 | 20 | 5110 | 107.00 | \$428 | 4.4 MMBtu | 0 kWh | \$35 | 12.2 yrs | |
| | Cond | 1.5 | In-Line Pump | 2 | Cellular Glass | 3 | 15 | 5110 | 42.40 | \$127 | 3.5 MMBtu | 0 kWh | \$28 | 4.6 yrs | |
| | Cond | 1.5 | Steam Trap | 1.5 | Removable Blanket | 1 | 4.4 | 5110 | 123.30 | \$123 | 1.0 MMBtu | 0 kWh | \$8 | 15.9 yrs | |
| | Cond | 1.5 | Straight Pipe | 2 | Cellular Glass | 53 | 53 | 5110 | 35.80 | \$1,895 | 12.3 MMBtu | 0 kWh | \$98 | 19.3 yrs | |
| | Cond | 1.5 | Straight Pipe | 2 | Cellular Glass | 103 | 103 | 5110 | 35.80 | \$3,682 | 23.9 MMBtu | 0 kWh | \$191 | 19.3 yrs | |
| | Cond | 1.5 | T Intersection | 2 | Cellular Glass | 3 | 3.6 | 5110 | 37.70 | \$226 | 1.7 MMBtu | 0 kWh | \$13 | 16.9 yrs | |
| | Cond | 2 | 45 Degree Elbow | 2 | Cellular Glass | 2 | 2 | 5110 | 37.70 | \$75 | 0.6 MMBtu | 0 kWh | \$5 | 16.5 yrs | |
| | Cond | 2 | 90 Degree Elbow | 2 | Cellular Glass | 6 | 10.8 | 5110 | 37.70 | \$226 | 3.1 MMBtu | 0 kWh | \$25 | 9.2 yrs | |
| | Cond | 2 | Gate Valve | 1.5 | Removable Blanket | 1 | 5 | 5110 | 123.30 | \$123 | 1.4 MMBtu | 0 kWh | \$11 | 11.4 yrs | |
| | Cond | 2 | Straight Pipe | 2 | Cellular Glass | 24 | 24 | 5110 | 36.10 | \$867 | 6.8 MMBtu | 0 kWh | \$55 | 15.8 yrs | |
| | Cond | 2 | T Intersection | 2 | Cellular Glass | 1 | 1.2 | 5110 | 37.70 | \$38 | 0.3 MMBtu | 0 kWh | \$3 | 13.8 yrs | |
| | Cond | 2.5 | 45 Degree Elbow | 2 | Cellular Glass | 4 | 4 | 5110 | 40.40 | \$161 | 1.4 MMBtu | 0 kWh | \$11 | 14.9 yrs | |
| | Cond | 2.5 | 90 Degree Elbow | 2 | Cellular Glass | 4 | 7.2 | 5110 | 40.40 | \$161 | 2.4 MMBtu | 0 kWh | \$20 | 8.3 yrs | |
| | Cond | 2.5 | 90 Degree Elbow | 2 | Cellular Glass | 6 | 10.8 | 5110 | 40.40 | \$242 | 3.7 MMBtu | 0 kWh | \$29 | 8.3 yrs | |
| | Cond | 2.5 | Flange | 2 | Cellular Glass | 2 | 3.6 | 5110 | 36.70 | \$73 | 1.2 MMBtu | 0 kWh | \$10 | 7.5 yrs | |
| | Cond | 2.5 | Flange | 2 | Cellular Glass | 3 | 5.4 | 5110 | 36.70 | \$110 | 1.8 MMBtu | 0 kWh | \$15 | 7.5 yrs | |
| | Cond | 2.5 | Gate Valve | 1.5 | Removable Blanket | 2 | 10 | 5110 | 123.30 | \$247 | 3.2 MMBtu | 0 kWh | \$26 | 9.5 yrs | |
| | Cond | 2.5 | Straight Pipe | 2 | Cellular Glass | 24 | 24 | 5110 | 36.70 | \$880 | 8.2 MMBtu | 0 kWh | \$65 | 13.5 yrs | |
| | Cond | 2.5 | Straight Pipe | 2 | Cellular Glass | 84 | 84 | 5110 | 36.70 | \$3,079 | 28.5 MMBtu | 0 kWh | \$228 | 13.5 yrs | |
| | Cond | 4 | Straight Pipe | 2 | Cellular Glass | 4 | 4 | 5110 | 38.40 | \$154 | 2.0 MMBtu | 0 kWh | \$16 | 9.4 yrs | |
| | Cond | 4 | Straight Pipe | 2 | Cellular Glass | 6 | 6 | 5110 | 38.40 | \$231 | 3.1 MMBtu | 0 kWh | \$25 | 9.4 yrs | |
| | Cond | 4 | T Intersection | 2 | Cellular Glass | 6 | 7.2 | 5110 | 43.60 | \$261 | 3.7 MMBtu | 0 kWh | \$29 | 8.9 yrs | |
| | Cond | 4 | T Intersection | 2 | Cellular Glass | 3 | 3.6 | 5110 | 43.60 | \$131 | 1.8 MMBtu | 0 kWh | \$15 | 8.9 yrs | |
| Cond Total | | | | | | | | | | \$22,499 | 179.7 MMBtu | 0 kWh | \$1,438 | 15.6 yrs | |
| Lowell Elementary School Total | | | | | | | | | | \$30,186 | 282.5 MMBtu | 0 kWh | \$2,260 | 13.4 yrs | |
| Teaneck High School | MTHW | 3 | Butterfly Valve | 1.5 | Removable Blanket | 1 | 4.1 | 5110 | 107.00 | \$107 | 2.0 MMBtu | 0 kWh | \$16 | 6.6 yrs | |
| | MTHW | 3 | Flange | 1.5 | Removable Blanket | 1 | 1.8 | 5110 | 87.60 | \$88 | 0.9 MMBtu | 0 kWh | \$7 | 12.2 yrs | |
| | MTHW Total | | | | | | | | | | \$195 | 2.9 MMBtu | 0 kWh | \$23 | 8.3 yrs |
| | LPS | 1.5 | 90 Degree Elbow | 2.5 | Cellular Glass | 2 | 3.6 | 5110 | 69.50 | \$139 | 1.4 MMBtu | 0 kWh | \$11 | 12.1 yrs | |
| | LPS | 1.5 | Control Valve | 1.5 | Removable Blanket | 1 | 4.1 | 5110 | 123.30 | \$247 | 3.1 MMBtu | 0 kWh | \$25 | 10.1 yrs | |
| | LPS | 1.5 | Flange | 1.5 | Removable Blanket | 2 | 3.6 | 5110 | 71.40 | \$143 | 1.3 MMBtu | 0 kWh | \$11 | 13.3 yrs | |
| | LPS | 1.5 | Straight Pipe | 2.5 | Cellular Glass | 3 | 3 | 5110 | 66.00 | \$198 | 1.2 MMBtu | 0 kWh | \$10 | 20.7 yrs | |
| | LPS | 1.5 | Straight Pipe | 2.5 | Cellular Glass | 19 | 19 | 5110 | 66.00 | \$1,254 | 7.6 MMBtu | 0 kWh | \$61 | 20.7 yrs | |
| | LPS | 1.5 | Strainer | 1.5 | Removable Blanket | 1 | 5 | 5110 | 105.40 | \$211 | 3.7 MMBtu | 0 kWh | \$30 | 7.0 yrs | |
| | LPS | 2.5 | 90 Degree Elbow | 2.5 | Cellular Glass | 2 | 3.6 | 5110 | 72.70 | \$145 | 2.1 MMBtu | 0 kWh | \$17 | 8.7 yrs | |

Teaneck Public Schools Energy Savings Plan

TEANECK PUBLIC SCHOOLS, NJ MECHANICAL INSULATION SAVINGS SUMMARY

| Building | Fluid Type | Pipe Dia (") or Tank Surface Area(SF)* | Component | Insulation Thickness (") | Proposed Insulation Type | Quantity or Length | Total Eq Length(LF) or Total Area(SF)* | Heating or Cooling Hrs/Yr | Price per Unit | Total Investment | Fuel Savings MMBTU | Electric Savings kWh | Total Savings | Payback |
|---------------------|------------------|--|-----------------|--------------------------|--------------------------|--------------------|--|---------------------------|----------------|------------------|--------------------|----------------------|---------------|----------------|
| Teaneck High School | LPS | 2.5 | Control Valve | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 155.80 | \$312 | 4.5 MMBtu | 0 kWh | \$36 | 8.7 yrs |
| | LPS | 2.5 | Flange | 2.5 | Cellular Glass | 7 | 12.6 | 5110 | 67.60 | \$473 | 7.3 MMBtu | 0 kWh | \$59 | 8.1 yrs |
| | LPS | 2.5 | Gate Valve | 1.5 | Removable Blanket | 2 | 10 | 5110 | 123.30 | \$247 | 5.5 MMBtu | 0 kWh | \$44 | 5.6 yrs |
| | LPS | 2.5 | Straight Pipe | 2.5 | Cellular Glass | 5 | 5 | 5110 | 67.60 | \$338 | 2.9 MMBtu | 0 kWh | \$23 | 14.5 yrs |
| | LPS | 2.5 | Strainer | 1.5 | Removable Blanket | 2 | 10 | 5110 | 123.30 | \$247 | 5.5 MMBtu | 0 kWh | \$44 | 5.6 yrs |
| | LPS | 3 | Bonnet | 1.5 | Removable Blanket | 1 | 1.8 | 5110 | 123.30 | \$123 | 1.2 MMBtu | 0 kWh | \$9 | 13.0 yrs |
| | LPS | 3 | Bonnet | 1.5 | Removable Blanket | 3 | 5.4 | 5110 | 123.30 | \$370 | 3.5 MMBtu | 0 kWh | \$28 | 13.0 yrs |
| | LPS | 3 | Control Valve | 1.5 | Removable Blanket | 1 | 4.1 | 5110 | 188.30 | \$377 | 5.4 MMBtu | 0 kWh | \$43 | 8.7 yrs |
| | LPS | 3 | Flange | 1.5 | Removable Blanket | 2 | 3.6 | 5110 | 87.60 | \$175 | 2.4 MMBtu | 0 kWh | \$19 | 9.3 yrs |
| | LPS | 3 | Flange | 2.5 | Cellular Glass | 2 | 3.6 | 5110 | 68.10 | \$136 | 2.5 MMBtu | 0 kWh | \$20 | 6.8 yrs |
| | LPS | 3 | Gate Valve | 1.5 | Removable Blanket | 1 | 5 | 5110 | 155.80 | \$156 | 3.3 MMBtu | 0 kWh | \$26 | 5.9 yrs |
| | LPS | 3 | Straight Pipe | 2.5 | Cellular Glass | 3 | 3 | 5110 | 68.10 | \$204 | 2.1 MMBtu | 0 kWh | \$17 | 12.2 yrs |
| | LPS | 3 | Strainer | 1.5 | Removable Blanket | 1 | 5 | 5110 | 123.30 | \$123 | 3.3 MMBtu | 0 kWh | \$26 | 4.7 yrs |
| | LPS | 5 | 90 Degree Elbow | 3 | Cellular Glass | 1 | 1.8 | 5110 | 88.00 | \$88 | 1.9 MMBtu | 0 kWh | \$15 | 5.7 yrs |
| | LPS | 5 | Bonnet | 1.5 | Removable Blanket | 1 | 1.8 | 5110 | 155.80 | \$156 | 1.8 MMBtu | 0 kWh | \$14 | 10.8 yrs |
| | LPS | 5 | Flange | 1.5 | Removable Blanket | 1 | 1.8 | 5110 | 201.40 | \$201 | 1.8 MMBtu | 0 kWh | \$14 | 14.0 yrs |
| | LPS | 5 | Straight Pipe | 3 | Cellular Glass | 6 | 6 | 5110 | 74.20 | \$445 | 6.5 MMBtu | 0 kWh | \$52 | 8.6 yrs |
| | LPS | 8 | Bonnet | 1.5 | Removable Blanket | 1 | 1.8 | 5110 | 204.50 | \$205 | 2.7 MMBtu | 0 kWh | \$21 | 9.5 yrs |
| | LPS | 10 | Bonnet | 1.5 | Removable Blanket | 2 | 3.6 | 5110 | 220.80 | \$442 | 6.6 MMBtu | 0 kWh | \$53 | 8.4 yrs |
| | LPS Total | | | | | | | | | \$7,153 | 91.0 MMBtu | 0 kWh | \$728 | 9.8 yrs |
| Cond | | 1 | 90 Degree Elbow | 1.5 | Cellular Glass | 2 | 3.6 | 5110 | 32.30 | \$65 | 0.6 MMBtu | 0 kWh | \$5 | 14.1 yrs |
| Cond | | 1 | 90 Degree Elbow | 1.5 | Cellular Glass | 16 | 28.8 | 5110 | 32.30 | \$517 | 4.6 MMBtu | 0 kWh | \$37 | 14.1 yrs |
| Cond | | 1 | Gate Valve | 1.5 | Removable Blanket | 1 | 5 | 5110 | 82.70 | \$83 | 0.8 MMBtu | 0 kWh | \$6 | 13.3 yrs |
| Cond | | 1 | In-Line Pump | 1.5 | Removable Blanket | 2 | 10 | 5110 | 118.30 | \$237 | 1.6 MMBtu | 0 kWh | \$12 | 19.0 yrs |
| Cond | | 1 | Steam Trap | 1.5 | Removable Blanket | 1 | 4.4 | 5110 | 116.80 | \$117 | 0.7 MMBtu | 0 kWh | \$5 | 21.3 yrs |
| Cond | | 1 | Straight Pipe | 1.5 | Cellular Glass | 2 | 2 | 5110 | 32.90 | \$66 | 0.3 MMBtu | 0 kWh | \$3 | 25.8 yrs |
| Cond | | 1 | Straight Pipe | 1.5 | Cellular Glass | 48 | 48 | 5110 | 32.90 | \$1,581 | 7.7 MMBtu | 0 kWh | \$61 | 25.8 yrs |
| Cond | | 1 | Strainer | 1.5 | Removable Blanket | 1 | 5 | 5110 | 100.50 | \$101 | 0.8 MMBtu | 0 kWh | \$6 | 16.1 yrs |
| Cond | | 1.5 | 90 Degree Elbow | 2 | Cellular Glass | 4 | 7.2 | 5110 | 37.70 | \$301 | 3.3 MMBtu | 0 kWh | \$27 | 11.3 yrs |
| Cond | | 1.5 | 90 Degree Elbow | 2 | Cellular Glass | 3 | 5.4 | 5110 | 37.70 | \$113 | 1.3 MMBtu | 0 kWh | \$10 | 11.3 yrs |
| Cond | | 1.5 | 90 Degree Elbow | 2 | Cellular Glass | | | | 34.00 | \$102 | 0.5 MMBtu | 0 kWh | \$4 | 24.3 yrs |
| Cond | | 1.5 | 90 Degree Elbow | 2 | Cellular Glass | 11 | 19.8 | 5110 | 37.70 | \$414 | 4.6 MMBtu | 0 kWh | \$37 | 11.3 yrs |
| Cond | | 1.5 | Check Valve | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 123.30 | \$247 | 1.8 MMBtu | 0 kWh | \$14 | 17.1 yrs |
| Cond | | 1.5 | In-Line Pump | 1.5 | Removable Blanket | 2 | 10 | 5110 | 142.70 | \$285 | 2.2 MMBtu | 0 kWh | \$18 | 16.2 yrs |
| Cond | | 1.5 | Steam Trap | 1.5 | Removable Blanket | 4 | 17.6 | 5110 | 123.30 | \$493 | 3.9 MMBtu | 0 kWh | \$31 | 15.9 yrs |
| Cond | | 1.5 | Steam Trap | 1.5 | Removable Blanket | 1 | 4.4 | 5110 | 123.30 | \$247 | 1.9 MMBtu | 0 kWh | \$15 | 15.9 yrs |
| Cond | | 1.5 | Straight Pipe | 2 | Cellular Glass | 6 | 6 | 5110 | 35.80 | \$215 | 1.4 MMBtu | 0 kWh | \$11 | 19.3 yrs |
| Cond | | 1.5 | Straight Pipe | 2 | Cellular Glass | 3 | 3 | 5110 | 35.80 | \$215 | 1.4 MMBtu | 0 kWh | \$11 | 19.3 yrs |
| Cond | | 1.5 | Straight Pipe | 2 | Cellular Glass | 24 | 24 | 5110 | 35.80 | \$858 | 5.6 MMBtu | 0 kWh | \$45 | 19.3 yrs |
| Cond | | 1.5 | Straight Pipe | 2 | Cellular Glass | 19 | 19 | 5110 | 35.20 | \$668 | 1.8 MMBtu | 0 kWh | \$15 | 45.2 yrs |
| Cond | | 1.5 | Strainer | 1.5 | Removable Blanket | 2 | 10 | 5110 | 105.40 | \$211 | 2.2 MMBtu | 0 kWh | \$18 | 12.0 yrs |
| Cond | | 1.5 | Strainer | 1.5 | Removable Blanket | 4 | 20 | 5110 | 105.40 | \$422 | 4.4 MMBtu | 0 kWh | \$35 | 12.0 yrs |
| Cond | | 1.5 | Strainer | 1.5 | Removable Blanket | 1 | 5 | 5110 | 105.40 | \$105 | 1.1 MMBtu | 0 kWh | \$9 | 12.0 yrs |
| Cond | | 1.5 | T Intersection | 2 | Cellular Glass | 1 | 1.2 | 5110 | 34.00 | \$34 | 0.1 MMBtu | 0 kWh | \$1 | 36.4 yrs |
| Cond | | 2 | 45 Degree Elbow | 2 | Cellular Glass | 2 | 2 | 5110 | 37.70 | \$75 | 0.6 MMBtu | 0 kWh | \$5 | 16.5 yrs |
| Cond | | 2 | 90 Degree Elbow | 2 | Cellular Glass | 2 | 3.6 | 5110 | 37.70 | \$75 | 1.0 MMBtu | 0 kWh | \$8 | 9.2 yrs |
| Cond | | 2 | 90 Degree Elbow | 2 | Cellular Glass | 1 | 1.8 | 5110 | 37.70 | \$113 | 1.2 MMBtu | 0 kWh | \$10 | 11.4 yrs |
| Cond | | 2 | 90 Degree Elbow | 2 | Cellular Glass | 3 | 5.4 | 5110 | 37.70 | \$113 | 1.5 MMBtu | 0 kWh | \$12 | 9.2 yrs |
| Cond | | 2 | 90 Degree Elbow | 2 | Cellular Glass | 5 | 9 | 5110 | 37.70 | \$188 | 2.6 MMBtu | 0 kWh | \$21 | 9.2 yrs |
| Cond | | 2 | Check Valve | 1.5 | Removable Blanket | 3 | 12.3 | 5110 | 123.30 | \$370 | 3.3 MMBtu | 0 kWh | \$27 | 13.9 yrs |
| Cond | | 2 | Gate Valve | 1.5 | Removable Blanket | 3 | 15 | 5110 | 123.30 | \$370 | 4.1 MMBtu | 0 kWh | \$32 | 11.4 yrs |
| Cond | | 2 | Steam Trap | 1.5 | Removable Blanket | 1 | 4.4 | 5110 | 123.30 | \$123 | 1.2 MMBtu | 0 kWh | \$10 | 12.9 yrs |
| Cond | | 2 | Straight Pipe | 2 | Cellular Glass | 2 | 2 | 5110 | 36.10 | \$72 | 0.2 MMBtu | 0 kWh | \$2 | 38.7 yrs |
| Cond | | 2 | Straight Pipe | 2 | Cellular Glass | 1 | 1 | 5110 | 36.10 | \$36 | 0.3 MMBtu | 0 kWh | \$2 | 15.8 yrs |
| Cond | | 2 | Straight Pipe | 2 | Cellular Glass | 9 | 9 | 5110 | 36.10 | \$650 | 5.1 MMBtu | 0 kWh | \$41 | 15.8 yrs |
| Cond | | 2 | Straight Pipe | 2 | Cellular Glass | 21 | 21 | 5110 | 36.10 | \$758 | 6.0 MMBtu | 0 kWh | \$48 | 15.8 yrs |
| Cond | | 2 | Straight Pipe | 2 | Cellular Glass | 20 | 20 | 5110 | 36.10 | \$722 | 5.7 MMBtu | 0 kWh | \$46 | 15.8 yrs |
| Cond | | 2 | Strainer | 1.5 | Removable Blanket | 1 | 5 | 5110 | 123.30 | \$123 | 1.4 MMBtu | 0 kWh | \$11 | 11.4 yrs |
| Cond | | 2 | Strainer | 1.5 | Removable Blanket | 3 | 15 | 5110 | 123.30 | \$370 | 4.1 MMBtu | 0 kWh | \$32 | 11.4 yrs |
| Cond | | 4 | 90 Degree Elbow | 2 | Cellular Glass | 1 | 1.8 | 5110 | 43.60 | \$44 | 0.9 MMBtu | 0 kWh | \$7 | 5.9 yrs |
| Cond | | 4 | Flange | 1.5 | Removable Blanket | 1 | 1.8 | 5110 | 168.90 | \$169 | 0.9 MMBtu | 0 kWh | \$7 | 24.1 yrs |

Teaneck Public Schools Energy Savings Plan

MECHANICAL INSULATION SAVINGS SUMMARY

| Building | Fluid Type | Pipe Dia (") or Tank Surface Area(SF)* | Component | Insulation Thickness (") | Proposed Insulation Type | Quantity or Length | Total Eq Length(LF) or Total Area(SF)* | Heating or Cooling Hrs/Yr | Price per Unit | Total Investment | Fuel Savings MMBtu | Electric Savings kWh | Total Savings | Payback |
|---|-------------------|--|------------------|--------------------------|--------------------------|--------------------|--|---------------------------|----------------|------------------|--------------------|----------------------|----------------|-----------------|
| Teaneck High School | | | | | | | | | | | | | | |
| | Cond | 4 | Straight Pipe | 2 | Cellular Glass | 5 | 5 | 5110 | 38.40 | \$192 | 2.6 MMBtu | 0 kWh | \$20 | 9.4 yrs |
| | Cond | 4 | T Intersection | 2 | Cellular Glass | 2 | 2.4 | 5110 | 43.60 | \$87 | 1.2 MMBtu | 0 kWh | \$10 | 8.9 yrs |
| | Cond | 6 | Flange | 2 | Cellular Glass | 1 | 1.8 | 5110 | 40.10 | \$40 | 1.3 MMBtu | 0 kWh | \$10 | 3.8 yrs |
| | Cond | 16 | Condensate Tank | 2 | Cellular Glass | 1 | 16 | 5110 | 44.90 | \$718 | 7.1 MMBtu | 0 kWh | \$57 | 12.6 yrs |
| | Cond | 51.4 | Condensate Tank | 2 | Cellular Glass | 1 | 51.4 | 5110 | 44.90 | \$2,307 | 23.0 MMBtu | 0 kWh | \$184 | 12.6 yrs |
| | Cond | 129.1 | Condensate Tank | 2 | Cellular Glass | 1 | 129.1 | 5110 | 31.90 | \$4,120 | 57.7 MMBtu | 0 kWh | \$461 | 8.9 yrs |
| | Cond Total | | | | | | | | | \$19,533 | 187.4 MMBtu | 0 kWh | \$1,499 | 13.0 yrs |
| Teaneck High School Total | | | | | | | | | | \$26,881 | 281.4 MMBtu | 0 kWh | \$2,251 | 11.9 yrs |
| Thomas Jefferson Middle School | | | | | | | | | | | | | | |
| | MTHW | 10 | Butterfly Valve | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 305.20 | \$610 | 11.3 MMBtu | 0 kWh | \$91 | 6.7 yrs |
| | MTHW | 10 | Centrifugal Pump | 1.5 | Removable Blanket | 2 | 10 | 5110 | 352.30 | \$705 | 13.8 MMBtu | 0 kWh | \$111 | 6.4 yrs |
| | MTHW | 10 | Check Valve | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 337.70 | \$675 | 11.3 MMBtu | 0 kWh | \$91 | 7.4 yrs |
| | MTHW | 10 | Flange | 1.5 | Removable Blanket | 12 | 21.6 | 5110 | 279.30 | \$3,352 | 29.9 MMBtu | 0 kWh | \$239 | 14.0 yrs |
| | MTHW | 10 | Flex Fitting | 2 | Cellular Glass | 4 | 6 | 5110 | 62.80 | \$251 | 8.7 MMBtu | 0 kWh | \$70 | 3.6 yrs |
| | MTHW | 10 | Suction Diffuser | 1.5 | Removable Blanket | 2 | 8.8 | 5110 | 352.30 | \$705 | 12.2 MMBtu | 0 kWh | \$97 | 7.2 yrs |
| | MTHW Total | | | | | | | | | \$6,298 | 87.3 MMBtu | 0 kWh | \$698 | 9.0 yrs |
| Thomas Jefferson Middle School Total | | | | | | | | | | \$6,298 | 87.3 MMBtu | 0 kWh | \$698 | 9.0 yrs |
| Whittier Elementary School | | | | | | | | | | | | | | |
| | MTHW | 4 | 90 Degree Elbow | 2 | Cellular Glass | 2 | 3.6 | 5110 | 43.60 | \$87 | 2.4 MMBtu | 0 kWh | \$19 | 4.6 yrs |
| | MTHW | 4 | In-Line Pump | 1.5 | Removable Blanket | 1 | 5 | 5110 | 207.70 | \$208 | 3.1 MMBtu | 0 kWh | \$25 | 8.3 yrs |
| | MTHW Total | | | | | | | | | \$295 | 5.5 MMBtu | 0 kWh | \$44 | 6.7 yrs |
| | LPS | 1.25 | 90 Degree Elbow | 2.5 | Cellular Glass | 4 | 7.2 | 5110 | 66.80 | \$267 | 2.5 MMBtu | 0 kWh | \$20 | 13.2 yrs |
| | LPS | 1.25 | Control Valve | 1.5 | Removable Blanket | 2 | 8.2 | 5110 | 100.50 | \$201 | 2.7 MMBtu | 0 kWh | \$22 | 9.3 yrs |
| | LPS | 1.25 | Gate Valve | 1.5 | Removable Blanket | 1 | 5 | 5110 | 82.70 | \$83 | 1.6 MMBtu | 0 kWh | \$13 | 6.3 yrs |
| | LPS | 1.25 | Straight Pipe | 2.5 | Cellular Glass | 9 | 9 | 5110 | 65.30 | \$588 | 3.2 MMBtu | 0 kWh | \$25 | 23.2 yrs |
| | LPS | 1.25 | T Intersection | 2.5 | Cellular Glass | 4 | 4.8 | 5110 | 66.80 | \$267 | 1.7 MMBtu | 0 kWh | \$14 | 19.8 yrs |
| | LPS | 3 | Bonnet | 1.5 | Removable Blanket | 1 | 1.8 | 5110 | 123.30 | \$123 | 1.2 MMBtu | 0 kWh | \$9 | 13.0 yrs |
| | LPS | 3 | Flange | 1.5 | Removable Blanket | 2 | 3.6 | 5110 | 87.60 | \$175 | 2.4 MMBtu | 0 kWh | \$19 | 9.3 yrs |
| | LPS | 3 | Gate Valve | 1.5 | Removable Blanket | 1 | 5 | 5110 | 155.80 | \$156 | 3.3 MMBtu | 0 kWh | \$26 | 5.9 yrs |
| | LPS | 3 | Strainer | 1.5 | Removable Blanket | 1 | 5 | 5110 | 123.30 | \$123 | 3.3 MMBtu | 0 kWh | \$26 | 4.7 yrs |
| | LPS | 4 | Bonnet | 1.5 | Removable Blanket | 2 | 3.6 | 5110 | 155.80 | \$312 | 3.0 MMBtu | 0 kWh | \$24 | 13.1 yrs |
| | LPS | 4 | Strainer | 1.5 | Removable Blanket | 1 | 5 | 5110 | 155.80 | \$156 | 2.1 MMBtu | 0 kWh | \$17 | 9.4 yrs |
| | LPS | 5 | 45 Degree Elbow | 3 | Cellular Glass | 1 | 1 | 5110 | 88.00 | \$88 | 1.1 MMBtu | 0 kWh | \$9 | 10.2 yrs |
| | LPS | 5 | 90 Degree Elbow | 3 | Cellular Glass | 2 | 3.6 | 5110 | 88.00 | \$176 | 3.9 MMBtu | 0 kWh | \$31 | 5.7 yrs |
| | LPS | 5 | Flange | 1.5 | Removable Blanket | 5 | 9 | 5110 | 201.40 | \$1,007 | 9.0 MMBtu | 0 kWh | \$72 | 14.0 yrs |
| | LPS | 5 | Straight Pipe | 3 | Cellular Glass | 4 | 4 | 5110 | 74.20 | \$297 | 4.3 MMBtu | 0 kWh | \$34 | 8.6 yrs |
| | LPS | 6 | Bonnet | 1.5 | Removable Blanket | 4 | 7.2 | 5110 | 204.50 | \$818 | 8.5 MMBtu | 0 kWh | \$68 | 12.1 yrs |
| | LPS | 8 | Bonnet | 1.5 | Removable Blanket | 2 | 3.6 | 5110 | 204.50 | \$409 | 5.4 MMBtu | 0 kWh | \$43 | 9.5 yrs |
| | LPS | 10 | End Cap | 3 | Cellular Glass | 1 | 1.8 | 5110 | 141.10 | \$141 | 3.5 MMBtu | 0 kWh | \$28 | 5.0 yrs |
| | LPS | 10 | Flange | 3 | Cellular Glass | 1 | 1.8 | 5110 | 82.80 | \$83 | 3.5 MMBtu | 0 kWh | \$28 | 2.9 yrs |
| | LPS Total | | | | | | | | | \$5,470 | 66.1 MMBtu | 0 kWh | \$528 | 10.4 yrs |
| | Cond | 1 | 45 Degree Elbow | 1.5 | Cellular Glass | 1 | 1 | 5110 | 32.30 | \$32 | 0.2 MMBtu | 0 kWh | \$1 | 25.3 yrs |
| | Cond | 1 | 90 Degree Elbow | 1.5 | Cellular Glass | 10 | 18 | 5110 | 32.30 | \$323 | 2.9 MMBtu | 0 kWh | \$23 | 14.1 yrs |
| | Cond | 1 | Steam Trap | 1.5 | Removable Blanket | 3 | 13.2 | 5110 | 116.80 | \$350 | 2.1 MMBtu | 0 kWh | \$16 | 21.3 yrs |
| | Cond | 1 | Straight Pipe | 1.5 | Cellular Glass | 43 | 43 | 5110 | 32.90 | \$1,417 | 6.9 MMBtu | 0 kWh | \$55 | 25.8 yrs |
| | Cond | 1 | Strainer | 1.5 | Removable Blanket | 5 | 25 | 5110 | 100.50 | \$503 | 3.9 MMBtu | 0 kWh | \$31 | 16.1 yrs |
| | Cond | 1 | T Intersection | 1.5 | Cellular Glass | 3 | 3.6 | 5110 | 32.30 | \$97 | 0.6 MMBtu | 0 kWh | \$5 | 21.1 yrs |
| | Cond | 1.25 | 90 Degree Elbow | 1.5 | Cellular Glass | 2 | 3.6 | 5110 | 32.30 | \$65 | 0.7 MMBtu | 0 kWh | \$6 | 11.3 yrs |
| | Cond | 1.25 | 90 Degree Elbow | 1.5 | Cellular Glass | 1 | 1.8 | 5110 | 32.30 | \$32 | 0.4 MMBtu | 0 kWh | \$3 | 11.3 yrs |
| | Cond | 1.25 | Straight Pipe | 1.5 | Cellular Glass | 3 | 3 | 5110 | 32.90 | \$99 | 0.6 MMBtu | 0 kWh | \$5 | 20.7 yrs |
| | Cond | 1.25 | Straight Pipe | 1.5 | Cellular Glass | 18 | 18 | 5110 | 32.90 | \$593 | 3.6 MMBtu | 0 kWh | \$29 | 20.7 yrs |
| | Cond | 1.25 | Strainer | 1.5 | Removable Blanket | 1 | 5 | 5110 | 100.50 | \$101 | 1.0 MMBtu | 0 kWh | \$8 | 13.0 yrs |
| | Cond | 1.25 | T Intersection | 1.5 | Cellular Glass | 1 | 1.2 | 5110 | 32.30 | \$32 | 0.2 MMBtu | 0 kWh | \$2 | 17.0 yrs |
| | Cond | 1.5 | 45 Degree Elbow | 2 | Cellular Glass | 2 | 2 | 5110 | 37.70 | \$75 | 0.5 MMBtu | 0 kWh | \$4 | 20.3 yrs |
| | Cond | 1.5 | 90 Degree Elbow | 2 | Cellular Glass | 22 | 39.6 | 5110 | 37.70 | \$829 | 9.2 MMBtu | 0 kWh | \$73 | 11.3 yrs |
| | Cond | 1.5 | In-Line Pump | 1.5 | Removable Blanket | 2 | 10 | 5110 | 142.70 | \$285 | 2.2 MMBtu | 0 kWh | \$18 | 16.2 yrs |
| | Cond | 1.5 | Steam Trap | 1.5 | Removable Blanket | 1 | 4.4 | 5110 | 123.30 | \$247 | 1.9 MMBtu | 0 kWh | \$15 | 15.9 yrs |
| | Cond | 1.5 | Straight Pipe | 2 | Cellular Glass | 107 | 107 | 5110 | 35.80 | \$3,825 | 24.8 MMBtu | 0 kWh | \$199 | 19.3 yrs |

Teaneck Public Schools Energy Savings Plan


TEANECK PUBLIC SCHOOLS, NJ MECHANICAL INSULATION SAVINGS SUMMARY

| Building | Fluid Type | Pipe Dia (") or Tank Surface Area(SF)* | Component | Insulation Thickness (") | Proposed Insulation Type | Quantity or Length | Total Eq Length(LF) or Total Area(SF)* | Heating or Cooling Hrs-Yr | Price per Unit | Total Investment | Fuel Savings MMBTU | Electric Savings kWh | Total Savings | Payback | |
|----------------------------|---|--|-----------------|--------------------------|--------------------------|--------------------|--|---------------------------|----------------|------------------|--------------------|----------------------|---------------|-----------------|-----------------|
| Whittier Elementary School | Cond | 1.5 | Strainer | 1.5 | Removable Blanket | 3 | 15 | 5110 | 105.40 | \$316 | 3.3 MMBtu | 0 kWh | \$26 | 12.0 yrs | |
| | Cond | 1.5 | T Intersection | 2 | Cellular Glass | 1 | 1.2 | 5110 | 37.70 | \$38 | 0.3 MMBtu | 0 kWh | \$2 | 16.9 yrs | |
| | Cond | 2 | 45 Degree Elbow | 2 | Cellular Glass | 6 | 6 | 5110 | 37.70 | \$226 | 1.7 MMBtu | 0 kWh | \$14 | 16.5 yrs | |
| | Cond | 2 | 90 Degree Elbow | 2 | Cellular Glass | 7 | 12.6 | 5110 | 37.70 | \$264 | 3.6 MMBtu | 0 kWh | \$29 | 9.2 yrs | |
| | Cond | 2 | Gate Valve | 1.5 | Removable Blanket | 1 | 5 | 5110 | 123.30 | \$123 | 1.4 MMBtu | 0 kWh | \$11 | 11.4 yrs | |
| | Cond | 2 | Straight Pipe | 2 | Cellular Glass | 78 | 78 | 5110 | 36.10 | \$2,817 | 22.2 MMBtu | 0 kWh | \$178 | 15.8 yrs | |
| | Cond | 2 | Strainer | 1.5 | Removable Blanket | 1 | 5 | 5110 | 123.30 | \$123 | 1.4 MMBtu | 0 kWh | \$11 | 11.4 yrs | |
| | Cond | 2 | T Intersection | 2 | Cellular Glass | 1 | 1.2 | 5110 | 37.70 | \$38 | 0.3 MMBtu | 0 kWh | \$3 | 13.8 yrs | |
| | Cond | 3 | 90 Degree Elbow | 2 | Cellular Glass | 2 | 3.6 | 5110 | 40.40 | \$81 | 1.5 MMBtu | 0 kWh | \$12 | 6.9 yrs | |
| | Cond | 3 | Flange | 2 | Cellular Glass | 2 | 3.6 | 5110 | 37.10 | \$74 | 1.5 MMBtu | 0 kWh | \$12 | 6.3 yrs | |
| | Cond | 3 | Straight Pipe | 2 | Cellular Glass | 13 | 13 | 5110 | 37.10 | \$482 | 5.3 MMBtu | 0 kWh | \$42 | 11.4 yrs | |
| | Cond | 3 | T Intersection | 2 | Cellular Glass | 2 | 2.4 | 5110 | 40.40 | \$81 | 1.0 MMBtu | 0 kWh | \$8 | 10.3 yrs | |
| | Cond | 4 | 90 Degree Elbow | 2 | Cellular Glass | 6 | 10.8 | 5110 | 43.60 | \$261 | 5.5 MMBtu | 0 kWh | \$44 | 5.9 yrs | |
| | Cond | 4 | Straight Pipe | 2 | Cellular Glass | 26 | 26 | 5110 | 38.40 | \$1,000 | 13.3 MMBtu | 0 kWh | \$106 | 9.4 yrs | |
| | Cond | 4 | T Intersection | 2 | Cellular Glass | 6 | 7.2 | 5110 | 43.60 | \$261 | 3.7 MMBtu | 0 kWh | \$29 | 8.9 yrs | |
| | Cond | 56.9 | Condensate Tank | 2 | Cellular Glass | 1 | 56.9 | 5110 | 44.90 | \$2,553 | 25.4 MMBtu | 0 kWh | \$203 | 12.6 yrs | |
| | Cond Total | | | | | | | | | | \$17,644 | 152.8 MMBtu | 0 kWh | \$1,222 | 14.4 yrs |
| | Whittier Elementary School Total | | | | | | | | | | \$23,409 | 224.3 MMBtu | 0 kWh | \$1,795 | 13.0 yrs |
| | Grand Totals | | | | | | | | | | \$136,646 | 1,432.3 MMBtu | 0 kWh | \$11,459 | 11.9 yrs |

Steam Trap Replacements


Bryant Elementary School

- Steam returning to condensate receiver in boiler room. Temperature is 217F (measured by gauge and IR camera)
- Overheating in some areas that have thermostatic controls on terminal heating unit (some TS controls may be faulty)
- Steam in condensate return system may also be contributing to the overheating in some areas
- Some trap tags were hung on the UC, UV or radiator enclosures rather than the trap piping.
- In many instances it was difficult to confirm size, make and model of the various thermostatic traps inside radiator and convector enclosures due to the cover itself and accumulated dust and debris. This information should be confirmed before ordering any model specific parts.



Teaneck Public Schools Energy Savings Plan


Bryant Elementary School Continued



Teaneck Public Schools Energy Savings Plan


Hawthorne Elementary School

- Boiler pressure: 6-7psig
- No school on day of survey (building unoccupied)
- Survey performed during daytime hours
- Condensate receiver in boiler room is 136F
- Condensate received in tunnel (under Rm. 23) is 213F (venting slightly)
- Couldn't survey tunnel under Rm.'s 15 & 16 and the hallway for Rm.'s 10 - 12 due to steam leak in tunnel
- Couldn't survey tunnel under Rm.'s 13 & 14 and the hallway in front of Rm. 17 due to flooding (4"+ deep)



Teaneck Public Schools Energy Savings Plan


Hawthorne Elementary School Continued



Teaneck Public Schools Energy Savings Plan

Lowell Elementary School

- Boiler pressure: 6-7psig
- No school on day of survey (building unoccupied)
- Survey performed during daytime hours
- Condensate receiver in boiler room is 182F (temperatures of various condensate return lines vary significantly)
- Many terminal heating units located outside of classrooms were cold indicating they hadn't called for heat recently.



Lowell Basement Floor




Teaneck Public Schools Energy Savings Plan

Lowell Elementary School Continued



Lowell First Floor




Teaneck Public Schools Energy Savings Plan

Lowell Elementary School Continued




Lowell Second Floor



Teaneck Public Schools Energy Savings Plan


Whittier Elementary School

- Boiler pressure: 6-7psig
- No school on day of survey (building unoccupied)
- Survey performed during daytime hours
- Condensate receiver in boiler room is 214F (venting)



Teaneck Public Schools Energy Savings Plan

Whittier Elementary School Continued




Whittier 1st floor

0 5' 10' 15' 20'

Teaneck Public Schools Energy Savings Plan

Whittier Elementary School Continued



Whittier second floor

0 5' 10' 15' 20'

Teaneck Public Schools Energy Savings Plan

Boiler Combustion Report Data

| Location | Date | W/S | Boiler | O2 % | CO ppm | Eff. % | CO2% | Stack Temp F | Average |
|----------------------|------------|-------|--------|--------|--------|---------|-------|--------------|---------|
| Benjamin Franklin MS | 11/11/2019 | Water | 1 | 14.2 % | 23 | 85.60 % | 3.8% | 167 | 86% |
| Benjamin Franklin MS | 11/11/2019 | Water | 2 | 14.1 % | 8 | 88.10 % | 3.8% | 124 | |
| Benjamin Franklin MS | 11/11/2019 | Water | 3 | 15.6 % | 11 | 84.30 % | 3.0% | 163 | |
| Lowell ES | 11/11/2019 | Steam | 1 | 4.9 % | 2 | 85.20 % | 9.0% | 280 | 84.35% |
| Lowell ES | 11/11/2019 | Steam | 2 | 3.6 % | 3000 | 83.50 % | 9.8% | 314 | |
| Whittier ES | 11/11/2019 | Steam | 1 | 1.9 % | 3000 | 87.00 % | 10.7% | 194 | 87% |
| Whittier ES | 11/11/2019 | Steam | 2 | | | | | | |
| Bryant ES | 11/11/2019 | Steam | 1 | 9.8 % | 14 | 84.20 % | 6.3% | 265 | 82.75 |
| Bryant ES | 11/11/2019 | Steam | 2 | 13.7 % | 18 | 81.30 % | 4.1% | 263 | |
| Hawthorne ES | 11/11/2019 | Steam | 1 | 5.4 % | 156 | 86.60 % | 8.7% | 234 | 86.75% |
| Hawthorne ES | 11/11/2019 | Steam | 2 | 4.1 % | 43 | 86.90 % | 9.5% | 236 | |
| Thomas Jefferson MS | 11/11/2019 | Water | 1 | 9.9 % | 9 | 88.10 % | 6.2% | 160 | 88.05% |
| Thomas Jefferson MS | 11/11/2019 | Water | 2 | 12.9 % | 30 | 88.00 % | 4.5% | 144 | |
| Thomas Jefferson MS | 11/11/2019 | Water | 3 | 17.1 % | 90 | XXX | XXX | 150 | |
| Teaneck HS | 11/11/2019 | Steam | 1 | 9.7 % | 268 | 84.90 % | 6.3% | 244 | 83.80% |
| Teaneck HS | 11/11/2019 | Steam | 2 | 14.7 % | 6 | 82.70 % | 3.5% | 220 | |

Teaneck Public Schools Energy Savings Plan

| Location | Adjusted Boiler Efficiency | | | | Final Efficiency |
|-----------------------------|----------------------------|----------------------------|-----------------------|-------------------------|------------------|
| | W/S | Avg. Combustion Efficiency | Heat Exchanger Losses | Piping & Thermal Losses | |
| Benjamin Franklin MS | Water | 86.00% | 0.0% | 2.0% | 84.0% |
| Lowell ES | Steam | 84.35% | 4.0% | 2.0% | 78.4% |
| Whittier ES | Steam | 87.00% | 4.0% | 2.0% | 81.0% |
| Bryant ES | Steam | 82.75% | 4.0% | 2.0% | 76.8% |
| Hawthorne ES | Steam | 86.75% | 4.0% | 2.0% | 80.8% |
| Thomas Jefferson MS | Water | 88.05% | 0.0% | 2.0% | 86.1% |

| Teaneck High School | Avg. Combustion Efficiency | Stack Loss Factor | Skin and shell factor | Operational Inefficiency Factor | Final Efficiency |
|----------------------------------|----------------------------|-------------------|-----------------------|---------------------------------|------------------|
| Pre – Avg Sys Eff Factors | 83.80% | 97% | 98% | 96% | 76% |
| Post– Avg Sys Eff Factors | 93.50% | 100% | 98% | 98% | 90% |

Teaneck Public Schools Energy Savings Plan

esg. *Teaneck...*

.....
..... *HS*



BACHARACH, INC.
PCA 3
SN: UZ1000

=====
Time: 07:47:34 PM
Date: 11/11/19

Fuel
NGAS

| | |
|---------------------|---------|
| O ₂ | 9.7 % |
| CO | 269 ppm |
| Eff | 84.9 % |
| CO ₂ | 6.3 % |
| T-Stk | 244 °F |
| T-Air | 87.6 °F |
| EA | 77.3 % |
| CO (O) | 503 ppm |
| NO | *** ppm |
| NO ₂ | 2 ppm |
| NO _x | *** ppm |
| SO ₂ | 7 ppm |
| NO (O) | *** ppm |
| NO ₂ (O) | 3 ppm |
| NO _x (O) | *** ppm |
| SO ₂ (O) | 14 ppm |

Draft Reading
0.00 inwc

Boiler ①

Comments:

esg. *Teaneck...*

.....
..... *HS*



BACHARACH, INC.
PCA 3
SN: UZ1000

=====
Time: 07:53:18 PM
Date: 11/11/19

Fuel
NGAS

| | |
|---------------------|---------|
| O ₂ | 14.7 % |
| CO | 6 ppm |
| Eff | 82.7 % |
| CO ₂ | 3.5 % |
| T-Stk | 220 °F |
| T-Air | 88.4 °F |
| EA | 209.3 % |
| CO (O) | 21 ppm |
| NO | *** ppm |
| NO ₂ | 0 ppm |
| NO _x | *** ppm |
| SO ₂ | 2 ppm |
| NO (O) | *** ppm |
| NO ₂ (O) | 1 ppm |
| NO _x (O) | *** ppm |
| SO ₂ (O) | 7 ppm |

Draft Reading
0.01 inwc

Boiler ②

Comments:

Teaneck Public Schools Energy Savings Plan

esg. *Bengiman*
.....*Franklin MS*
.....
BACHARACH
BACHARACH, INC.
PCA 3
SN: UZ1000

Time: 04:35:11 PM
Date: 11/11/19

Fuel
NGAS

| | |
|---------------------|---------|
| O ₂ | 14.2 % |
| CO | 23 ppm |
| Eff | 85.6 % |
| CO ₂ | 3.8 % |
| T-Stk | 187 °F |
| T-Air | 76.4 °F |
| EA | 189.8 % |
| CO (0) | 73 ppm |
| NO | *** ppm |
| NO ₂ | 1 ppm |
| NO _x | *** ppm |
| SO ₂ | 1 ppm |
| NO (0) | *** ppm |
| NO ₂ (0) | 3 ppm |
| NO _x (0) | *** ppm |
| SO ₂ (0) | 4 ppm |

Draft Reading
0.01 inwc

Boiler ①

Comments:

esg. *Bengiman*
.....*Franklin MC*
.....
BACHARACH
BACHARACH, INC.
PCA 3
SN: UZ1000

Time: 04:30:11 PM
Date: 11/11/19

Fuel
NGAS

| | |
|---------------------|---------|
| O ₂ | 14.1 % |
| CO | 8 ppm |
| Eff | 88.1 % |
| CO ₂ | 3.8 % |
| T-Stk | 124 °F |
| T-Air | 75.6 °F |
| EA | 186.2 % |
| CO (0) | 28 ppm |
| NO | *** ppm |
| NO ₂ | 1 ppm |
| NO _x | *** ppm |
| SO ₂ | 1 ppm |
| NO (0) | *** ppm |
| NO ₂ (0) | 2 ppm |
| NO _x (0) | *** ppm |
| SO ₂ (0) | 4 ppm |

Draft Reading
0.01 inwc

Boiler ②

Comments:

esg. *Bengiman*
.....*Franklin MS*
.....
BACHARACH
BACHARACH, INC.
PCA 3
SN: UZ1000

Time: 04:16:25 PM
Date: 11/11/19

Fuel
NGAS

| | |
|---------------------|---------|
| O ₂ | 15.6 % |
| CO | 11 ppm |
| Eff | 84.3 % |
| CO ₂ | 3.0 % |
| T-Stk | 163 °F |
| T-Air | 72.3 °F |
| EA | 250.0 % |
| CO (0) | 45 ppm |
| NO | *** ppm |
| NO ₂ | 0 ppm |
| NO _x | *** ppm |
| SO ₂ | 1 ppm |
| NO (0) | *** ppm |
| NO ₂ (0) | 1 ppm |
| NO _x (0) | *** ppm |
| SO ₂ (0) | 4 ppm |

Draft Reading
0.00 inwc

Boiler ③

Comments:

Teaneck Public Schools Energy Savings Plan

esg lowell....
.....
..... ES



BACHARACH, INC.
PCA 3
SN: UZ1000

Time: 05:13:24 PM
Date: 11/11/19

Fuel
NGAS

| | |
|---------------------|---------|
| O ₂ | 4.9 % |
| CO | 2 ppm |
| Eff | 85.2 % |
| CO ₂ | 9.0 % |
| T-Stk | 280 °F |
| T-Air | 78.6 °F |
| EA | 27.6 % |
| CO (0) | 3 ppm |
| NO | ppm |
| NO ₂ | 1 ppm |
| NO _x | ppm |
| SO ₂ | 5 ppm |
| NO (0) | ppm |
| NO ₂ (0) | 2 ppm |
| NO _x (0) | ppm |
| SO ₂ (0) | 6 ppm |

Draft Reading
0.00 inwc

Boiler ①

Comments:

esg lowell....
.....
..... ES



BACHARACH, INC.
PCA 3
SN: UZ1000

Time: 05:16:16 PM
Date: 11/11/19

Fuel
NGAS

| | |
|---------------------|---------|
| O ₂ | 3.6 % |
| CO | XXX ppm |
| Eff | 83.5 % |
| CO ₂ | 9.8 % |
| T-Stk | 314 °F |
| T-Air | 80.6 °F |
| EA | 17.8 % |
| CO (0) | XXX ppm |
| NO | ppm |
| NO ₂ | 1 ppm |
| NO _x | ppm |
| SO ₂ | 375 ppm |
| NO (0) | ppm |
| NO ₂ (0) | 2 ppm |
| NO _x (0) | ppm |
| SO ₂ (0) | 453 ppm |

Draft Reading
0.01 inwc

Boiler ②

Comments:

Teaneck Public Schools Energy Savings Plan

esg. *Whittier.*

.....
..... *ES*



BACHARACH, INC.
PCA 3
SN: UZ1000

=====
Time: 05:42:24 PM

Date: 11/11/19

Fuel
NGAS

| | |
|---------------------|----------|
| O ₂ | 1.9 % |
| CO | XXX ppm |
| Eff | 87.0 % |
| CO ₂ | 10.7 % |
| T-Stk | 194 °F |
| T-Air | 89.8 °F |
| EA | 8.1 % |
| CO (0) | XXX ppm |
| NO | *** ppm |
| NO ₂ | 3 ppm |
| NO _x | *** ppm |
| SO ₂ | 918 ppm |
| NO (0) | *** ppm |
| NO ₂ (0) | 3 ppm |
| NO _x (0) | *** ppm |
| SO ₂ (0) | 1008 ppm |

Draft Reading

0.00 inwc

Boiler ①

Comments:

Teaneck Public Schools Energy Savings Plan

esg. *Bryan.T.*

.....
..... *ES*



BACHARACH, INC.
PCA 3
SN: UZ1000

Time: 06:23:51 PM
Date: 11/11/19

Fuel
NGAS

| | |
|---------------------|-----------|
| O ₂ | 9.8 % |
| CO | 14 ppm |
| Eff | 84.2 % |
| CO ₂ | 6.3 % |
| T-Stk | 265 °F |
| T-Air | 88.8 °F |
| EA | 78.5 % |
| CO (0) | 27 ppm |
| NO | ppm |
| NO ₂ | 3 ppm |
| NO _x | ppm |
| SO ₂ | 5 ppm |
| NO (0) | ppm |
| NO ₂ (0) | 5 ppm |
| NO _x (0) | ppm |
| SO ₂ (0) | 10 ppm |

Draft Reading
0.00 inwc

Boiler ①

Comments:

esg. *Bryan.T.*

.....
..... *ES*



BACHARACH, INC.
PCA 3
SN: UZ1000

Time: 06:28:45 PM
Date: 11/11/19

Fuel
NGAS

| | |
|---------------------|-----------|
| O ₂ | 13.7 % |
| CO | 18 ppm |
| Eff | 81.3 % |
| CO ₂ | 4.1 % |
| T-Stk | 263 °F |
| T-Air | 88.9 °F |
| EA | 168.4 % |
| CO (0) | 52 ppm |
| NO | ppm |
| NO ₂ | 2 ppm |
| NO _x | ppm |
| SO ₂ | 4 ppm |
| NO (0) | ppm |
| NO ₂ (0) | 4 ppm |
| NO _x (0) | ppm |
| SO ₂ (0) | 12 ppm |

Draft Reading
0.01 inwc

Boiler ②

Comments:

Teaneck Public Schools Energy Savings Plan

esg Hawthorne
.....
..... ES



BACHARACH, INC.
PCA 3
SN: UZ1000

Time: 06:53:04 PM
Date: 11/11/19

Fuel
NGAS

| | |
|---------------------|---------|
| O ₂ | 5.4 % |
| CO | 156 ppm |
| Eff | 86.6 % |
| CO ₂ | 8.7 % |
| T-Stk | 234 °F |
| T-Air | 86.8 °F |
| EA | 31.2 % |
| CO (0) | 210 ppm |
| NO | *** ppm |
| NO ₂ | 2 ppm |
| NO _x | *** ppm |
| SO ₂ | 9 ppm |
| NO (0) | *** ppm |
| NO ₂ (0) | 3 ppm |
| NO _x (0) | *** ppm |
| SO ₂ (0) | 12 ppm |

Draft Reading
0.01 inwc

Boiler ①

Comments:

esg Hawthorne
.....
..... ES



BACHARACH, INC.
PCA 3
SN: UZ1000

Time: 08:55:54 PM
Date: 11/11/19

Fuel
NGAS

| | |
|---------------------|---------|
| O ₂ | 4.1 % |
| CO | 43 ppm |
| Eff | 86.9 % |
| CO ₂ | 9.5 % |
| T-Stk | 236 °F |
| T-Air | 87.6 °F |
| EA | 21.7 % |
| CO (0) | 53 ppm |
| NO | *** ppm |
| NO ₂ | 2 ppm |
| NO _x | *** ppm |
| SO ₂ | 7 ppm |
| NO (0) | *** ppm |
| NO ₂ (0) | 3 ppm |
| NO _x (0) | *** ppm |
| SO ₂ (0) | 9 ppm |

Draft Reading
0.01 inwc

Boiler ②

Comments:

Teaneck Public Schools Energy Savings Plan

esg. *Thos. Jefferson*
.....
..... *MS*



BACHARACH, INC.
PCA 3
SN: UZ1000

Time: 07:12:41 PM
Date: 11/11/19

Fuel
NGAS

| | |
|---------------------|---------|
| O ₂ | 9.9 % |
| CO | 9 ppm |
| Eff | 88.1 % |
| CO ₂ | 6.2 % |
| T-Stk | 160 °F |
| T-Air | 87.2 °F |
| EA | 80.0 % |
| CO (0) | 17 ppm |
| NO | *** ppm |
| NO ₂ | 0 ppm |
| NO _x | *** ppm |
| SO ₂ | 5 ppm |
| NO (0) | *** ppm |
| NO ₂ (0) | 1 ppm |
| NO _x (0) | *** ppm |
| SO ₂ (0) | 9 ppm |

Draft Reading
0.00 inwc

Boiler ①

Comments:

esg. *Thos. Jefferson*
.....
..... *MS*



BACHARACH, INC.
PCA 3
SN: UZ1000

Time: 07:15:28 PM
Date: 11/11/19

Fuel
NGAS

| | |
|---------------------|---------|
| O ₂ | 12.9 % |
| CO | 30 ppm |
| Eff | 88.0 % |
| CO ₂ | 4.5 % |
| T-Stk | 144 °F |
| T-Air | 87.6 °F |
| EA | 143.8 % |
| CO (0) | 77 ppm |
| NO | *** ppm |
| NO ₂ | 0 ppm |
| NO _x | *** ppm |
| SO ₂ | 6 ppm |
| NO (0) | *** ppm |
| NO ₂ (0) | 1 ppm |
| NO _x (0) | *** ppm |
| SO ₂ (0) | 15 ppm |

Draft Reading
0.00 inwc

Boiler ②

Comments:

esg. *Thos. Jefferson*
.....
..... *MS*



BACHARACH, INC.
PCA 3
SN: UZ1000

Time: 07:18:23 PM
Date: 11/11/19

Fuel
NGAS

| | |
|---------------------|---------|
| O ₂ | 17.1 % |
| CO | 90 ppm |
| Eff | --- % |
| CO ₂ | --- % |
| T-Stk | 150 °F |
| T-Air | 88.1 °F |
| EA | --- % |
| CO (0) | --- ppm |
| NO | *** ppm |
| NO ₂ | 0 ppm |
| NO _x | *** ppm |
| SO ₂ | 16 ppm |
| NO (0) | *** ppm |
| NO ₂ (0) | --- ppm |
| NO _x (0) | *** ppm |
| SO ₂ (0) | --- ppm |

Draft Reading
0.01 inwc


Boiler ③

Comments:


Teaneck Public Schools Energy Savings Plan

Boiler HW Trends and Data


Thomas Jefferson Middle School



Teaneck Public Schools Energy Savings Plan




3




4

Whittier Elementary School


Teaneck Public Schools Energy Savings Plan




Teaneck Public Schools Energy Savings Plan



7




Teaneck Public Schools Energy Savings Plan




Teaneck Public Schools Energy Savings Plan


Bryant Elementary School




11




Teaneck Public Schools Energy Savings Plan




13



Teaneck Public Schools Energy Savings Plan




15




Benjamin Franklin Middle School


Teaneck Public Schools Energy Savings Plan




17





Teaneck Public Schools Energy Savings Plan




19



Teaneck Public Schools Energy Savings Plan




Teaneck Public Schools Energy Savings Plan




Teaneck Public Schools Energy Savings Plan


Hawthorne Elementary School




24




Teaneck Public Schools Energy Savings Plan



26




Teaneck Public Schools Energy Savings Plan




Teaneck Public Schools Energy Savings Plan


Lowell Elementary School




29



Teaneck Public Schools Energy Savings Plan




31




Teaneck High School


Teaneck Public Schools Energy Savings Plan




33





Teaneck Public Schools Energy Savings Plan



35



Teaneck Public Schools Energy Savings Plan



APPENDIX 5. RECOMMENDED PROJECT - ESP

| ECM # | ECM | Year 1 Savings (\$/Yr) | ECM Cost | Simple Payback | Installation Plan | Recommend Installation |
|-------|---|------------------------|--------------|----------------|----------------------------|------------------------|
| 1 | Comprehensive LED Lighting Upgrades - Teaneck HS | \$53,668 | \$357,574 | 6.7 | Public Bidding | Yes |
| 2 | Install VFD's and Premium Motor Upgrades for HVAC | \$ 4,609 | \$ 33,685 | 7.3 | Public Bidding | Yes |
| 3 | Direct Install Program (Lighting) | \$ 74,283 | \$ 696,698 | 9.4 | DI Installer | Yes |
| 4 | Plug Load Controls | \$ 4,994 | \$ 44,952 | 9.0 | Public Bidding | Yes |
| 5 | Combined Heat and Power (35kW) | \$ 14,122* | \$ 335,500 | 23.8 | Public Bidding | Yes |
| 6 | Computer Power Management Software | \$ 15,401 | \$ 30,875 | 2.0 | Public Bidding | Yes |
| 7 | Refrigeration Controls | \$ 4,096 | \$ 42,684 | 10.4 | Public Bidding | Yes |
| 8 | Fuel Use Economizers (Hot Water Boilers) | \$ 5,513 | \$ 39,270 | 7.1 | Public Bidding | Yes |
| 9 | Direct Install Program Fuel Use Economizers (Steam Boilers) | \$ 9,979 | \$ 4,916 | 0.5 | DI Installer | Yes |
| 10 | Direct Install Program Low-flow Domestic Hot Water Devices | \$ 790 | \$ 597 | 0.8 | DI Installer | Yes |
| 11 | Replace Rooftop Cooling Unit at Whittier Elementary School | \$ 1,126 | \$ 134,922 | 119.8 | Public Bidding | Yes |
| 12 | Replace Cooling in Media Center – Benjamin Franklin Middle School | \$ 1,016 | \$ 70,018 | 68.9 | Public Bidding | Yes |
| 13 | Replace Cooling in Media Center – Lowell Elementary School | \$ 96 | \$ 34,312 | 355.7 | DI Installer | Yes |
| 14 | Condensing Hot Water Boiler Plant (Teaneck High School - Fan Room Upgrades) | \$ 10,493 | \$ 1,037,479 | 98.9 | Co-op Mechanical Installer | Yes |
| 15 | Condensing Hot Water Boiler Plant (Teaneck High School – Hot Water Header Pipe) | \$ 0 | \$ 284,900 | 100+ | Co-op Mechanical Installer | Yes |
| 16 | Replace Steam Traps | \$ 13,070 | \$ 198,580 | 15.2 | Public Bidding | Yes |
| 17 | Replace Domestic Hot Water Storage Tank at Benjamin Franklin Middle School | \$ 370 | \$ 50,070 | 135.2 | Public Bidding | Yes |
| 18 | Refurbish Cooling Tower | \$ 1,599 | \$ 22,638 | 14.2 | Public Bidding | Yes |
| 19 | Upgrade Building Management System | \$ 22,529 | \$ 413,584 | 18.4 | Co-op Controls Installer | Yes |
| 20 | Operational Verification and HVAC Improvements | \$ 38,938 | \$ 163,130 | 4.2 | Co-op Controls Installer | Yes |
| 21 | Building Envelope Weatherization | \$ 21,429 | \$ 257,632 | 12.0 | Public Bidding | Yes |
| 22 | Repair Missing Piping Insulation | \$ 7,484 | \$ 113,334 | 15.1 | Public Bidding | Yes |
| 23 | Construction Contingency | \$ 0.0 | \$ 542,500 | | Public Bidding | Yes |
| 24 | Unit Ventilator Refurbishment at Teaneck High School – First Floor | \$ 1,744 | \$ 132,000 | 75.7 | Public Bidding | Yes |
| 25 | Unit Ventilator Replacement at Teaneck High School – Second Floor | \$ 1,581 | \$ 438,625 | 277.5 | Public Bidding | Yes |
| 26 | Unit Ventilator Replacement at Teaneck High School – Third Floor | \$ 2,453 | \$ 680,625 | 277.5 | Public Bidding | Yes |

*Savings from Combined Heat and Power is Energy Savings & Distributed Generation (Capacity & Generation: \$20,093; Energy: (\$5,971))

APPENDIX 6. LIGHTING UPGRADES

Lighting Upgrades Ben Franklin Middle School

| PROJECT: Teaneck PS - Ben Franklin MS - New Fixtures - R3 | | | | | |
|---|---------------------|-----------------------|----------------|---------------------------|----------------------------|
| Room Info | | Existing Fixture Info | | Lighting Fixture Upgrades | |
| X | | X | X | X | X |
| Floor | Location | No. of Fix. | Fixture Type | ECM No. | Upgrade Description |
| First | Maintenance Storage | 10 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| First | | 4 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| First | | 5 | 2x4-4FO28-W | T4L44 | (4) 10.5w 4' T8 LED B |
| First | | 4 | 1x8-4FO28-Fin | 5NE30 | New 41w 1x8 LED Low Bay |
| First | | 1 | 1x4-2F40-IH | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Lounge | 9 | 2x2-2FO28U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Storage | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Corridor | 1 | 1x8-4FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| First | Shop | 3 | 1x4-2FO28-S | 3NE46 | New 23w 1x4 LED Low Bay |
| First | | 1 | 2x4-4FO28-Surf | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | | 1 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| First | Restroom | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Maintenance Shop | 10 | 2x4-4FO28-Surf | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Shop | 2 | 2x4-4FO28-Surf | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Maintenance Garage | 5 | 2x4-4FO28-Surf | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Cages | 2 | 2x4-4FO28-Surf | T4L44 | (4) 10.5w 4' T8 LED B |
| First | | 1 | 1x8-4FO28-W | T4L44 | (4) 10.5w 4' T8 LED B |
| First | Conference Room | 4 | 2x4-4FO28-P.5 | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Corridor | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Operations Office | 6 | 2x4-3FO28-P18 | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | | 3 | 2x2-2FO28U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Office | 4 | 2x2-2FO28U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Office | 6 | 2x2-2FO28U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Classroom | 12 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 6 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 12 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 11 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Women's Restroom | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | Men's Restroom | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | Storage | 4 | Bare-CF42 | ID10 | (1) 17w Dimmable LED A |
| First | Classroom | 6 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Custodial Supplies | 2 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| First | | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| First | Restroom | 3 | Drum-(3)CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Stairwell | 2 | 2x2-MV100 | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Storage | 5 | 1x4-2FO28-VAP | T4L22 | (2) 10.5w 4' T8 LED B |
| First | | 1 | Bare-CF42 | ID10 | (1) 17w Dimmable LED A |
| First | Classroom | 10 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Child Study | 3 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Office | 2 | 2x4-3FO28-P18 | 7NE24 | New 30w 2x4 LED Flat Panel |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Ben Franklin Middle School Continued

| | | | | | |
|--------|----------------------|----|------------------|-------|------------------------------|
| First | Offices | 4 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Guidance | 6 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Office | 4 | 2x2-2FO28U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Office | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Art Room | 18 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | | 1 | 2x2-2FO28U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | | 2 | 1x4-1FO28-L | 3NE28 | New 40w 1x4 LED Flat Panel |
| First | Storage | 3 | Bare-CF42 | ID10 | (1) 17w Dimmable LED A |
| First | Stairwell | 3 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| First | | 1 | 2x2-MV100 | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Corridors | 41 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| First | Men's Locker Room | 16 | 1x4-2FO28-VAP | 3NE18 | New 37w 1x4 LED Vapor Tite |
| First | | 2 | Square-60A | ID08 | (1) 10w Dimmable LED A |
| First | Custodian | 1 | Bare-CF13 | ID07 | (1) 6w Dimmable LED A |
| First | Storage | 1 | Bare-CF13 | ID07 | (1) 6w Dimmable LED A |
| First | Vestibule | 2 | 1x4-2FO28-VAP | 3NE18 | New 37w 1x4 LED Vapor Tite |
| First | Office - Phy Ed | 2 | 1x4-2FO28-VAP | 3NE18 | New 37w 1x4 LED Vapor Tite |
| First | Restroom | 1 | 1x4-2FO28-VAP | 3NE18 | New 37w 1x4 LED Vapor Tite |
| First | Gym | 24 | High Bay-6FP54HO | 9NE11 | New 177w Linear LED High Bay |
| First | Office | 2 | 1x4-2FO28-VAP | 3NE18 | New 37w 1x4 LED Vapor Tite |
| First | Office - Phy Ed | 2 | 1x4-2FO28-VAP | 3NE18 | New 37w 1x4 LED Vapor Tite |
| First | Restroom | 1 | 1x4-2FO28-VAP | 3NE18 | New 37w 1x4 LED Vapor Tite |
| First | Women's Locker Room | 21 | 1x4-2FO28-VAP | 3NE18 | New 37w 1x4 LED Vapor Tite |
| First | | 2 | Square-60A | ID08 | (1) 10w Dimmable LED A |
| First | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Nurse | 3 | 1x8-4FO28-L | 3NE28 | New 40w 1x4 LED Vapor Tite |
| First | Restroom | 1 | Drum-(3)CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Storage | 1 | Drum-(3)CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Stairwell | 2 | 2x2-MV100 | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | | 1 | Square-60A | ID08 | (1) 10w Dimmable LED A |
| First | Receiving | 4 | 2x4-4FO28-Surf | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Boiler Room (Locked) | 20 | 1x4-2FO28-IH | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Men's Restroom | 3 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | Classroom | 9 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 12 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 12 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Vestibule | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| First | Corridor | 25 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| First | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | Women's Restroom | 3 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | Custodian | 1 | Bare-CF13 | ID07 | (1) 6w Dimmable LED A |
| First | Mechanical | 1 | Bare-CF42 | ID10 | (1) 17w Dimmable LED A |
| First | Stairwell | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Dressing Room | 16 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Women's Locker Room | 3 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Men's Locker Room | 3 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Lobby | 18 | 2x2-MV100 | 6NE04 | New 30w 2x2 LED Flat Panel |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Ben Franklin Middle School Continued

| | | | | | |
|--------|------------------|----|-----------------------|-------|----------------------------|
| Second | Main Office | 12 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | | 2 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second | | 1 | Square-60A | ID08 | (1) 10w Dimmable LED A |
| Second | Principal | 6 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Vestibule | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Restroom | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Asst Principal | 4 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Restroom | 1 | Drum-(2)CF13 | ID09 | (1) 12w Dimmable LED A |
| Second | Closet | 1 | Bare-60A | ID08 | (1) 10w Dimmable LED A |
| Second | Classroom | 9 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | | 3 | 2x2-2FO28U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | Men's Restroom | 1 | 1x4-2LED18-W | - | No Upgrade |
| Second | Faculty | 4 | 2x4-4FO28-Surf | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Women's Restroom | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second | | 2 | 1x2-LED20-W | - | No Upgrade |
| Second | Asst Principal | 4 | 2x4-4FO28-Surf | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Second | Stairwell | 3 | 2x2-MV100 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | Men's Restroom | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second | Lobby | 4 | 2x2-MV100 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Women's Restroom | 2 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second | Cafeteria | 42 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | | 1 | Soda Machine | S01 | Vending Miser |
| Second | Kitchen | 30 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | | 4 | Jelly-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Cooler | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Closet | 1 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| Second | Restroom | 1 | 2x4-4FO28-Surf | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Office | 1 | 2x4-4FO28-Surf | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Storage | 2 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| Second | Coolers | 4 | Jelly-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Faculty Dining | 10 | 1x4-2FO28-Surf | 3NE10 | New 23w 1x4 LED Wrap |
| Second | Stairwell | 2 | 2x2-MV100 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | Corridor | 19 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Second | | 2 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Second | Media Center | 21 | 1x8-4FO28-Fin | 5NE30 | New 41w 1x8 LED Low Bay |
| Second | | 7 | 1x4-2FO28-L | 3NE28 | New 40w 1x4 LED Flat Panel |
| Second | | 3 | 1x8-4FO28-L | 3NE28 | New 40w 1x4 LED Flat Panel |
| Second | Classroom | 6 | 2x4-3FO28-P18 (2 Bal) | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Computer Room | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Stairwell | 3 | 2x2-MV100 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | Storage (Locked) | 1 | 1x8-4FO28-Fin | 5NE30 | New 41w 1x8 LED Low Bay |
| Second | Classroom | 3 | 1x8-4FO28-W | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Women's Restroom | 3 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second | Men's Restroom | 3 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second | Classroom | 6 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 8 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 8 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 12 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Ben Franklin Middle School Continued

| | | | | | |
|----------|---------------------|----|---------------------|-------|----------------------------|
| Second | Prep Room | 1 | 1x8-4FO28-Fin | 5NE30 | New 41w 1x8 LED Low Bay |
| Second | | 1 | 1x4-2FO28-FIN | 3NE46 | New 23w 1x4 LED Low Bay |
| Second | Greenhouse (Locked) | 2 | Sconce-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Corridor | 22 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Second | | 2 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Second | Stairwell | 3 | 2x2-MV100 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | Classroom | 12 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 12 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Classroom | 12 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Vestibule | 2 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Stage | 4 | Work-LED27A | - | No Upgrade |
| Second | Chair Storage | 4 | 2x4-4FO28-L | T4L42 | (2) 10.5w 4' T8 LED B |
| Second | Auditorium | 23 | HH-300R40 | - | No Upgrade |
| Second | Dance Studio | 8 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Vestibule | 4 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Mezzanine | 1 | Bare-100A | ID09 | (1) 12w Dimmable LED A |
| Second | | 2 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Catwalk | 5 | Bare-100A | ID09 | (1) 12w Dimmable LED A |
| Second | Instrumental Music | 15 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Second | Office | 2 | 1x8-4FO28-Fin | 5NE30 | New 41w 1x8 LED Low Bay |
| Second | Vestibule | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Practice Room | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Practice Room | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Storage | 2 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| Second | Vestibule | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Restroom | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Third | Stairwell | 3 | 2x2-MV100 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Third | Office | 3 | 2x4-4FO28-Surf | 7NE24 | New 30w 2x4 LED Flat Panel |
| Third | Classroom | 8 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Third | Classroom | 12 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Third | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Third | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Third | Classroom | 12 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Third | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Third | Stairwell | 3 | 2x2-MV100 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Third | Men's Restroom | 2 | 2x4-4FO28-W | 7NE24 | New 30w 2x4 LED Flat Panel |
| Third | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Third | Women's Restroom | 4 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Third | Classroom | 10 | 2x4-3FO28-L (2 Bal) | 7NE24 | New 30w 2x4 LED Flat Panel |
| Third | | 1 | 2x2-2FO28U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| Third | Classroom | 12 | 2x4-3FO28-L (2 Bal) | 7NE24 | New 30w 2x4 LED Flat Panel |
| Third | Classroom | 9 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Third | Classroom | 12 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Third | Corridor | 28 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Exterior | Building Perimeter | 11 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| Exterior | | 3 | Flood-LED100 | - | No Upgrade |
| Exterior | | 3 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Ben Franklin Middle School Continued

| | | | | | |
|-----------|--------------|--------------|--------------------|------|-----------------------------|
| Exterior | | 1 | Wallpack-Cut-LED30 | - | No Upgrade |
| Exterior | | 1 | Jelly-CF23 | ID09 | (1) 12w Dimmable LED A |
| Exterior | | 3 | Wallpack-LED30 | - | No Upgrade |
| Exterior | | 2 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| All Areas | Emergency BB | 30 | (Battery Backup) | VE28 | Emergency Back-Up LED Strip |
| | | Total | 1116 | | |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Bryant Elementary School

| PROJECT: Teaneck PS - Bryant Elementary - R3 | | | | | |
|--|---------------------|-----------------------|----------------|---------------------------|----------------------------|
| Room Info | | Existing Fixture Info | | Lighting Fixture Upgrades | |
| X | | X | X | X | X |
| Floor | Location | No. of Fix. | Fixture Type | ECM No. | Upgrade Description |
| Ground Floor | Lobby | 6 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Ground Floor | | 2 | 1x2-1F20-S | T211 | (1) 7w 2' T8 LED B |
| Ground Floor | Corridor | 10 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Ground Floor | | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Ground Floor | Classroom | 10 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Corridor | 1 | HH-CF23 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Classroom | 10 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Restroom | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Vestibule | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Ground Floor | Men's Restroom | 1 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Library | 9 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Restroom | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Restroom | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Women's Restroom | 1 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 9 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Corridor | 7 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Ground Floor | | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Ground Floor | Vestibule | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Ground Floor | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Boiler Room (Locke) | 10 | 2x4-4FO28-Surf | T4L44 | (4) 10.5w 4' T8 LED B |
| Ground Floor | | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Corridor | 5 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Ground Floor | Office Speech | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Restroom | 1 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 1 | 1x2-2FO17-W | 1NE03 | New 18w 1x2 LED Wrap |
| Ground Floor | | 4 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Ground Floor | | 6 | 2x4-4FO28-W | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Restroom | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Ground Floor | Vestibule | 1 | HH-CF23 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Vestibule | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Classroom | 4 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Ground Floor | | 6 | 2x4-4FO28-W | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Restroom | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Ground Floor | Corridor | 28 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Ground Floor | Telecom | 1 | 2x4-4FO28-Surf | T4L44 | (4) 10.5w 4' T8 LED B |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Bryant Elementary School Continued

| | | | | | |
|--------------|---------------------|----|-------------------|-------|------------------------------|
| Ground Floor | Classroom | 8 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Restroom | 1 | 2x2-3FO17-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| Ground Floor | Classroom | 8 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Restroom | 1 | HH-CF23 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Therapy | 1 | 2x2-3FO17-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| Ground Floor | | 4 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Men's Restroom | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Custodian | 2 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| Ground Floor | | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Storage (Locked) | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Women's Restroom | 3 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 8 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 8 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Vestibule | 1 | HH-CF23 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Restroom | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Classroom | 8 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Corridor | 3 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Ground Floor | Corridor | 10 | 2x4-2FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Cafeteria | 28 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | | 3 | 2x2-2FO17-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| Ground Floor | Restroom | 1 | 1x4-2FO28-Up/Down | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Restroom | 1 | 1x4-2FO28-Up/Down | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Kitchen | 4 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Electrical | 4 | 1x4-2FO28-VAP | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Classroom | 11 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Restroom | 1 | 1x4-2FO28-Up/Down | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Office | 3 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Office | 6 | 2x4-2FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | | 1 | 2x2-2FO17-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| Ground Floor | Nurse | 7 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Restroom | 1 | 1x4-2FO28-Up/Down | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Closet | 2 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Classroom | 8 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 8 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Corridor | 1 | HH-CF23 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Restroom | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Classroom | 8 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 8 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Storage (Locked) | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Women's Restroom | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Vestibule | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Ground Floor | Main Office | 12 | 2x2-2FO28U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Ground Floor | Office | 8 | 2x2-2FO28U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Ground Floor | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Corridor | 17 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Ground Floor | | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Ground Floor | Corridor | 12 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Ground Floor | | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Ground Floor | Electrical (Locked) | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Electrical (Locked) | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Gym | 20 | High Bay-6FP54HO | 9NE11 | New 177w Linear LED High Bay |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Bryant Elementary School Continued

| | | | | | |
|--------------|--------------------|--------------|--------------------|-------|-----------------------------|
| Ground Floor | Stage | 2 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Office | 4 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Restroom | 1 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Vestibule | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Ground Floor | Study Room | 1 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Men's Restroom | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Classroom | 8 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Restroom | 1 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Open Office | 3 | 2x2-2FO28U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Ground Floor | Office | 2 | 2x2-2FO28U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Ground Floor | | 1 | Drum-60A | ID08 | (1) 10w Dimmable LED A |
| Ground Floor | Restroom | 1 | Drum-60A | ID08 | (1) 10w Dimmable LED A |
| Ground Floor | Office | 2 | 2x2-2FO28U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Ground Floor | Office | 2 | 2x2-2FO28U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Basement | Corridor | 2 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| Basement | Storage | 2 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| Basement | Closet (Locked) | 1 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| Second Floor | Stairwell | 1 | 2x4-4FO28-Surf | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second Floor | Faculty | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Restroom | 1 | Sconce-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second Floor | Corridor | 2 | 2x4-4FO28-Surf | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second Floor | Women's Restroom | 1 | 2x4-4FO28-Surf | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second Floor | Roof Access | 1 | Bare-CF32 | ID09 | (1) 12w Dimmable LED A |
| Exterior | Building Perimeter | 1 | Chandelier-CF23 | ID09 | (1) 12w Dimmable LED A |
| Exterior | | 2 | Flood-HPS70 | HN95 | New 31w LED Flood |
| Exterior | | 5 | Wallpack-Cut-LED30 | - | No Upgrade |
| Exterior | | 1 | Flood-LED45 | - | No Upgrade |
| Exterior | | 1 | Wallpack-LED40 | - | No Upgrade |
| Exterior | | 1 | Canopy-HPS70 | HN230 | New 30w LED Canopy |
| Exterior | | 3 | Wallpack-HPS70 | HN72 | New 28w LED Cutoff Wallpack |
| Exterior | | 2 | Sconce-CF23 | ID09 | (1) 12w Dimmable LED A |
| Exterior | Courtyard | 2 | Flood-HPS100 | HN95 | New 31w LED Flood |
| Exterior | | 1 | Flood-LED25 | - | No Upgrade |
| All Areas | Emergency BB | 30 | (Battery Backup) | VE28 | Emergency Back-Up LED Strip |
| | | Total | 512 | | |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Hawthorne Elementary School

| PROJECT: Teaneck PS - Hawthorne ES - R3 | | | | | |
|---|------------------|-----------------------|---------------------|---------------------------|------------------------------|
| Room Info | | Existing Fixture Info | | Lighting Fixture Upgrades | |
| x | | x | x | x | x |
| Floor | Location | No. of Fix. | Fixture Type | ECM No. | Upgrade Description |
| Ground Floor | Main Office | 6 | 2x4-3FO28-P18 (2 Ba | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | | 1 | HH8-2PL26 | IN18 | New 12w 8-Inch LED Downlight |
| Ground Floor | Office | 4 | 2x4-3FO28-P18 (2 Ba | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Copy Room | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Ground Floor | Corridor | 14 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | | 6 | HH8-2PL26 | IN18 | New 12w 8-Inch LED Downlight |
| Ground Floor | | 2 | 2x4-4FO28-Drop | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Conference Room | 4 | 2x4-3FO28-P18 (2 Ba | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 12 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 12 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 12 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 12 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 12 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Women's Restroom | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | | 2 | HH8-2PL26 | IN18 | New 12w 8-Inch LED Downlight |
| Ground Floor | Storage | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Men's Restroom | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | | 2 | HH8-2PL26 | IN18 | New 12w 8-Inch LED Downlight |
| Ground Floor | Electrical | 1 | 1x4-2FO28-VAP | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Custodian | 1 | 1x4-2FO28-VAP | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Nurse | 7 | 2x4-3FO28-L (2 Bal) | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Restroom | 1 | 1x4-2FO28-WW | 3NE46 | New 23w 1x4 LED Low Bay |
| Ground Floor | Exam Room | 1 | 2x4-3FO28-P18 | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Storage | 1 | 1x4-2FO28-VAP | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Storage | 1 | 1x4-2FO28-VAP | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Corridor | 12 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 8 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 8 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 8 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 8 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Custodian | 1 | Bare-CF32 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Restroom | 1 | 2x2-2LED9-L | - | No Upgrade |
| Ground Floor | Lobby | 10 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Ground Floor | | 7 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | | 1 | 1x3-1FO25-S | T311 | (1) 12w 3' T8 LED B |
| Ground Floor | Closet | 2 | Bare-CF32 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Office | 1 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Office | 4 | 2x4-3FO28-P18 | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 9 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 9 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Hawthorne Elementary School Continued

| | | | | | |
|--------------|------------------|----|---------------------|-------|------------------------------|
| Ground Floor | Corridor | 13 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Men's Restroom | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | | 2 | HH8-2PL26 | IN18 | New 12w 8-Inch LED Downlight |
| Ground Floor | Electrical | 1 | 1x4-2FO28-VAP | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Custodian | 1 | 1x4-2FO28-VAP | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Storage | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Women's Restroom | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | | 2 | HH8-2PL26 | IN18 | New 12w 8-Inch LED Downlight |
| Ground Floor | Cafeteria | 32 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Kitchen | 4 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Storage | 5 | 1x4-2FO28-VAP | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Classroom | 12 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 12 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 12 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 12 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Corridor | 13 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | | 2 | 2x4-4FO28-Drop | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | | 6 | HH8-2PL26 | IN18 | New 12w 8-Inch LED Downlight |
| Ground Floor | Classroom | 9 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 10 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Corridor | 13 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 10 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Storage (Locked) | 1 | 1x4-2F40-L | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Classroom | 3 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 9 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Vestibule | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 15 | 1x4-2FO28-W | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Restroom | 1 | Drum-CF32 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Closet | 1 | Bare-CF32 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Classroom | 17 | 1x4-2FO28-W | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Restroom | 1 | Drum-CF32 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Closet | 1 | Bare-CF32 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Classroom | 8 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 9 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 9 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Vestibule | 1 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Corridor | 15 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Corridor | 5 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Men's Restroom | 4 | 1x4-2FO28-L | 3NE28 | New 40w 1x4 LED Flat Panel |
| Ground Floor | Office | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Conference Room | 3 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Office | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Restroom | 1 | 1x4-2F40-L | 3NE28 | New 40w 1x4 LED Flat Panel |
| Ground Floor | Women's Restroom | 4 | 1x4-2FO28-L | 3NE28 | New 40w 1x4 LED Flat Panel |
| Ground Floor | Classroom | 12 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Custodian | 1 | Bare-CF32 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Storage | 2 | 2x4-4F40-W | T4L42 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Classroom | 8 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 8 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Classroom | 12 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Stage | 2 | Jelly-CF32 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Gym | 24 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Hawthorne Elementary School Continued

| | | | | | |
|--------------|--------------------|--------------|---------------------|-------|-----------------------------|
| Ground Floor | Storage | 1 | 2x4-4F40-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Classroom | 9 | 2x4-3FO28-P18 (2 Ba | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Copy Room | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Men's Restroom | 3 | 1x4-2FO28-L | 3NE28 | New 40w 1x4 LED Flat Panel |
| Ground Floor | Custodian | 1 | Bare-CF32 | ID09 | (1) 12w Dimmable LED A |
| Ground Floor | Storage | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Women's Restroom | 4 | 1x4-2FO28-L | 3NE28 | New 40w 1x4 LED Flat Panel |
| Ground Floor | Classroom | 10 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | Library | 22 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Ground Floor | | 1 | 1x4-2FO28-S | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground Floor | Workroom (Locked) | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground Floor | Storage (Locked) | 1 | 1x4-2F40-L | T4L22 | (2) 10.5w 4' T8 LED B |
| Second Floor | Stairwell | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Second Floor | Lounge | 10 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second Floor | Restroom | 1 | Drum-CF32 | ID09 | (1) 12w Dimmable LED A |
| Second Floor | Kitchenette | 1 | Drum-CF32 | ID09 | (1) 12w Dimmable LED A |
| Second Floor | Restroom | 1 | Drum-CF32 | ID09 | (1) 12w Dimmable LED A |
| Basement | Boiler Room | 4 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| Basement | | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Basement | | 1 | 1x4-2LED18-W | - | No Upgrade |
| Exterior | Building Perimeter | 4 | Wallpack-LED30 | - | No Upgrade |
| Exterior | | 8 | Wallpack-HPS150 | HN72 | New 28w LED Cutoff Wallpack |
| Exterior | | 14 | Flood-HPS150 | HN102 | New 74w LED Flood |
| Exterior | Courtyard | 4 | Wallpack-HPS150 | HN72 | New 28w LED Cutoff Wallpack |
| Exterior | Canopy | 12 | 1x4-1FO28-VAP | T4L11 | (1) 10.5w 4' T8 LED B |
| All Areas | Emergency BB | 30 | (Battery Backup) | \E28 | Emergency Back-Up LED Strip |
| | | Total | 687 | | |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Lowell Elementary School

| PROJECT: Teaneck PS - Lowell Elementary - R3 | | | | | |
|--|--------------------|-----------------------|---------------------|---------------------------|------------------------------|
| Room Info | | Existing Fixture Info | | Lighting Fixture Upgrades | |
| x | | x | x | x | x |
| Floor | Location | No. of Fix. | Fixture Type | ECM No. | Upgrade Description |
| Second | Office | 3 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Classroom | 2 | 2x4-3FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 4 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Women's Restroom | 1 | 2x2-2FO28U-L | 6NE01 | New 20w 2x2 LED Flat Panel |
| Second | | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Stairwell | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Men's Restroom | 1 | 2x2-2FO28U-L | 6NE01 | New 20w 2x2 LED Flat Panel |
| Second | | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 8 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Storage (Locked) | 2 | 1x4-2FO28-Surf | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Corridor | 21 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Second | Corridor | 12 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Stairwell | 4 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 9 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Library (Locked) | 20 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | | 9 | HH8-2PL18 | IN18 | New 12w 8-Inch LED Downlight |
| Second | Copy Room (Locked) | 5 | 2x4-3FO28-L (2 Bal) | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Closet (Locked) | 1 | 2x2-2F40U-L | T2UR2 | (2) 7w 2' T8 LED B-Ref |
| Second | Classroom | 12 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 12 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 12 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Gym | 3 | 2x4-3FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second | Mechanical | 6 | 1x4-2FO28-VAP | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Stairwell | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Men's Restroom | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Women's Restroom | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Custodian | 1 | 1x4-2FO28-VAP | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Corridor | 8 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Custodian | 1 | 1x4-2FO28-VAP | T4L22 | (2) 10.5w 4' T8 LED B |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Lowell Elementary School Continued

| | | | | | |
|--------|-----------------------|----|---------------------|-------|------------------------------|
| Second | Storage | 1 | 1x4-2FO28-VAP | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Open Office | 6 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Office | 4 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Work Area | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Nurse | 8 | 2x4-3FO28-P18 | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Restroom | 1 | 1x4-2FO28-Dir/Ind | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Closet | 1 | 2x2-2F40U-L | T2UR2 | (2) 7w 2' T8 LED B-Ref |
| First | Classroom | 16 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Closet | 1 | Bare-200A | ID09 | (1) 12w Dimmable LED A |
| First | Vestibule | 1 | Bare-200A | ID09 | (1) 12w Dimmable LED A |
| First | Classroom | 5 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Stairwell | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | | 1 | 1x4-2FO28-Surf | 3NE10 | New 23w 1x4 LED Wrap |
| First | Classroom | 11 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 12 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 12 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 7 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Lounge | 8 | 2x4-3FO28-L (2 Bal) | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Restroom | 1 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Restroom | 1 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Vestibule | 2 | 1x4-4FO28-Surf | 3NE10 | New 23w 1x4 LED Wrap |
| First | Classroom (Locked) | 12 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 12 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 12 | 2x4-3FO28-L (2 Bal) | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Cafeteria | 35 | 2x4-3FO28-L (2 Bal) | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Elevator Machine (Loc | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Pantry | 4 | 1x4-2FO28-L | 3NE28 | New 40w 1x4 LED Flat Panel |
| First | Electrical | 4 | 1x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Vestibule | 3 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | | 4 | 1x8-4FO28-Up/Dow | T8L44 | (4) 10.5w 4' T8 LED B |
| First | Men's Restroom | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Women's Restroom (L | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Custodian (Locked) | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Custodian | 1 | 1x4-2FO28-VAP | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Storage | 1 | 1x4-2FO28-VAP | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Gym | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | | 8 | High Bay-6FP54HO | 9NE11 | New 177w Linear LED High Bay |
| First | Stage | 2 | Bare-CF32 | ID10 | (1) 17w Dimmable LED A |
| First | | 2 | Flood-300Q | HN95 | New 31w LED Flood |
| First | | 4 | Bare-200A | ID10 | (1) 17w Dimmable LED A |
| First | Storage | 1 | 2x4-4F40-Egg | 3NE10 | New 23w 1x4 LED Wrap |
| First | Storage (Locked) | 1 | 2x4-4F40-Egg | 3NE10 | New 23w 1x4 LED Wrap |
| First | Corridor | 12 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Corridor | 8 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Corridor | 4 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| First | | 3 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| First | Vestibule | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| First | Custodian (Locked) | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Women's Restroom | 1 | 2x2-2FO28U-L | 6NE01 | New 20w 2x2 LED Flat Panel |
| First | | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Lowell Elementary School Continued

| | | | | | |
|-----------|--------------------|--------------|-------------------|-------|-------------------------------|
| First | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Restroom (Locked) | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Stairwell | 1 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| First | | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| First | Men's Restroom | 1 | 2x2-2FO28U-L | 6NE01 | New 20w 2x2 LED Flat Panel |
| First | | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Restroom (Locked) | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| First | Corridor | 15 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| First | | 1 | 1x3-1FO25-S | T311 | (1) 12w 3' T8 LED B |
| Basement | Stairwell | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Basement | | 2 | 1x4-2FO28-VAP | 3NE10 | New 23w 1x4 LED Wrap |
| Basement | Electrical | 2 | 1x4-2FO28-VAP | 3NE10 | New 23w 1x4 LED Wrap |
| Basement | Corridor | 2 | 1x4-2FO28-VAP | 3NE10 | New 23w 1x4 LED Wrap |
| Basement | | 1 | 2x4-4FO28-Surf | 7NE24 | New 30w 2x4 LED Flat Panel |
| Basement | Corridor | 4 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Basement | Storage (Locked) | 8 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Basement | Pump | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Basement | Boiler Room | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Basement | | 4 | 2x4-4FO28-Surf | 7NE24 | New 30w 2x4 LED Flat Panel |
| Basement | | 2 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Basement | | 1 | 1x4-2FO28-IH | 3NE10 | New 23w 1x4 LED Wrap |
| Basement | Fire Control | 1 | 2x4-4FO28-Surf | 7NE24 | New 30w 2x4 LED Flat Panel |
| Exterior | Building Perimeter | 2 | Sconce-CF23 | ID09 | (1) 12w Dimmable LED A |
| Exterior | | 1 | Wallpack-Cut-HPS7 | HN72 | New 28w LED Cutoff Wallpack |
| Exterior | | 2 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| Exterior | | 1 | Sconce-CF23 | ID09 | (1) 12w Dimmable LED A |
| Exterior | | 2 | Wallpack-HPS150 | HN74 | New 42.7w LED Cutoff Wallpack |
| Exterior | | 2 | Flood-HPS150 | HN103 | New 89w LED Flood |
| Exterior | | 8 | Wallpack-LED20 | - | No Upgrade |
| Exterior | | 2 | Flood-LED25 | - | No Upgrade |
| Exterior | | 1 | Canopy-LED15 | - | No Upgrade |
| All Areas | Emergency BB | 30 | (Battery Backup) | \E28 | Emergency Back-Up LED Strip |
| | | Total | 588 | | |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Teaneck High School

| PROJECT: Teaneck PS - High School - R3 | | | | | |
|--|------------------|-----------------------|-----------------|---------------------------|--------------------------|
| Room Info | | Existing Fixture Info | | Lighting Fixture Upgrades | |
| x | | x | x | x | x |
| Floor | Location | No. of Fix. | Fixture Type | ECM No. | Upgrade Description |
| Basement | Stairwell | 1 | 1x4-2FO28-Surf | T4L22 | (2) 10.5w 4' T8 LED B |
| Basement | | | Jelly-CF23 | ID09 | (1) 12w Dimmable LED A |
| Basement | Vestibule | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Basement | Storage | 2 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Basement | Storage | 4 | 1x8-4FO28-S | T8L44 | (4) 10.5w 4' T8 LED B |
| Basement | Storage (Locked) | 2 | 1x8-4FO28-S | T8L44 | (4) 10.5w 4' T8 LED B |
| Basement | Stairwell | 1 | 1x4-2FO28-Surf | T4L22 | (2) 10.5w 4' T8 LED B |
| Basement | | 1 | 1x4-1FO28-S | T4L11 | (1) 10.5w 4' T8 LED B |
| Basement | Vestibule | 1 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| Basement | Storage | 2 | 1x4-2FO28-IH | T4L22 | (2) 10.5w 4' T8 LED B |
| Basement | Storage | 1 | 1x8-2FO28-W | T8L22 | (2) 10.5w 4' T8 LED B |
| Basement | Storage | 2 | 2x4-4FO28-W | T4L42 | (2) 10.5w 4' T8 LED B |
| Basement | | 1 | 1x8-2FO28-W | T8L22 | (2) 10.5w 4' T8 LED B |
| Basement | | 1 | 1x4-2FO28-S | T4L22 | (2) 10.5w 4' T8 LED B |
| Basement | Storage | 2 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Gym Lobby | 12 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| First | | 4 | 2x4-3FO28-L (E) | T4EL32 | (2) 10.5w 4' T8 LED B-BB |
| First | Closet | 1 | 1x4-2FO28-S | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Women's RR | 1 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| First | | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Men's RR | 1 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| First | | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Closet | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Vestibule | 2 | 2x2-2FO28U-L | T2UR2 | (2) 7w 2' T8 LED B-Ref |
| First | Closet | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Corridor | 3 | 1x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| First | | 3 | 1x4-2FO28-L (E) | T4EL22 | (2) 10.5w 4' T8 LED B-BB |
| First | | 1 | 2x2-2FO28U-L | T2UR2 | (2) 7w 2' T8 LED B-Ref |
| First | Football LR | 9 | 1x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| First | | 3 | 1x4-2FO28-L (E) | T4EL22 | (2) 10.5w 4' T8 LED B-BB |
| First | Vestibule | 1 | 2x2-2FO28U-L | T2UR2 | (2) 7w 2' T8 LED B-Ref |
| First | Volleyball LR | 5 | 1x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| First | | 3 | 1x4-2FO28-L (E) | T4EL22 | (2) 10.5w 4' T8 LED B-BB |
| First | Men's LR | 12 | 1x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| First | | 5 | 1x4-2FO28-L (E) | T4EL22 | (2) 10.5w 4' T8 LED B-BB |
| First | | 1 | 2x2-2FO28U-L | T2UR2 | (2) 7w 2' T8 LED B-Ref |
| First | Locker Room | 1 | 2x4-4FO28-L | T4L42 | (2) 10.5w 4' T8 LED B |
| First | Office | 4 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Teaneck High School Continued

| | | | | | |
|-------|-----------------|----|--------------------------------------|---------------|---|
| First | Restroom | 1 | 1x4-2FO28-Van | T8L22 | (2) 10.5w 4' T8 LED B |
| First | Storage | 1 | 2x4-4FO28-L | T4L42 | (2) 10.5w 4' T8 LED B |
| First | Storage | 1 | Square-60A | ID08 | (1) 10w Dimmable LED A |
| First | Vestibule | 1 | 1x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Gym | 34 | High Bay-6FP54HO (Battery Backup) | 9NE24 \E28 | New 150w Linear LED High Bay Emergency Back-Up LED Strip |
| First | Women's LR | 10 | 1x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| First | | 7 | 1x4-2FO28-L (E) | T4EL22 | (2) 10.5w 4' T8 LED B-BB |
| First | | 1 | 2x2-2FO28U-L | T2UR2 | (2) 7w 2' T8 LED B-Ref |
| First | LR (Locked) | 1 | 2x4-4FO28-L | T4L42 | (2) 10.5w 4' T8 LED B |
| First | Office (Locked) | 4 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| First | RR (Locked) | 1 | 1x4-2FO28-Van | T8L22 | (2) 10.5w 4' T8 LED B |
| First | Corridor | 4 | 2x2-3F31U-L | 6NE01 | New 20w 2x2 LED Flat Panel |
| First | Stairwell | 2 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Women's RR | 3 | 2x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Book Room | 1 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| First | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Storage | 2 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Classroom | 8 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Corridor | 3 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| First | | 2 | 1x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Mechanical | 1 | 1x4-2FO28-S | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Corridor | 14 | 2x2-3F31U-L | 6NE01 | New 20w 2x2 LED Flat Panel |
| First | | 1 | 1x4-1FO28-S | T4L11 | (1) 10.5w 4' T8 LED B |
| First | Men's RR | 3 | 2x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| First | | 2 | 2x2-3F31U-L | T2UR3 | (3) 7w 2' T8 LED B-Ref |
| First | Closet | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Stairwell | 1 | 1x4-2LED15-W | - | No Upgrade |
| First | | 1 | 1x4-2FO28-Van | T8L22 | (2) 10.5w 4' T8 LED B |
| First | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Classroom | 6 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Classroom | 10 | 2x4-4FO28-P.5 | T4L44 | (4) 10.5w 4' T8 LED B |
| First | Guidance | 2 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Office | 4 | 2x2-3F31U-L | 6NE01 | New 20w 2x2 LED Flat Panel |
| First | Office | 3 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| First | Break Room | 2 | 2x2-3F31U-L | 6NE01 | New 20w 2x2 LED Flat Panel |
| First | Closet | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Closet | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Vestibule | 1 | Drum-(2)CF13 | IN30 | New 24w 16-Inch LED Deco Flush M |
| First | Office | 2 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| First | Corridor | 13 | 2x2-3F31U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Stairwell | 1 | 1x4-2FP28-Dir/Ind | 3NE10 | New 23w 1x4 LED Wrap |
| First | | 1 | 1x4-2FO28-Van | T8L22 | (2) 10.5w 4' T8 LED B |
| First | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Classroom | 8 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Teaneck High School Continued

| | | | | | |
|-------|------------------|----|--------------------|-------|----------------------------|
| First | Open Office | 4 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Vestibule | 1 | 2x2-3F31U-L | 6NE01 | New 20w 2x2 LED Flat Panel |
| First | Storage | 1 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| First | Conference Rm | 1 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Open Office | 8 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Lobby | 16 | 2x2-3F31U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | | 3 | 1x4-1FO28-S | T4L11 | (1) 10.5w 4' T8 LED B |
| First | | 2 | 1x3-1FO25-S | T311 | (1) 12w 3' T8 LED B |
| First | Corridor | 5 | 2x2-3F31U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | | 1 | 2x2-2FO28U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Nurse | 11 | 2x2-2F40BX-Dir/Ind | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Storage | 2 | 2x2-3F40BX-L | 6NE01 | New 20w 2x2 LED Flat Panel |
| First | Office | 4 | 2x2-2F40BX-Dir/Ind | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Conference Rm | 2 | 2x2-2F40BX-Dir/Ind | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Storage | 1 | 2x2-3F40BX-L | 6NE01 | New 20w 2x2 LED Flat Panel |
| First | Exam Room | 2 | 2x2-2F40BX-Dir/Ind | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Restroom | 1 | 2x2-2FO28U-L | T2UR2 | (2) 7w 2' T8 LED B-Ref |
| First | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Shop | 6 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| First | Storage | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Classroom | 5 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| First | | 2 | 2x2-3F31U-L | T2UR3 | (3) 7w 2' T8 LED B-Ref |
| First | Classroom | 4 | 2x2-3F31U-L | 6NE01 | New 20w 2x2 LED Flat Panel |
| First | Restroom | 3 | 2x2-3F31U-L | 6NE01 | New 20w 2x2 LED Flat Panel |
| First | Office | 5 | 2x4-3FO28-P18 | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Closet | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Storage | 2 | 1x8-2FO28-W | T8L22 | (2) 10.5w 4' T8 LED B |
| First | Storage | 2 | Bare-100A | ID09 | (1) 12w Dimmable LED A |
| First | Storage (Locked) | 3 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| First | Storage (Locked) | 3 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| First | Fire Alarm | 3 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| First | Maintenance | 3 | 2x4-4FO28-Surf | T4L44 | (4) 10.5w 4' T8 LED B |
| First | Lounge | 2 | 1x8-2FO28-W | T8L22 | (2) 10.5w 4' T8 LED B |
| First | Storage | 2 | 1x8-2FO28-W | T8L22 | (2) 10.5w 4' T8 LED B |
| First | | 1 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| First | Office | 1 | 1x8-4FO28-S | T8L44 | (4) 10.5w 4' T8 LED B |
| First | Corridor | 2 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| First | Boiler Room | 9 | 2x4-2FO28-Surf | T4L22 | (2) 10.5w 4' T8 LED B |
| First | | 13 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Electrical | 1 | 2x4-2FO28-Surf | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Office | 3 | 2x4-2FO28-Surf | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Pump Room | 2 | 2x4-2FO28-Surf | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Electrical | 1 | 1x8-4F40-W | T8L44 | (4) 10.5w 4' T8 LED B |
| First | Stairwell | 2 | Bare-LED8A | - | No Upgrade |
| First | Corridor | 6 | 2x2-3F31U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | | 3 | 1x8-2FO28-W | T8L22 | (2) 10.5w 4' T8 LED B |
| First | Storage | 11 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| First | Stairwell | 1 | 2x4-4FO28-Surf | T4L44 | (4) 10.5w 4' T8 LED B |
| First | Stairwell | 2 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Corridor | 9 | 2x2-3F31U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | | 2 | 1x4-1FO28-S | T4L11 | (1) 10.5w 4' T8 LED B |
| First | Open Office | 3 | 2x2-3F31U-L | 6NE04 | New 30w 2x2 LED Flat Panel |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Teaneck High School Continued

| | | | | | |
|-------|--------------|----|---------------------|-------|----------------------------|
| First | | 4 | 1x12-6FO28-Dir/Ind | T8L66 | (6) 10.5w 4' T8 LED B |
| First | | 2 | 1x8-4FO28-Dir/Ind | T8L44 | (4) 10.5w 4' T8 LED B |
| First | | 6 | 2x2-3F31U-P9 | T2UR3 | (3) 7w 2' T8 LED B-Ref |
| First | | 4 | 2x4-3FO28-P18 | T4L33 | (3) 10.5w 4' T8 LED B |
| First | | 1 | Soda Machine | S01 | Vending Miser |
| First | Locker Room | 3 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| First | Workroom | 2 | 2x2-3F31U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Workroom | 2 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Stairwell | 2 | 1x4-2LED15-W | - | No Upgrade |
| First | Mail Room | 2 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Copy Room | 2 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| First | Open Office | 9 | 2x2-LED30-Vol | - | No Upgrade |
| First | Office | 4 | 2x2-LED30-Vol | - | No Upgrade |
| First | Office | 4 | 2x2-LED30-Vol | - | No Upgrade |
| First | Office | 6 | 2x2-LED30-Vol | - | No Upgrade |
| First | Office | 4 | 2x2-LED30-Vol | - | No Upgrade |
| First | Office | 6 | 2x2-LED30-Vol | - | No Upgrade |
| First | Office | 4 | 2x2-LED30-Vol | - | No Upgrade |
| First | Office | 4 | 2x2-LED30-Vol | - | No Upgrade |
| First | Restroom | 1 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| First | Restroom | 1 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| First | Restroom | 1 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| First | Custodian | 1 | Bare-LED8A | - | No Upgrade |
| First | Corridor | 7 | 2x2-3F31U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Wellness Ctr | 12 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | | 1 | 2x2-3F31U-L | T2UR3 | (3) 7w 2' T8 LED B-Ref |
| First | Office | 4 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| First | Weight Room | 27 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| First | Storage | 1 | 1x4-2FO28-Surf | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Storage | 1 | 1x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Corridor | 13 | 2x2-3F31U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Men's LR | 14 | 1x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Men's RR | 3 | 2x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Women's RR | 3 | 2x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Women's LR | 14 | 1x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Classroom | 6 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Stairwell | 1 | 1x4-2FP54HO-Dir/Ind | 3NE10 | New 23w 1x4 LED Wrap |
| First | Corridor | 7 | 2x2-3F31U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Studio | 12 | 2x4-LED30-L | - | No Upgrade |
| First | | 2 | 2x2-LED20-L | - | No Upgrade |
| First | Locker Room | 2 | 2x4-LED30-L | - | No Upgrade |
| First | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Corridor | 23 | 2x2-3F31U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | | 1 | 1x4-1FO28-S | T4L11 | (1) 10.5w 4' T8 LED B |
| First | Office | 1 | 2x4-4FO28-Surf | T4L44 | (4) 10.5w 4' T8 LED B |
| First | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Stairwell | 1 | 1x4-2FP54HO-Dir/Ind | 3NE10 | New 23w 1x4 LED Wrap |
| First | | 1 | 1x4-2LED15-W | - | No Upgrade |
| First | Aux Gym | 12 | 2x2-4F40BX-L | 6NE40 | New 92w 2x2 LED Troffer |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Teaneck High School Continued

| | | | | | |
|--------|----------------|----|-----------------|-------|----------------------------------|
| First | Storage | 2 | 1x4-2FO28-IH | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Storage | 1 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| First | Office | 1 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Restroom | 1 | 2x2-3F31U-L | 6NE01 | New 20w 2x2 LED Flat Panel |
| First | Vestibule | 1 | 2x2-3F31U-L | 6NE01 | New 20w 2x2 LED Flat Panel |
| First | Mechanical | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Aux Gym | 12 | 2x2-4F40BX-L | 6NE40 | New 92w 2x2 LED Troffer |
| First | Vestibule | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Office | 1 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Restroom | 1 | 2x2-3F31U-L | 6NE01 | New 20w 2x2 LED Flat Panel |
| First | Storage | 2 | 1x4-2FO28-IH | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Stairwell | 1 | 1x4-2FO28-Van | T8L22 | (2) 10.5w 4' T8 LED B |
| First | | 1 | 1x4-2LED15-W | - | No Upgrade |
| First | Home Econ. | 17 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| First | Vestibule | 1 | 2x4-4FO28-L | T4L42 | (2) 10.5w 4' T8 LED B |
| First | Office | 2 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| First | Storage | 1 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| First | | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Closet | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| First | Closet | 1 | 2x2-2FO28U-L | T2UR2 | (2) 7w 2' T8 LED B-Ref |
| First | Classroom | 15 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| First | Storage | 2 | 2x4-4FO28-L | T4L42 | (2) 10.5w 4' T8 LED B |
| First | Office | 1 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| First | Classroom | 12 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| First | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| First | Stairwell | 1 | 1x4-2FO28-Van | T8L22 | (2) 10.5w 4' T8 LED B |
| First | | 1 | 1x4-2LED15-W | - | No Upgrade |
| Second | Lobby | 44 | Chandelier-CF9C | I16 | (1) 5w LED Clear Candle |
| Second | | 6 | 1x4-2FO28-Van | T8L22 | (2) 10.5w 4' T8 LED B |
| Second | Asst Principal | 12 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | Vault | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Office | 8 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | Office | 8 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | Restroom | 2 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Stairwell | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | | 1 | 1x4-2LED15-W | - | No Upgrade |
| Second | Classroom | 6 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Classroom | 6 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Book Room | 3 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Office | 2 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| Second | Restroom | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Storage | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Vestibule | 1 | Drum-(3)CF23 | IN30 | 12w 24w 16-Inch LED Deco Flush M |
| Second | Open Office | 5 | 2x2-LED30-Vol | - | No Upgrade |
| Second | Office | 4 | 2x2-LED30-Vol | - | No Upgrade |
| Second | Office | 4 | 2x2-LED30-Vol | - | No Upgrade |
| Second | Office | 4 | 2x2-LED30-Vol | - | No Upgrade |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Teaneck High School Continued

| | | | | | |
|--------|-------------|----|--------------------|-------|----------------------------|
| Second | Office | 4 | 2x2-LED30-Vol | - | No Upgrade |
| Second | Office | 4 | 2x2-LED30-Vol | - | No Upgrade |
| Second | Office | 4 | 2x2-LED30-Vol | - | No Upgrade |
| Second | Stairwell | 2 | 1x4-2LED15-W | - | No Upgrade |
| Second | Restroom | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Men's RR | 5 | 2x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Classroom | 3 | 1x12-6FO28-Dir/Ind | T8L66 | (6) 10.5w 4' T8 LED B |
| Second | | 5 | 1x8-4FO28-Dir/Ind | T8L44 | (4) 10.5w 4' T8 LED B |
| Second | | 4 | 2x2-2FO28U-L | T2UR3 | (3) 7w 2' T8 LED B-Ref |
| Second | Storage | 1 | 2x4-4FO28-L | T4L42 | (2) 10.5w 4' T8 LED B |
| Second | Classroom | 3 | 1x12-6FO28-Dir/Ind | T8L66 | (6) 10.5w 4' T8 LED B |
| Second | | 4 | 1x8-4FO28-Dir/Ind | T8L44 | (4) 10.5w 4' T8 LED B |
| Second | | 1 | 2x2-2FO28U-L | T2UR3 | (3) 7w 2' T8 LED B-Ref |
| Second | Storage | 1 | 2x4-4FO28-L | T4L42 | (2) 10.5w 4' T8 LED B |
| Second | Classroom | 3 | 1x12-6FO28-Dir/Ind | T8L66 | (6) 10.5w 4' T8 LED B |
| Second | | 5 | 1x8-4FO28-Dir/Ind | T8L44 | (4) 10.5w 4' T8 LED B |
| Second | | 1 | 2x2-2FO28U-L | T2UR3 | (3) 7w 2' T8 LED B-Ref |
| Second | Storage | 1 | 2x4-4FO28-L | T4L42 | (2) 10.5w 4' T8 LED B |
| Second | Classroom | 5 | 1x12-6FO28-Dir/Ind | T8L66 | (6) 10.5w 4' T8 LED B |
| Second | | 4 | 1x8-4FO28-Dir/Ind | T8L44 | (4) 10.5w 4' T8 LED B |
| Second | Classroom | 2 | 1x12-6FO28-Dir/Ind | T8L66 | (6) 10.5w 4' T8 LED B |
| Second | | 6 | 1x8-4FO28-Dir/Ind | T8L44 | (4) 10.5w 4' T8 LED B |
| Second | | 1 | 2x2-2FO28U-L | T2UR3 | (3) 7w 2' T8 LED B-Ref |
| Second | Office | 1 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| Second | Classroom | 3 | 1x12-6FO28-Dir/Ind | T8L66 | (6) 10.5w 4' T8 LED B |
| Second | | 5 | 1x8-4FO28-Dir/Ind | T8L44 | (4) 10.5w 4' T8 LED B |
| Second | | 4 | 2x2-2FO28U-L | T2UR3 | (3) 7w 2' T8 LED B-Ref |
| Second | Storage | 1 | 2x4-4FO28-L | T4L42 | (2) 10.5w 4' T8 LED B |
| Second | Women's RR | 5 | 2x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Restroom | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Stairwell | 2 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Corridor | 37 | 1x4-2FO28-Van | T8L22 | (2) 10.5w 4' T8 LED B |
| Second | Office | 2 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| Second | Vocal Music | 24 | 2x4-LED30-L | - | No Upgrade |
| Second | | 3 | 2x2-LED30-Vol | - | No Upgrade |
| Second | Practice Rm | 2 | 2x4-LED30-L | - | No Upgrade |
| Second | Office | 2 | 2x4-LED30-L | - | No Upgrade |
| Second | Corridor | 8 | 1x4-2FO28-Van | T8L22 | (2) 10.5w 4' T8 LED B |
| Second | Stairwell | 2 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Classroom | 6 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Book Room | 6 | 2x4-4FO28-L | T4L42 | (2) 10.5w 4' T8 LED B |
| Second | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Corridor | 20 | 1x4-2FO28-Van | T8L22 | (2) 10.5w 4' T8 LED B |
| Second | Guidance | 23 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | | 4 | 1x12-6FO28-Dir/Ind | T8L66 | (6) 10.5w 4' T8 LED B |
| Second | | 5 | 1x8-4FO28-Dir/Ind | T8L44 | (4) 10.5w 4' T8 LED B |
| Second | Storage | 1 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| Second | Office | 6 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Teaneck High School Continued

| | | | | | |
|--------|---------------|----|--------------------|-------|--------------------------------|
| Second | Office | 2 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | Office | 2 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | Office | 2 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | Office | 2 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | Office | 2 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | Conference Rm | 4 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | Office | 4 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | Closet | 1 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| Second | Office | 4 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | Office | 4 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | Library | 24 | 1x12-6FO28-Dir/Ind | T8L66 | (6) 10.5w 4' T8 LED B |
| Second | | 12 | 1x8-4FO28-Dir/Ind | T8L44 | (4) 10.5w 4' T8 LED B |
| Second | | 1 | 1x4-2FO28-Dir/Ind | T8L22 | (2) 10.5w 4' T8 LED B |
| Second | | 11 | 2x2-4FP14-Dir/Ind | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | | 4 | 1x4-2FO28-Tube | T8L22 | (2) 10.5w 4' T8 LED B |
| Second | | 9 | HH6-2PL26 | IN22 | New 13.5w 6-Inch LED Downlight |
| Second | | 8 | 2x2-3F40BX | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | | 10 | Sconce-50MR16 | I04 | (1) 7w LED MR16 (12v) |
| Second | | 2 | 1x4-1FO28-S | T4L11 | (1) 10.5w 4' T8 LED B |
| Second | Workroom | 8 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| Second | Workroom | 2 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Corridor | 4 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| Second | Classroom | 12 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | | 12 | HH6-2PL26 | IN22 | New 13.5w 6-Inch LED Downlight |
| Second | Storage | 2 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| Second | Storage | 2 | HH6-2PL26 | IN22 | New 13.5w 6-Inch LED Downlight |
| Second | Classroom | 6 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Stairwell | 2 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Electrical | 1 | 1x4-2FO28-Surf | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Main Office | 15 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | Copy Room | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Office | 6 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Second | Storage | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Vestibule | 1 | 1x2-2F20-W | T222 | (2) 7w 2' T8 LED B |
| Second | Closet | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Restroom | 1 | 1x2-2F20-W | T222 | (2) 7w 2' T8 LED B |
| Second | Stairwell 4 | 2 | 1x4-2LED15-W | - | No Upgrade |
| Second | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Custodian | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Storage | 2 | 1x8-4FO28-W | T8L44 | (4) 10.5w 4' T8 LED B |
| Second | Women's RR | 3 | 2x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Classroom | 6 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | | 1 | 2x2-3F31U-L | T2UR3 | (3) 7w 2' T8 LED B-Ref |
| Second | Closet | 1 | 1x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Restroom | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Vestibule | 2 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Stairwell 5 | 2 | 2x4-2FP54HO-Vol | 3NE10 | New 23w 1x4 LED Wrap |
| Second | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Teaneck High School Continued

| | | | | | |
|--------|-------------------|----|--------------------|-------|-------------------------------|
| Second | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Stairwell 6 | 2 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Men's RR | 3 | 2x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Bookroom | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | | 4 | 2x4-4FO28-L | T4L42 | (2) 10.5w 4' T8 LED B |
| Second | Closet (Locked) | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Corridor | 16 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Storage | 1 | 2x4-4FO28-L | T4L42 | (2) 10.5w 4' T8 LED B |
| Second | Office | 1 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| Second | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Second | Elevator Lobby | 1 | 2x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | | 2 | 2x4-4FO28-L | T4L42 | (2) 10.5w 4' T8 LED B |
| Second | Telecom | 1 | 1x8-4F40-W | T8L44 | (4) 10.5w 4' T8 LED B |
| Second | Corridor | 20 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Display Case | 1 | 1x4-1FO28-S | T4L11 | (1) 10.5w 4' T8 LED B |
| Second | Auditorium | 28 | HH-150Q | HN183 | New 43w 10-Inch LED Downlight |
| Second | | 13 | HH10-MH175 | HN183 | New 43w 10-Inch LED Downlight |
| Second | | 11 | HH-150Q | HN183 | New 43w 10-Inch LED Downlight |
| Second | | 2 | HH-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Balcony | 15 | HH-150Q | HN183 | New 43w 10-Inch LED Downlight |
| Second | Stage | 8 | 1x4-2FO28-VAP | T8L22 | (2) 10.5w 4' T8 LED B |
| Second | Stairwell | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | | 1 | Bare-LED12A | - | No Upgrade |
| Second | Stairwell | 2 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Third | Student Center | 5 | 1x8-4FO28-Up | T8L44 | (4) 10.5w 4' T8 LED B |
| Third | | 16 | 1x12-6FO28-Up/Down | T8L66 | (6) 10.5w 4' T8 LED B |
| Third | | 36 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Third | Open Office | 8 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Third | Closet | 1 | 2x2-3F31U-L | T2UR2 | (2) 7w 2' T8 LED B-Ref |
| Third | Electrical | 1 | 2x2-3F31U-L | T2UR2 | (2) 7w 2' T8 LED B-Ref |
| Third | Office | 2 | 2x2-3F31U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| Third | Stairwell 8 | 1 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| Third | | 1 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| Third | Holocaust Ctr (Lc | 6 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Third | Corridor | 1 | 1x12-6FO28-Up/Down | T8L66 | (6) 10.5w 4' T8 LED B |
| Third | | 1 | 1x8-4FO28-Up | T8L44 | (4) 10.5w 4' T8 LED B |
| Third | Asian Center | 6 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Third | African Center | 6 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Third | Latin Center | 6 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Third | Peer Center | 5 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Third | Cashier | 1 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Third | Closet | 1 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| Third | Storage | 1 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| Third | Storage | 1 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| Third | Storage | 1 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| Third | Display Case | 2 | 1x4-1F40-S | T4L11 | (1) 10.5w 4' T8 LED B |
| Third | Corridor | 2 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Third | Office | 3 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Teaneck High School Continued

| | | | | | |
|-------|-----------------|----|---------------------|--------|--------------------------------|
| Third | | 1 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| Third | Classroom | 16 | 2x4-3FO28-P18 (2 Ba | T4BL33 | (3) 10.5w 4' T8 LED B-Bi |
| Third | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Third | Women's RR | 4 | 2x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Classroom | 18 | 2x4-3FO28-P18 | T4L33 | (3) 10.5w 4' T8 LED B |
| Third | Closet | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Third | Lab | 1 | 2x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Third | Faculty Rm | 8 | 2x2-2FO28U-L | T2UR3 | (3) 7w 2' T8 LED B-Ref |
| Third | Restroom | 1 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| Third | Restroom | 1 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| Third | Classroom | 15 | 2x4-3FO28-L (2 Bal) | T4BL33 | (3) 10.5w 4' T8 LED B-Bi |
| Third | Laundry | 2 | 2x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | | 4 | 2x4-4FO28-L | T4L42 | (2) 10.5w 4' T8 LED B |
| Third | Corridor | 2 | 2x2-2F31U-L | 6NE01 | New 20w 2x2 LED Flat Panel |
| Third | Storage | 6 | 1x4-2FO28-Dir/Ind | T8L22 | (2) 10.5w 4' T8 LED B |
| Third | Storage | 6 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Storage | 6 | 1x4-2FO28-Dir/Ind | T8L22 | (2) 10.5w 4' T8 LED B |
| Third | Music Room | 36 | 1x4-2FO28-Dir/Ind | T8L22 | (2) 10.5w 4' T8 LED B |
| Third | | 8 | 1x4-2FO28-Up | T8L22 | (2) 10.5w 4' T8 LED B |
| Third | | 4 | 1x8-4FO28-Up | T8L44 | (4) 10.5w 4' T8 LED B |
| Third | Office | 10 | 2x2-3F31U-L | 6NE01 | New 20w 2x2 LED Flat Panel |
| Third | Practice Rm | 1 | 1x4-2F40-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Practice Rm | 1 | 1x4-2F40-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Office | 2 | 2x4-3FO28-P18 | T4L33 | (3) 10.5w 4' T8 LED B |
| Third | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Third | Stairwell 1 | 2 | 2x4-2FP54HO-Vol | 3NE10 | New 23w 1x4 LED Wrap |
| Third | Office (Locked) | 2 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| Third | Cafeteria D | 43 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Third | Counter | 6 | 2x4-3FO28-P18 | T4L33 | (3) 10.5w 4' T8 LED B |
| Third | | 14 | HH7-PL26 | IN12 | New 19w 8-Inch LED Downlight |
| Third | | 5 | 1x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Corridor | 3 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| Third | Kitchen | 5 | Jelly-CF23 | ID09 | (1) 12w Dimmable LED A |
| Third | | 11 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| Third | Cooler | 1 | Jelly-LED8A | - | No Upgrade |
| Third | Cooler | 1 | 1x4-2FO28-VAP | T8L22 | (2) 10.5w 4' T8 LED B |
| Third | Pantry | 3 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| Third | Cafeteria B | 43 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Third | Stairwell 2 | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Classroom | 20 | 2x4-3FO28-P18 (2 Ba | T4BL33 | (3) 10.5w 4' T8 LED B-Bi |
| Third | Office | 2 | 2x4-3FO28-P18 (2 Ba | T4BL33 | (3) 10.5w 4' T8 LED B-Bi |
| Third | Classroom | 17 | 2x4-3FO28-P18 (2 Ba | T4BL33 | (3) 10.5w 4' T8 LED B-Bi |
| Third | | 5 | 2x2-3F31U-P9 | T2UR3 | (3) 7w 2' T8 LED B-Ref |
| Third | Office | 3 | 2x4-3FO28-L (2 Bal) | T4BL33 | (3) 10.5w 4' T8 LED B-Bi |
| Third | Lab | 2 | 2x4-4FO28-Surf | T4L44 | (4) 10.5w 4' T8 LED B |
| Third | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Third | Custodian | 1 | Dome-Circ54 | IN30 | v 24w 16-Inch LED Deco Flush M |
| Third | Men's RR | 2 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| Third | Closet (Locked) | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Third | Classroom | 15 | 2x4-3FO28-P18 (2 Ba | T4BL33 | (3) 10.5w 4' T8 LED B-Bi |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Teaneck High School Continued

| | | | | | |
|----------|-------------------|----|---------------------|--------|----------------------------------|
| Third | Classroom | 15 | 2x4-3FO28-P18 | T4L33 | (3) 10.5w 4' T8 LED B |
| Third | Stairwell 3 | 2 | 1x4-2LED15-W | - | No Upgrade |
| Third | Classroom | 6 | Chandelier-(4)PL42 | I84 | 4) 10.5w Horizontal LED 4-Pin PL |
| Third | | 6 | Chandelier-(5)PL42 | I85 | 5) 10.5w Horizontal LED 4-Pin PL |
| Third | Workroom | 3 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Third | Classroom | 4 | Chandelier-(4)PL42 | I84 | 4) 10.5w Horizontal LED 4-Pin PL |
| Third | | 4 | Chandelier-(5)PL42 | I85 | 5) 10.5w Horizontal LED 4-Pin PL |
| Third | Workroom | 2 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Third | Electrical | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Third | Stairwell 4 | 2 | 1x4-2LED15-W | - | No Upgrade |
| Third | Classroom | 6 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Third | Classroom | 18 | 2x4-3FO28-P18 (2 Ba | T4BL33 | (3) 10.5w 4' T8 LED B-Bi |
| Third | Custodian (Locke | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Third | Women's RR | 4 | 2x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Classroom | 19 | 2x4-3FO28-P18 (2 Ba | T4BL33 | (3) 10.5w 4' T8 LED B-Bi |
| Third | Closet | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Storage | 3 | 2x4-3FO28-Surf | T4L32 | (2) 10.5w 4' T8 LED B |
| Third | Break Room | 1 | 2x4-3FO28-Surf | T4L32 | (2) 10.5w 4' T8 LED B |
| Third | Restroom | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Third | Storage | 1 | 2x4-3FO28-Surf | T4L32 | (2) 10.5w 4' T8 LED B |
| Third | Closet | 1 | 1x4-2FO28-VAP | T8L22 | (2) 10.5w 4' T8 LED B |
| Third | Closet | 1 | Bare-60A | ID08 | (1) 10w Dimmable LED A |
| Third | Storage | 1 | 1x4-2FO28-VAP | T8L22 | (2) 10.5w 4' T8 LED B |
| Third | Closet | 1 | Bare-60A | ID08 | (1) 10w Dimmable LED A |
| Third | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Third | Stairwell 5 | 2 | 1x4-2LED15-W | - | No Upgrade |
| Third | Classroom | 15 | 2x4-3FO28-P18 (2 Ba | T4BL33 | (3) 10.5w 4' T8 LED B-Bi |
| Third | Classroom | 12 | 2x4-3FO28-P18 (2 Ba | T4BL33 | (3) 10.5w 4' T8 LED B-Bi |
| Third | Stairwell | 2 | 1x4-2LED15-W | - | No Upgrade |
| Third | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Third | Men's RR | 4 | 2x4-2FO28-L | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Open Office | 2 | 2x4-3FO28-P18 | T4L33 | (3) 10.5w 4' T8 LED B |
| Third | | 3 | 1x4-2FO28-Dir/Ind | T8L22 | (2) 10.5w 4' T8 LED B |
| Third | Classroom | 16 | 2x4-3FO28-P18 (2 Ba | T4BL33 | (3) 10.5w 4' T8 LED B-Bi |
| Third | Classroom | 9 | 2x4-3FO28-L | T4L33 | (3) 10.5w 4' T8 LED B |
| Third | Office | 3 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| Third | Elevator Lobby | 3 | 2x4-4FO28-L | T4L44 | (4) 10.5w 4' T8 LED B |
| Third | Mechanical | 2 | 1x4-2F40-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Control Room | 1 | 2x4-2FO28-Surf | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Corridor | 3 | HH-LED12A | - | No Upgrade |
| Third | | 13 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Corridor | 20 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | | 6 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Display Case | 6 | 1x4-2FO28-IH | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Above Display Ca | 4 | 1x4-2FO28-S | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Corridor | 17 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Corridor | 10 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Corridor | 26 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Third | Display Case | 1 | 1x4-1FO28-S | T4L11 | (1) 10.5w 4' T8 LED B |
| Exterior | Building Perimete | 7 | Wallpack-LED20 | - | No Upgrade |
| Exterior | | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Teaneck High School Continued

| | | | | | |
|-----------|-----------------|--------------|--------------------|-------|-----------------------------|
| Exterior | | 3 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| Exterior | | 1 | Sconce-CF23 | ID09 | (1) 12w Dimmable LED A |
| Exterior | | 3 | Canopy-(2)PL18 | HN190 | New 14w LED Canopy |
| Exterior | | 1 | Flood-HPS150 | HN95 | New 31w LED Flood |
| Exterior | | 3 | Wallpack-CF23 | ID09 | (1) 12w Dimmable LED A |
| Exterior | | 2 | Flood-LED25 | - | No Upgrade |
| Exterior | | 2 | Wallpack-Cut-LED30 | - | No Upgrade |
| Garage | Garage (Locked) | 4 | 1x8-2F96-VAP | 5NE30 | New 41w 1x8 LED Low Bay |
| All Areas | Emergency BB | 50 | (Battery Backup) | \E28 | Emergency Back-Up LED Strip |
| | | Total | 2599 | | |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Thomas Jefferson Middle School

| PROJECT: Teaneck PS - Thomas Jefferson MS - New Fixtures - R3 | | | | | |
|---|-------------------------|-----------------------|-------------------|---------------------------|----------------------------|
| Room Info | | Existing Fixture Info | | Lighting Fixture Upgrades | |
| X | | X | X | X | X |
| Floor | Location | No. of Fix. | Fixture Type | ECM No. | Upgrade Description |
| Second | Stairwell | 2 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Second | Stairwell | 2 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second | Women's Restroom | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second | | 1 | 1x4-2FO28-W (E) | 3NE10 | New 23w 1x4 LED Wrap |
| Second | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Men's Restroom | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second | | 1 | 1x4-2FO28-W (E) | 3NE10 | New 23w 1x4 LED Wrap |
| Second | | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Women's Restroom | 2 | 1x4-2FO28-W (E) | 3NE10 | New 23w 1x4 LED Wrap |
| Second | | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second | Asst Principal Restroom | 4 | 1x8-4FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Second | | 1 | 1x4-2FO28-W (E) | 3NE10 | New 23w 1x4 LED Wrap |
| Second | Book Room | 8 | Drum-CF23 | ID08 | (1) 10w Dimmable LED A |
| Second | Classroom | 8 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Second | Prep Room | 3 | 1x8-4FO28-Fin | 7NE27 | New 30w 2x4 LED Flat Panel |
| Second | Greenhouse | 1 | Sconce-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Classroom | 8 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 1x8-4FO28-Fin | 7NE27 | New 30w 2x4 LED Flat Panel |
| Second | | 2 | 1x4-2FO28-FIN | 7NE27 | New 30w 2x4 LED Flat Panel |
| Second | Corridor | 16 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Corridor | 11 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Classroom | 15 | 2x4-3FO28-L (2 Ba | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second | Stairwell | 2 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second | Art Room | 29 | 1x4-2FO28-FIN | 3NE28 | New 40w 1x4 LED Flat Panel |
| Second | Storage | 4 | Drum-CF18 | ID07 | (1) 6w Dimmable LED A |
| Second | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Second | Men's Restroom | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second | | 1 | 1x4-2FO28-W (E) | 3NE10 | New 23w 1x4 LED Wrap |
| Second | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Custodian | 2 | Drum-CF18 | ID07 | (1) 6w Dimmable LED A |
| Second | Women's Restroom | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second | | 1 | 1x4-2FO28-W (E) | 3NE10 | New 23w 1x4 LED Wrap |
| Second | Stairwell | 2 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Thomas Jefferson Middle School Continued

| | | | | | |
|--------|---------------------|----|------------------|-------|------------------------------|
| Second | Classroom | 2 | 1x8-4FO28-Fin | 7NE27 | New 30w 2x4 LED Flat Panel |
| Second | | 2 | 1x4-2FO28-FIN | 7NE27 | New 30w 2x4 LED Flat Panel |
| Second | Media Center | 48 | 1x4-2FO28-Surf | 3NE28 | New 40w 1x4 LED Flat Panel |
| Second | | 4 | 2x4-4FO28-Surf | 7NE26 | New 50w 2x4 LED Flat Panel |
| Second | | 4 | HH-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second | Office | 3 | 1x4-2FO28-Surf | 3NE10 | New 23w 1x4 LED Wrap |
| Second | Mechanical | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Second | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Second | | 3 | 1x8-4FO28-W | 7NE28 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Second | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | Garage (Locked) | 3 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| First | Corridor | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Men's Locker Room | 27 | 1x4-2FO28-VAP | 3NE10 | New 23w 1x4 LED Wrap |
| First | | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | | 4 | HH-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Closet | 2 | Drum-CF18 | ID07 | (1) 6w Dimmable LED A |
| First | Office | 2 | 2x4-4FO28-Surf | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Restroom | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | Closet | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Gym | 20 | High Bay-6FP54HC | 9NE11 | New 177w Linear LED High Bay |
| First | Storage | 1 | 1x4-2LED15-W | - | No Upgrade |
| First | Storage | 2 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Closet | 1 | Bare-CF13 | ID07 | (1) 6w Dimmable LED A |
| First | Women's Locker Room | 28 | 1x4-2FO28-VAP | 3NE10 | New 23w 1x4 LED Wrap |
| First | | 3 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | | 7 | HH-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Office | 2 | 2x4-4FO28-Surf | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Restroom | 2 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Closet | 2 | Drum-CF18 | ID07 | (1) 6w Dimmable LED A |
| First | Closet | 1 | Bare-CF13 | ID07 | (1) 6w Dimmable LED A |
| First | Closet | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Vestibule | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Cafeteria | 32 | 1x8-4FO28-W | 5NE31 | New 78w 1x8 LED Low Bay |
| First | | 1 | Soda Machine | S01 | Vending Miser |
| First | | 1 | Snack Machine | S02 | Snack Miser |
| First | Faculty Dining | 10 | 2x2-LED20-L | - | No Upgrade |
| First | | 1 | Soda Machine | S01 | Vending Miser |
| First | Copy Room | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | Closet | 2 | Drum-CF18 | ID07 | (1) 6w Dimmable LED A |
| First | Kitchen | 22 | 1x8-4FO28-IH | 5NE31 | New 78w 1x8 LED Low Bay |
| First | | 6 | 1x4-2FO28-IH | 3NE46 | New 23w 1x4 LED Low Bay |
| First | | 8 | Jelly-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Storage | 1 | 2x4-4FO28-L | T4L42 | (2) 10.5w 4' T8 LED B |
| First | Storage | 4 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| First | Closet (Locked) | 1 | Bare-CF13 | ID07 | (1) 6w Dimmable LED A |
| First | Office | 2 | 1x4-2FO28-IH | 3NE46 | New 23w 1x4 LED Low Bay |
| First | Cooler | 1 | Jelly-CF23 | ID09 | (1) 12w Dimmable LED A |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Thomas Jefferson Middle School Continued

| | | | | | |
|-------|------------------|----|-------------------|-------|------------------------------|
| First | Restroom | 3 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Child Study | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Office | 1 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Office | 1 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Office | 1 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Classroom | 6 | 2x4-4FO28-L | 7NE26 | New 50w 2x4 LED Flat Panel |
| First | Guidance | 4 | 2x4-3FO28-P18 (2 | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Office | 3 | 2x4-3FO28-P18 (2 | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Closet | 1 | Bare-CF13 | ID07 | (1) 6w Dimmable LED A |
| First | Office | 3 | 2x4-3FO28-P18 (2 | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Office | 3 | 2x4-3FO28-P18 (2 | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Classroom | 6 | 1x8-4FO28-W | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | | 3 | 2x4-4FO28-L | 7NE26 | New 50w 2x4 LED Flat Panel |
| First | Custodian | 2 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| First | | 1 | 1x8-4FO28-Fin | 5NE30 | New 41w 1x8 LED Low Bay |
| First | Boiler Room | 4 | 2x4-4FO28-Surf | T4L44 | (4) 10.5w 4' T8 LED B |
| First | | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | | 3 | 1x8-4FO28-W | T4L44 | (4) 10.5w 4' T8 LED B |
| First | Classroom | 9 | 2x4-3FO28-L (2 Ba | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Book Room | 4 | Drum-CF18 | ID07 | (1) 6w Dimmable LED A |
| First | Corridor | 13 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Stairwell | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Women's Restroom | 2 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | School Store | 4 | Drum-60A | ID08 | (1) 10w Dimmable LED A |
| First | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Men's Restroom | 2 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | Classroom | 6 | 2x4-4FO28-L | 7NE26 | New 50w 2x4 LED Flat Panel |
| First | | 2 | HH8-2PL26 | IN12 | New 19w 8-Inch LED Downlight |
| First | Classroom | 4 | 2x4-4FO28-L | 7NE26 | New 50w 2x4 LED Flat Panel |
| First | | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Classroom | 6 | 2x4-4FO28-L | 7NE26 | New 50w 2x4 LED Flat Panel |
| First | Classroom | 6 | 2x4-3FO28-L (2 Ba | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | | 2 | 1x4-2FO28-L | 3NE28 | New 40w 1x4 LED Flat Panel |
| First | Classroom | 6 | 2x4-LED40-L | - | No Upgrade |
| First | | 3 | 1x4-2LED15-W | - | No Upgrade |
| First | Classroom | 6 | 2x4-LED40-L | - | No Upgrade |
| First | | 3 | 1x4-2LED15-W | - | No Upgrade |
| First | Kiln | 2 | 1x4-2LED15-W | - | No Upgrade |
| First | Stairwell | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Classroom | 2 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | Nurse | 6 | 2x4-3FO28-P18 | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Restroom | 2 | Drum-CF18 | ID07 | (1) 6w Dimmable LED A |
| First | Exam Room | 1 | 2x4-3FO28-P18 | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Exam Room | 1 | 2x4-3FO28-P18 | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Restroom | 2 | Drum-CF18 | ID07 | (1) 6w Dimmable LED A |
| First | Men's Restroom | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Women's Restroom | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Thomas Jefferson Middle School Continued

| | | | | | |
|-------|---------------------|----|-------------------|-------|----------------------------|
| First | Storage | 1 | Bare-60A | ID08 | (1) 10w Dimmable LED A |
| First | Vestibule | 2 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Classroom | 8 | 2x4-3FO28-L (2 Ba | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Classroom | 6 | 2x4-3FO28-L (2 Ba | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Corridor | 9 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Vestibule | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Lobby | 10 | Chandelier-LED27 | - | No Upgrade |
| First | | 3 | 1x4-1FO28-S | T4L11 | (1) 10.5w 4' T8 LED B |
| First | | 1 | HH-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Vestibule | 6 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Corridor | 7 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Storage | 1 | Bare-60A | ID08 | (1) 10w Dimmable LED A |
| First | Vocal Music | 24 | 1x4-2FO28-Surf | 3NE28 | New 40w 1x4 LED Flat Panel |
| First | Office | 4 | 1x4-2FO28-Surf | 3NE10 | New 23w 1x4 LED Wrap |
| First | Band Room | 33 | 1x4-2FO28-Surf | 3NE28 | New 40w 1x4 LED Flat Panel |
| First | Vestibule | 1 | 1x4-2FO28-Surf | 3NE10 | New 23w 1x4 LED Wrap |
| First | Practice Room | 1 | 1x4-2FO28-Surf | 3NE10 | New 23w 1x4 LED Wrap |
| First | Practice Room | 1 | 1x4-2FO28-Surf | 3NE10 | New 23w 1x4 LED Wrap |
| First | Practice Room | 2 | 1x4-2FO28-Surf | 3NE10 | New 23w 1x4 LED Wrap |
| First | Stairwell | 2 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Studio | 4 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | | 2 | 1x4-2FO28-FIN | 7NE27 | New 30w 2x4 LED Flat Panel |
| First | Dressing Room | 4 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | | 30 | Bare-CF13 | ID07 | (1) 6w Dimmable LED A |
| First | Mechanical | 2 | Work-75A | ID09 | (1) 12w Dimmable LED A |
| First | Wardrobe | 6 | Drum-CF18 | ID07 | (1) 6w Dimmable LED A |
| First | Women's Locker Room | 3 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Men's Locker Room | 3 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Stairwell | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | | 1 | Sconce-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Stage | 7 | Work-CF42 | ID10 | (1) 17w Dimmable LED A |
| First | Auditorium | 35 | HH-250R40 | - | No Upgrade |
| First | | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Vestibule | 4 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Main Office | 10 | 2x2-2FO28U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | | 4 | 1x4-2FO28-Surf | 3NE10 | New 23w 1x4 LED Wrap |
| First | File Room | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | Restroom | 2 | Drum-CF18 | ID07 | (1) 6w Dimmable LED A |
| First | Open Office | 3 | 2x2-2FO28U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Principal | 4 | 2x2-2FO28U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Closet | 2 | Drum-CF18 | ID07 | (1) 6w Dimmable LED A |
| First | Closet | 4 | Drum-CF18 | ID07 | (1) 6w Dimmable LED A |
| First | Closet | 2 | Drum-CF18 | ID07 | (1) 6w Dimmable LED A |
| First | Asst Principal | 4 | 2x2-2FO28U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Restroom | 2 | Drum-CF18 | ID07 | (1) 6w Dimmable LED A |
| First | Vestibule | 2 | Drum-CF18 | ID07 | (1) 6w Dimmable LED A |
| First | Closet | 2 | Drum-CF18 | ID07 | (1) 6w Dimmable LED A |
| First | Corridor | 15 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First | Classroom | 10 | 2x4-4FO28-L | 7NE26 | New 50w 2x4 LED Flat Panel |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Thomas Jefferson Middle School Continued

| | | | | | |
|-----------|--------------------|--------------|------------------|-------|--------------------------------|
| First | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | Stairwell | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| First | Stairwell | 1 | 1x4-2LED15-W | - | No Upgrade |
| First | | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Women's Restroom | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | | 1 | 1x4-2FO28-W (E) | 3NE10 | New 23w 1x4 LED Wrap |
| First | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First | Men's Restroom | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | | 1 | 1x4-2FO28-W (E) | 3NE10 | New 23w 1x4 LED Wrap |
| First | Women's Restroom | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First | | 1 | 1x4-2FO28-W (E) | 3NE10 | New 23w 1x4 LED Wrap |
| First | Server (Locked) | 3 | 1x8-4FO28-W | T4L44 | (4) 10.5w 4' T8 LED B |
| First | Faculty (Locked) | 3 | 1x8-4FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| First | Restroom | 1 | 2x2-2FO28U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| First | Mechanical | 1 | 1x4-2FO28-Surf | T4L22 | (2) 10.5w 4' T8 LED B |
| Ground | Stairwell | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Ground | | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| Ground | Classroom | 12 | 2x4-4FO28-W | 7NE26 | New 50w 2x4 LED Flat Panel |
| Ground | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Ground | Corridor | 5 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground | | 1 | HH6-PL26 | IN22 | New 13.5w 6-Inch LED Downlight |
| Ground | Classroom | 13 | 2x4-3FO28-P18 (2 | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground | | 12 | HH6-2PL26 | IN22 | New 13.5w 6-Inch LED Downlight |
| Ground | Classroom | 10 | 2x4-3FO28-P18 (2 | 7NE24 | New 30w 2x4 LED Flat Panel |
| Ground | | 2 | 2x2-3F31U-P9 | 6NE04 | New 30w 2x2 LED Flat Panel |
| Ground | | 2 | 2x2-2FO28U-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| Ground | | 7 | HH6-2PL26 | IN22 | New 13.5w 6-Inch LED Downlight |
| Ground | Storage | 2 | 2x4-4FO28-Surf | T4L42 | (2) 10.5w 4' T8 LED B |
| Ground | Classroom | 6 | 1x8-4FO28-Fin | 7NE28 | New 40w 2x4 LED Flat Panel |
| Ground | Classroom | 12 | 2x4-4FO28-W | 7NE26 | New 50w 2x4 LED Flat Panel |
| Exterior | Building Perimeter | 19 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| Exterior | | 4 | Flood-LED100 | - | No Upgrade |
| Exterior | | 1 | Wallpack-Cut-LED | - | No Upgrade |
| Exterior | | 2 | Flood-MH250 | HN103 | New 89w LED Flood |
| Exterior | Canopy | 9 | 1x4-1FO28-VAP | T4L11 | (1) 10.5w 4' T8 LED B |
| All Areas | Emergency BB | 30 | (Battery Backup) | 1E28 | Emergency Back-Up LED Strip |
| | | Total | 1160 | | |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Whittier Elementary School

| PROJECT: Teaneck PS - Whittier Elementary - R3 | | | | | |
|--|--------------------|-----------------------|----------------|---------------------------|-------------------------------|
| Room Info | | Existing Fixture Info | | Lighting Fixture Upgrades | |
| x | | x | | x | |
| Floor | Location | No. of Fix. | Fixture Type | ECM No. | Upgrade Description |
| Second Floor | Custodian (Locked) | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second Floor | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Women's Restroom | 2 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second Floor | Speech | 1 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Restroom | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second Floor | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Stairwell | 1 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Second Floor | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Men's Restroom | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second Floor | Custodian (Locked) | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second Floor | Classroom | 8 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 8 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Stairwell | 1 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Second Floor | Classroom | 8 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 8 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 8 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Custodian | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Second Floor | Restroom | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second Floor | Computer Room | 9 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Media Center | 21 | 2x4-3FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Storage | 3 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| Second Floor | Stairwell | 1 | 2x4-2FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second Floor | | 1 | 2x4-2FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second Floor | Classroom | 16 | 2x4-3FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 16 | 2x4-3FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 7 | 2x4-3FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Corridor | 8 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second Floor | Storage | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Second Floor | Corridor | 4 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second Floor | | 3 | HH6-2PL9 | IN20 | New 8.5w 6-Inch LED Downlight |
| Second Floor | Stairwell | 1 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second Floor | | 1 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second Floor | Classroom | 9 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Closet | 1 | Bare-60A | ID08 | (1) 10w Dimmable LED A |
| Second Floor | | 1 | Bare-CF23 | ID08 | (1) 10w Dimmable LED A |
| Second Floor | Corridor | 28 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Second Floor | | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Second Floor | Women's Restroom | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Second Floor | Restroom | 1 | Drum-CF23 | ID09 | (1) 12w Dimmable LED A |
| Second Floor | Corridor | 4 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Whittier Elementary School Continued

| | | | | | |
|--------------|--------------------|----|----------------|-------|-------------------------------|
| Second Floor | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Stairwell | 1 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Second Floor | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | | 1 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Break Room | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second Floor | Men's Restroom | 2 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Second Floor | Corridor | 15 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Second Floor | | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Second Floor | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Second Floor | Storage (Locked) | 1 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Second Floor | Stairwell | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Second Floor | Closet | 1 | Bare-60A | ID08 | (1) 10w Dimmable LED A |
| Second Floor | Corridor | 9 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Second Floor | | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| First Floor | Main Office | 5 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First Floor | Mail Room | 1 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First Floor | Office | 5 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First Floor | Restroom | 1 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First Floor | Stairwell | 1 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| First Floor | | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| First Floor | | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First Floor | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 6 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 14 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| First Floor | | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First Floor | Stairwell | 1 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| First Floor | Classroom (Locked) | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom (Locked) | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| First Floor | Women's Restroom | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First Floor | Custodian | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First Floor | Men's Restroom | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First Floor | Classroom (Locked) | 12 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| First Floor | Stairwell | 2 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First Floor | | 2 | HH6-2PL9 | IN20 | New 8.5w 6-Inch LED Downlight |
| First Floor | Corridor | 7 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| First Floor | | 23 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| First Floor | Elevator Machine | 1 | 1x4-1FO28-W | T4L11 | (1) 10.5w 4' T8 LED B |
| First Floor | Classroom | 7 | 2x4-3FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom (Locked) | 6 | 2x4-3FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 8 | 2x4-3FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 16 | 2x4-3FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| First Floor | Stairwell | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First Floor | Cafeteria | 32 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First Floor | Office | 2 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First Floor | Kitchen | 4 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First Floor | Restroom | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| First Floor | Custodian (Locked) | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First Floor | Corridor | 11 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First Floor | Classroom | 12 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 12 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Whittier Elementary School

| | | | | | |
|-------------|---------------------|----|------------------|-------|------------------------------|
| First Floor | Classroom | 12 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| First Floor | Stairwell | 1 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| First Floor | | 1 | Square-CF23 | ID09 | (1) 12w Dimmable LED A |
| First Floor | Classroom | 9 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| First Floor | Classroom | 9 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| First Floor | Men's Restroom | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First Floor | Restroom | 1 | Round-LED15 | - | No Upgrade |
| First Floor | Women's Restroom (L | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First Floor | Corridor | 25 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| First Floor | | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| First Floor | | 3 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First Floor | | 2 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First Floor | Vestibule | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| First Floor | Gym | 20 | High Bay-6FP54HO | 9NE11 | New 177w Linear LED High Bay |
| First Floor | Office | 1 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First Floor | Stage | 12 | Bare-CF23 | IRD25 | (1) 8w Dimmable LED R30 |
| First Floor | Pump (Locked) | 2 | 1x4-2FO28-VAP | T4L22 | (2) 10.5w 4' T8 LED B |
| First Floor | Child Study Team | 2 | 2x4-4FO28-L | 7NE25 | New 40w 2x4 LED Flat Panel |
| First Floor | Closet | 2 | Drum-CF23 | ID09 | (1) 12w Dimmable LED A |
| First Floor | Restroom | 2 | Drum-CF23 | ID09 | (1) 12w Dimmable LED A |
| First Floor | Office | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First Floor | Nurse | 5 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First Floor | Restroom | 1 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First Floor | Exam Room | 1 | 2x4-3FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| First Floor | Storage (Locked) | 1 | 2x4-3FO28-L | T4L32 | (2) 10.5w 4' T8 LED B |
| First Floor | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| First Floor | Stairwell | 1 | 1x8-2FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| First Floor | Vestibule | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| First Floor | Classroom | 6 | 2x4-4FO28-Surf | 7NE25 | New 40w 2x4 LED Flat Panel |
| Basement | Stairwell | 1 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Basement | | 1 | 1x4-2FO28-L | 3NE28 | New 40w 1x4 LED Flat Panel |
| Basement | Office | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Basement | Open Office | 3 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Basement | | 2 | 2x2-3FO17-L | 6NE04 | New 30w 2x2 LED Flat Panel |
| Basement | Server Room | 1 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Basement | | 1 | 1x4-2FO28-L | 3NE28 | New 40w 1x4 LED Flat Panel |
| Basement | Corridor | 5 | 1x4-2FO28-W | 3NE10 | New 23w 1x4 LED Wrap |
| Basement | | 1 | 1x8-4FO28-W | 5NE30 | New 41w 1x8 LED Low Bay |
| Basement | | 1 | 1x2-2FO17-W | 1NE03 | New 18w 1x2 LED Wrap |
| Basement | Restroom | 1 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Basement | Storage | 5 | 1x8-4FO28-W | T8L44 | (4) 10.5w 4' T8 LED B |
| Basement | | 3 | 2x2-2FO28U-L | T2UR2 | (2) 7w 2' T8 LED B-Ref |
| Basement | Boiler Room | 10 | 2x4-4FO28-Surf | T4L44 | (4) 10.5w 4' T8 LED B |
| Basement | Office | 6 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Basement | Storage | 4 | 1x8-4FO28-W | T8L44 | (4) 10.5w 4' T8 LED B |
| Basement | | 2 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Basement | Water Meter | 1 | 2x4-4FO28-Surf | T4L44 | (4) 10.5w 4' T8 LED B |
| Basement | | 1 | Bare-60A | ID08 | (1) 10w Dimmable LED A |
| Basement | Stairwell | 1 | 1x4-1FO28-W | 3NE46 | New 23w 1x4 LED Low Bay |
| Basement | File Room | 2 | 2x4-4FO28-L | 7NE24 | New 30w 2x4 LED Flat Panel |
| Basement | Storage | 2 | 1x8-4FO28-W | T8L44 | (4) 10.5w 4' T8 LED B |

Teaneck Public Schools Energy Savings Plan

Lighting Upgrades Whittier Elementary School


| | | | | | |
|-----------|--------------------|--------------|------------------|-------|--------------------------------|
| Basement | | 2 | 1x4-2FO28-W | T4L22 | (2) 10.5w 4' T8 LED B |
| Basement | Crawl Space | 1 | Bare-CF23 | ID09 | (1) 12w Dimmable LED A |
| Exterior | Building Perimeter | 3 | Sconce-CF23 | ID09 | (1) 12w Dimmable LED A |
| Exterior | | 3 | Flood-LED15 | - | No Upgrade |
| Exterior | | 6 | Square-(2)PL18 | HN190 | New 14w LED Canopy |
| Exterior | | 4 | Wallpack-LED40 | - | No Upgrade |
| Exterior | | 2 | Flood-HPS150 | HN102 | New 74w LED Flood |
| Exterior | | 1 | Flood-90PAR38 | IRD24 | (1) 13w Wet Location LED Par38 |
| Exterior | Flag Courtyard | 1 | Square-(2)PL18 | HN190 | New 14w LED Canopy |
| All Areas | Emergency BB | 30 | (Battery Backup) | \E28 | Emergency Back-Up LED Strip |
| | | Total | 700 | | |

Teaneck Public Schools Energy Savings Plan

Data Logger Reports

Benjamin Franklin Middle School

| Area Type Averages | | | | Normalized Weekly Lights On | | | | Normalized Weekly Occupied | | | | | | |
|-------------------------------|-----|-------|-----|-----------------------------|------|---------|---------|----------------------------|-------|------|---------|---------|-------|-------|
| Area Type | Qty | Watts | | Peak | Off | Shldr 1 | Shldr 2 | Total | Peak | Off | Shldr 1 | Shldr 2 | Total | % sav |
| Classroom | CR | 4 | 100 | 30.51 | 0.00 | 0.00 | 0.00 | 30.51 | 24.26 | 0.00 | 0.00 | 0.00 | 24.26 | 20.49 |
| Common Area | CA | 1 | 100 | 48.22 | 0.00 | 0.00 | 0.00 | 48.22 | 42.41 | 0.00 | 0.00 | 0.00 | 42.41 | 12.06 |
| Hallway | H | 4 | 100 | 70.99 | 0.00 | 0.00 | 0.00 | 70.99 | 43.72 | 0.00 | 0.00 | 0.00 | 43.72 | 38.41 |
| Library | LI | 1 | 100 | 39.09 | 0.00 | 0.00 | 0.00 | 39.09 | 37.72 | 0.00 | 0.00 | 0.00 | 37.72 | 3.52 |
| MultiPurpose Rm | MP | 1 | 100 | 29.19 | 0.00 | 0.00 | 0.00 | 29.19 | 28.07 | 0.00 | 0.00 | 0.00 | 28.07 | 3.83 |
| Office | O | 3 | 100 | 50.44 | 0.00 | 0.00 | 0.00 | 50.44 | 42.19 | 0.00 | 0.00 | 0.00 | 42.19 | 16.36 |
| Restroom | R | 3 | 100 | 71.77 | 0.00 | 0.00 | 0.00 | 71.77 | 29.66 | 0.00 | 0.00 | 0.00 | 29.66 | 58.67 |
| Building Average for 17 rooms | | | 100 | 52.31 | 0.00 | 0.00 | 0.00 | 52.31 | 35.05 | 0.00 | 0.00 | 0.00 | 35.05 | 33.00 |




Hours per Week for each Area Type.

Teaneck Public Schools Energy Savings Plan

Whittier Elementary School

| Area Type Averages | | | | Normalized Weekly Lights On | | | | | Normalized Weekly Occupied | | | | | |
|-------------------------------|-----|-------|------|-----------------------------|---------|---------|-------|-------|----------------------------|---------|---------|-------|-------|-------|
| Area Type | Qty | Watts | Peak | Off | Shldr 1 | Shldr 2 | Total | Peak | Off | Shldr 1 | Shldr 2 | Total | % sav | |
| Cafeteria | CF | 1 | 100 | 60.88 | 0.00 | 0.00 | 0.00 | 60.88 | 54.06 | 0.00 | 0.00 | 0.00 | 54.06 | 11.21 |
| Classroom | CR | 5 | 100 | 30.74 | 0.00 | 0.00 | 0.00 | 30.74 | 29.34 | 0.00 | 0.00 | 0.00 | 29.34 | 4.56 |
| Gym | G | 1 | 100 | 59.45 | 0.00 | 0.00 | 0.00 | 59.45 | 37.40 | 0.00 | 0.00 | 0.00 | 37.40 | 37.08 |
| Hallway | H | 3 | 100 | 70.08 | 0.00 | 0.00 | 0.00 | 70.08 | 52.50 | 0.00 | 0.00 | 0.00 | 52.50 | 25.08 |
| Library | LI | 1 | 100 | 26.61 | 0.00 | 0.00 | 0.00 | 26.61 | 26.61 | 0.00 | 0.00 | 0.00 | 26.61 | 0.00 |
| Office | O | 2 | 100 | 35.64 | 0.00 | 0.00 | 0.00 | 35.64 | 34.45 | 0.00 | 0.00 | 0.00 | 34.45 | 3.35 |
| Restroom | R | 1 | 100 | 58.59 | 0.00 | 0.00 | 0.00 | 58.59 | 36.05 | 0.00 | 0.00 | 0.00 | 36.05 | 38.47 |
| Building Average for 14 rooms | | | 100 | 45.80 | 0.00 | 0.00 | 0.00 | 45.80 | 37.68 | 0.00 | 0.00 | 0.00 | 37.68 | 17.74 |




Hours per Week for each Area Type.

Teaneck Public Schools Energy Savings Plan

Bryant Elementary School

| Area Type Averages | | | | Normalized Weekly Lights On | | | | | Normalized Weekly Occupied | | | | | % sav |
|-------------------------------|-----|-------|------|-----------------------------|---------|---------|-------|-------|----------------------------|---------|---------|-------|-------|-------|
| Area Type | Qty | Watts | Peak | Off | Shldr 1 | Shldr 2 | Total | Peak | Off | Shldr 1 | Shldr 2 | Total | | |
| Cafeteria | CF | 1 | 100 | 75.29 | 0.00 | 0.00 | 0.00 | 75.29 | 61.98 | 0.00 | 0.00 | 0.00 | 61.98 | 17.68 |
| Classroom | CR | 5 | 100 | 43.11 | 0.00 | 0.00 | 0.00 | 43.11 | 29.98 | 0.00 | 0.00 | 0.00 | 29.98 | 30.45 |
| Gym | G | 1 | 100 | 0.35 | 0.00 | 0.00 | 0.00 | 0.35 | 0.33 | 0.00 | 0.00 | 0.00 | 0.33 | 5.88 |
| Hallway | H | 3 | 100 | 78.97 | 0.00 | 0.00 | 0.00 | 78.97 | 62.25 | 0.00 | 0.00 | 0.00 | 62.25 | 21.16 |
| Library | LI | 1 | 100 | 41.36 | 0.00 | 0.00 | 0.00 | 41.36 | 18.81 | 0.00 | 0.00 | 0.00 | 18.81 | 54.52 |
| Office | O | 1 | 100 | 31.75 | 0.00 | 0.00 | 0.00 | 31.75 | 13.56 | 0.00 | 0.00 | 0.00 | 13.56 | 57.29 |
| Restroom | R | 2 | 100 | 71.35 | 0.00 | 0.00 | 0.00 | 71.35 | 29.79 | 0.00 | 0.00 | 0.00 | 29.79 | 58.25 |
| Building Average for 14 rooms | | | 100 | 53.13 | 0.00 | 0.00 | 0.00 | 53.13 | 35.07 | 0.00 | 0.00 | 0.00 | 35.07 | 34.00 |




Hours per Week for each Area Type.

Teaneck Public Schools Energy Savings Plan

Hawthorne Elementary School

| Area Type Averages | | | | Normalized Weekly Lights On | | | | | Normalized Weekly Occupied | | | | | |
|-------------------------------|----|-----|-------|-----------------------------|------|---------|---------|-------|----------------------------|------|---------|---------|-------|-------|
| Area Type | | Qty | Watts | Peak | Off | Shldr 1 | Shldr 2 | Total | Peak | Off | Shldr 1 | Shldr 2 | Total | % sav |
| Cafeteria | CF | 1 | 100 | 67.29 | 0.00 | 0.00 | 0.00 | 67.29 | 59.42 | 0.00 | 0.00 | 0.00 | 59.42 | 11.69 |
| Classroom | CR | 4 | 100 | 32.56 | 0.00 | 0.00 | 0.00 | 32.56 | 29.91 | 0.00 | 0.00 | 0.00 | 29.91 | 8.16 |
| Gym | G | 1 | 100 | 21.72 | 0.00 | 0.00 | 0.00 | 21.72 | 15.43 | 0.00 | 0.00 | 0.00 | 15.43 | 28.93 |
| Hallway | H | 3 | 100 | 68.33 | 0.00 | 0.00 | 0.00 | 68.33 | 48.02 | 0.00 | 0.00 | 0.00 | 48.02 | 29.72 |
| Library | LI | 1 | 100 | 40.66 | 0.00 | 0.00 | 0.00 | 40.66 | 34.88 | 0.00 | 0.00 | 0.00 | 34.88 | 14.22 |
| Office | O | 2 | 100 | 39.01 | 0.00 | 0.00 | 0.00 | 39.01 | 36.00 | 0.00 | 0.00 | 0.00 | 36.00 | 7.72 |
| Restroom | R | 1 | 100 | 19.88 | 0.00 | 0.00 | 0.00 | 19.88 | 19.88 | 0.00 | 0.00 | 0.00 | 19.88 | 0.00 |
| Building Average for 13 rooms | | | 100 | 43.29 | 0.00 | 0.00 | 0.00 | 43.29 | 35.79 | 0.00 | 0.00 | 0.00 | 35.79 | 17.32 |




Hours per Week for each Area Type.

Teaneck Public Schools Energy Savings Plan

Lowell Elementary School

| Area Type Averages | | | Normalized Weekly Lights On | | | | | Normalized Weekly Occupied | | | | | | |
|-------------------------------|-----|-------|-----------------------------|-------|---------|---------|-------|----------------------------|-------|---------|---------|-------|-------|-------|
| Area Type | Qty | Watts | Peak | Off | Shldr 1 | Shldr 2 | Total | Peak | Off | Shldr 1 | Shldr 2 | Total | % sav | |
| Cafeteria | CF | 1 | 100 | 71.04 | 0.00 | 0.00 | 0.00 | 71.04 | 58.85 | 0.00 | 0.00 | 0.00 | 58.85 | 17.16 |
| Classroom | CR | 5 | 100 | 28.46 | 0.00 | 0.00 | 0.00 | 28.46 | 25.28 | 0.00 | 0.00 | 0.00 | 25.28 | 11.17 |
| Gym | G | 1 | 100 | 38.10 | 0.00 | 0.00 | 0.00 | 38.10 | 28.21 | 0.00 | 0.00 | 0.00 | 28.21 | 25.95 |
| Hallway | H | 3 | 100 | 65.58 | 0.00 | 0.00 | 0.00 | 65.58 | 53.11 | 0.00 | 0.00 | 0.00 | 53.11 | 19.01 |
| Library | LI | 1 | 100 | 51.47 | 0.00 | 0.00 | 0.00 | 51.47 | 37.56 | 0.00 | 0.00 | 0.00 | 37.56 | 27.03 |
| Office | O | 2 | 100 | 33.91 | 0.00 | 0.00 | 0.00 | 33.91 | 29.13 | 0.00 | 0.00 | 0.00 | 29.13 | 14.11 |
| Restroom | R | 2 | 100 | 62.19 | 0.00 | 0.00 | 0.00 | 62.19 | 27.53 | 0.00 | 0.00 | 0.00 | 27.53 | 55.74 |
| Building Average for 15 rooms | | | 100 | 46.09 | 0.00 | 0.00 | 0.00 | 46.09 | 34.88 | 0.00 | 0.00 | 0.00 | 34.88 | 24.32 |




Hours per Week for each Area Type.

Teaneck Public Schools Energy Savings Plan

Thomas Jefferson Middle School

| Area Type Averages | | | | Normalized Weekly Lights On | | | | | Normalized Weekly Occupied | | | | | |
|-------------------------------|----|-----|-------|-----------------------------|------|---------|---------|-------|----------------------------|------|---------|---------|-------|-------|
| Area Type | | Qty | Watts | Peak | Off | Shldr 1 | Shldr 2 | Total | Peak | Off | Shldr 1 | Shldr 2 | Total | % sav |
| Classroom | CR | 9 | 100 | 28.74 | 0.00 | 0.00 | 0.00 | 28.74 | 24.19 | 0.00 | 0.00 | 0.00 | 24.19 | 15.85 |
| Hallway | H | 2 | 100 | 79.90 | 0.00 | 0.00 | 0.00 | 79.90 | 69.55 | 0.00 | 0.00 | 0.00 | 69.55 | 12.95 |
| Library | LI | 1 | 100 | 59.93 | 0.00 | 0.00 | 0.00 | 59.93 | 44.45 | 0.00 | 0.00 | 0.00 | 44.45 | 25.83 |
| Locker Rm | | 1 | 100 | 54.35 | 0.00 | 0.00 | 0.00 | 54.35 | 25.20 | 0.00 | 0.00 | 0.00 | 25.20 | 53.63 |
| Open Office | OO | 1 | 100 | 5.07 | 0.00 | 0.00 | 0.00 | 5.07 | 4.03 | 0.00 | 0.00 | 0.00 | 4.03 | 20.53 |
| Restroom | R | 2 | 100 | 50.55 | 0.00 | 0.00 | 0.00 | 50.55 | 24.93 | 0.00 | 0.00 | 0.00 | 24.93 | 50.68 |
| Building Average for 16 rooms | | | 100 | 39.93 | 0.00 | 0.00 | 0.00 | 39.93 | 30.01 | 0.00 | 0.00 | 0.00 | 30.01 | 24.83 |




Hours per Week for each Area Type.

Teaneck Public Schools Energy Savings Plan

Teaneck High School

| Area Type Averages | | | | Normalized Weekly Lights On | | | | | Normalized Weekly Occupied | | | | | |
|-------------------------------|----|-----|-------|-----------------------------|------|---------|---------|--------|----------------------------|------|---------|---------|-------|-------|
| Area Type | CR | Qty | Watts | Peak | Off | Shldr 1 | Shldr 2 | Total | Peak | Off | Shldr 1 | Shldr 2 | Total | % sav |
| Classroom | CR | 6 | 100 | 33.27 | 0.00 | 0.00 | 0.00 | 33.27 | 30.37 | 0.00 | 0.00 | 0.00 | 30.37 | 8.72 |
| Copy Rm | C | 1 | 100 | 70.58 | 0.00 | 0.00 | 0.00 | 70.58 | 40.69 | 0.00 | 0.00 | 0.00 | 40.69 | 42.35 |
| Hallway | H | 5 | 100 | 101.91 | 0.00 | 0.00 | 0.00 | 101.91 | 70.35 | 0.00 | 0.00 | 0.00 | 70.35 | 30.98 |
| Library | LI | 1 | 100 | 61.09 | 0.00 | 0.00 | 0.00 | 61.09 | 49.08 | 0.00 | 0.00 | 0.00 | 49.08 | 19.65 |
| Locker Rm | | 1 | 100 | 70.10 | 0.00 | 0.00 | 0.00 | 70.10 | 36.97 | 0.00 | 0.00 | 0.00 | 36.97 | 47.26 |
| MultiPurpose Rm | MP | 1 | 100 | 69.88 | 0.00 | 0.00 | 0.00 | 69.88 | 53.26 | 0.00 | 0.00 | 0.00 | 53.26 | 23.78 |
| Office | O | 5 | 100 | 50.86 | 0.00 | 0.00 | 0.00 | 50.86 | 33.14 | 0.00 | 0.00 | 0.00 | 33.14 | 34.84 |
| Open Office | OO | 1 | 100 | 51.35 | 0.00 | 0.00 | 0.00 | 51.35 | 49.94 | 0.00 | 0.00 | 0.00 | 49.94 | 2.74 |
| Stairwell | ST | 2 | 100 | 82.19 | 0.00 | 0.00 | 0.00 | 82.19 | 47.29 | 0.00 | 0.00 | 0.00 | 47.29 | 42.46 |
| Building Average for 23 rooms | | | 100 | 63.07 | 0.00 | 0.00 | 0.00 | 63.07 | 44.52 | 0.00 | 0.00 | 0.00 | 44.52 | 29.41 |



Hours per Week for each Area Type.

APPENDIX 7. THIRD PARTY ENERGY SAVINGS PLAN REVIEW COMMENTS & CORRESPONDENCE (DLB ASSOCIATES)
